

**UNITED STATES DEPARTMENT OF AGRICULTURE**  
**FOREST SERVICE**  
**SPECIFICATION FOR**  
**FIRE HOSE, CONNECTIONS AND FITTINGS**

Page 9, Table 7. Hoseline tee with cap and chain configuration. Substitute the following:

Substitute the sixth column heading of “B Centerline Waterway to Maximum Distance inch (mm)” with “C – Inlet Outside Diameter inch (mm).” The values in the column remain unchanged.

Substitute the seventh column heading of “C – Inlet Outside Diameter inch (mm)” with “B Centerline Waterway to Maximum Distance inch (mm).” The values in the column remain unchanged.

Page 11, Paragraph 3.3.1. Connection and Fitting Material. Substitute the following:

- a. Aluminum alloy, 6061-T6, or 6262-T651 (not 6262-T6) in accordance with ASTM B 221 or B241.

Substitute the following for the first part of the second sentence, with items d, e, f and g unchanged:

The material for the hose line tee, cap with chain and hose line tee with valve shall conform to the following: