

**UNITED STATES DEPARTMENT OF AGRICULTURE**  
**FOREST SERVICE**  
**SPECIFICATION FOR**  
**PUMP, ENGINE-DRIVEN**

Page 11

4.7.4.1. Suction Lift Test Condition.

Replace the first sentence with the following:

All pump testing shall be conducted at a 5 foot (1.52 m) +/- 3 inches (76 mm) suction lift.