

Color key:

- Below established thresholds for legionella, metals, and total coliform/E. coli
- Above established thresholds for legionella, metals, and total coliform/E. coli
- Positive for legionella, but below the established threshold

Notes:

- [1] U.S. EPA Primary Drinking Water Standards establish action levels for lead and copper as 15 ppb and 1,300 ppb, respectively.
- [2] CDC guidance defines < 1 CFU/mL for potable sources as the threshold for systems where legionella growth appears to be well controlled.
- [3] ppb means parts per billion.
- [4] CFU/mL means Colony Forming Units per milliliter.
- [5] ND means Legionella was not detected in the sample analyzed.
- [6] Column headers indicate when samples were pulled pre or post-filter.

985 Michigan Federal Building Water Testing Summary				Monthly Round 1 (3/26 -3/27)		Monthly Round 2 (4/23 -4/24)	
Plumbing Outlet Unique Identifier (for publication)	Floor	Analysis	Units	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER
LL15-1 Meter Room-Water Main Service Line	LL	E.Coli	--		Absent		Absent
LL15-1 Meter Room-Water Main Service Line	LL	Total Coliform	--		Absent		Absent
LL15-1 Meter Room-Water Main Service Line	LL	Lead	ppb		2.6		0
LL15-1 Meter Room-Water Main Service Line	LL	Copper	ppb		40		12
LL15-1 Meter Room-Water Main Service Line	LL	Legionella Culture	CFU/mL		ND		ND
LL16 Fire Pump Room-Water Main Service Line	LL	E.Coli	--		Absent		Absent
LL16 Fire Pump Room-Water Main Service Line	LL	Total Coliform	--		Absent		Absent
LL16 Fire Pump Room-Water Main Service Line	LL	Lead	ppb		0		12
LL16 Fire Pump Room-Water Main Service Line	LL	Copper	ppb		27		0
LL16 Fire Pump Room-Water Main Service Line	LL	Legionella Culture	CFU/mL		ND		ND
Print, Postal Sorting Area Faucet	LL	Copper	ppb	300	270	250	240
Print, Postal Sorting Area Faucet	LL	E.Coli	--			Absent	Absent
Print, Postal Sorting Area Faucet	LL	Lead	ppb	0	0	0	0
Print, Postal Sorting Area Faucet	LL	Total Coliform	--			Absent	Absent

Print, Postal Sorting Area Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND
LLW-1 Women-Lavatory Faucet-Left	LL	E.Coli	--				
LLW-1 Women-Lavatory Faucet-Left	LL	Total Coliform	--				
LLW-1 Women-Lavatory Faucet-Left	LL	Lead	ppb				
LLW-1 Women-Lavatory Faucet-Left	LL	Copper	ppb				
LLW-1 Women-Lavatory Faucet-Left	LL	Legionella Culture	CFU/mL				
LLW-1 Women-Lavatory Faucet-Right	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND
LLW-1 Women-Lavatory Faucet-Right	LL	Copper	ppb	760	410	790	500
LLW-1 Women-Lavatory Faucet-Right	LL	E.Coli	--	Absent	Absent	Absent	Absent
LLW-1 Women-Lavatory Faucet-Right	LL	Lead	ppb	5.6	0	1.9	0
LLW-1 Women-Lavatory Faucet-Right	LL	Total Coliform	--	Absent	Absent	Absent	Absent
LLM-1 Men-Lavatory Faucet-Left	LL	Legionella Culture	CFU/mL				
LLM-1 Men-Lavatory Faucet-Left	LL	Copper	ppb				
LLM-1 Men-Lavatory Faucet-Left	LL	E.Coli	--				
LLM-1 Men-Lavatory Faucet-Left	LL	Lead	ppb				
LLM-1 Men-Lavatory Faucet-Left	LL	Total Coliform	--				
LLM-1 Men-Lavatory Faucet-Right	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND
LLM-1 Men-Lavatory Faucet-Right	LL	Copper	ppb	160	140	480	450
LLM-1 Men-Lavatory Faucet-Right	LL	E.Coli	--	Absent	Absent	Absent	Absent
LLM-1 Men-Lavatory Faucet-Right	LL	Lead	ppb	0	0	0	0
LLM-1 Men-Lavatory Faucet-Right	LL	Total Coliform	--	Absent	Absent	Absent	Absent
LL Corridor North - Drinking Fountain-Left	LL	Legionella Culture	CFU/mL				
LL Corridor North - Drinking Fountain-Left	LL	Copper	ppb				
LL Corridor North - Drinking Fountain-Left	LL	E.Coli	--				
LL Corridor North - Drinking Fountain-Left	LL	Lead	ppb				
LL Corridor North - Drinking Fountain-Left	LL	Total Coliform	--				
LL15 Men's Restroom - Lavatory Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND
LL15 Men's Restroom - Lavatory Faucet	LL	Copper	ppb	870	1400	210	290
LL15 Men's Restroom - Lavatory Faucet	LL	E.Coli	--	Absent	Absent	Absent	Absent
LL15 Men's Restroom - Lavatory Faucet	LL	Lead	ppb	1.7	0	0	0
LL15 Men's Restroom - Lavatory Faucet	LL	Total Coliform	--	Absent	Absent	Absent	Absent

LL15 Women's Restroom - Lavatory Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND
LL15 Women's Restroom - Lavatory Faucet	LL	Copper	ppb	1100	1200	350	510
LL15 Women's Restroom - Lavatory Faucet	LL	E.Coli	--	Absent	Absent	Absent	Absent
LL15 Women's Restroom - Lavatory Faucet	LL	Lead	ppb	0	0	0	0
LL15 Women's Restroom - Lavatory Faucet	LL	Total Coliform	--	Absent	Absent	Absent	Absent
LL15 Break Room-Kitchen Faucet	LL	E.Coli	--	Absent	Absent	Absent	Absent
LL15 Break Room-Kitchen Faucet	LL	Total Coliform	--	Absent	Absent	Absent	Absent
LL15 Break Room-Kitchen Faucet	LL	Lead	ppb	3.3	0	0	0
LL15 Break Room-Kitchen Faucet	LL	Copper	ppb	200	180	440	210
LL15 Break Room-Kitchen Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Legionella Culture	CFU/mL	0.4	ND	ND	ND
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Copper	ppb	300	170	190	92
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	E.Coli	--	Absent	Absent	Absent	Absent
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Lead	ppb	3.1	0	2	0
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Total Coliform	--	Absent	Absent	Absent	Absent
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Copper	ppb	450	270	760	230
108-4 Cafe Prep. - Kitchen Faucet-Large	1	E.Coli	--	Absent	Absent	Absent	Absent
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Lead	ppb	0	0	0	0
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Total Coliform	--	Absent	Absent	Absent	Absent
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Copper	ppb	340	440	1700	910
108-4 Cafe Prep. - Kitchen Faucet-Small	1	E.Coli	--	Absent	Absent	Absent	Absent
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Lead	ppb	0	0	0	0
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Total Coliform	--	Absent	Absent	Absent	Absent
GSA Suite Kitchenette-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
GSA Suite Kitchenette-Sink/Faucet	1	Copper	ppb	1200	290	410	390
GSA Suite Kitchenette-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
GSA Suite Kitchenette-Sink/Faucet	1	Lead	ppb	0	0	0	0
GSA Suite Kitchenette-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent
1 Corridor South - Drinking Fountain-Left	1	Legionella Culture	CFU/mL				

1 Corridor South - Drinking Fountain-Left	1	Copper	ppb				
1 Corridor South - Drinking Fountain-Left	1	E.Coli	--				
1 Corridor South - Drinking Fountain-Left	1	Lead	ppb				
1 Corridor South - Drinking Fountain-Left	1	Total Coliform	--				
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL				
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Copper	ppb				
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	E.Coli	--				
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Lead	ppb				
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Total Coliform	--				
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	Copper	ppb	2800	250	440	260
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	E.Coli	--	Absent	Absent	Absent	Absent
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	Lead	ppb	28	0	6.6	0
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	Total Coliform	--	Absent	Absent	Absent	Absent
1M-1 Men's Restroom North - Lavatory Faucet-Rigl	1	Legionella Culture	CFU/mL				
1M-1 Men's Restroom North - Lavatory Faucet-Rigl	1	Copper	ppb				
1M-1 Men's Restroom North - Lavatory Faucet-Rigl	1	E.Coli	--				
1M-1 Men's Restroom North - Lavatory Faucet-Rigl	1	Lead	ppb				
1M-1 Men's Restroom North - Lavatory Faucet-Rigl	1	Total Coliform	--				
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL				
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Copper	ppb				
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	E.Coli	--				
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Lead	ppb				
1M-2 Men's Restroom South - Lavatory Faucet-Left	1	Total Coliform	--				
1M-2 Men's Restroom South - Lavatory Faucet-Rigl	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
1M-2 Men's Restroom South - Lavatory Faucet-Rigl	1	Copper	ppb	4100	1100	890	1300
1M-2 Men's Restroom South - Lavatory Faucet-Rigl	1	E.Coli	--	Absent	Absent	Absent	Absent
1M-2 Men's Restroom South - Lavatory Faucet-Rigl	1	Lead	ppb	0	0	0	0
1M-2 Men's Restroom South - Lavatory Faucet-Rigl	1	Total Coliform	--	Absent	Absent	Absent	Absent
1W-1 Women's Restroom North - Lavatory Faucet-	1	Legionella Culture	CFU/mL				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Copper	ppb				

1W-1 Women's Restroom North - Lavatory Faucet-	1	E.Coli	--				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Lead	ppb				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Total Coliform	--				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Legionella Culture	CFU/mL			ND	ND
1W-1 Women's Restroom North - Lavatory Faucet-	1	Copper	ppb				
1W-1 Women's Restroom North - Lavatory Faucet-	1	E.Coli	--				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Lead	ppb				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Total Coliform	--				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Legionella Culture	CFU/mL	ND	ND		
1W-1 Women's Restroom North - Lavatory Faucet-	1	Copper	ppb	3000	390	740	360
1W-1 Women's Restroom North - Lavatory Faucet-	1	E.Coli	--	Absent	Absent	Absent	Absent
1W-1 Women's Restroom North - Lavatory Faucet-	1	Lead	ppb	12	0	2	0
1W-1 Women's Restroom North - Lavatory Faucet-	1	Total Coliform	--	Absent	Absent	Absent	Absent
1W-2 Women's Restroom South - Lavatory Faucet-	1	Legionella Culture	CFU/mL				
1W-2 Women's Restroom South - Lavatory Faucet-	1	Copper	ppb				
1W-2 Women's Restroom South - Lavatory Faucet-	1	E.Coli	--				
1W-2 Women's Restroom South - Lavatory Faucet-	1	Lead	ppb				
1W-2 Women's Restroom South - Lavatory Faucet-	1	Total Coliform	--				
1W-2 Women's Restroom South - Lavatory Faucet-	1	Legionella Culture	CFU/mL	8	ND	4.8	ND
1W-2 Women's Restroom South - Lavatory Faucet-	1	Copper	ppb	540	800	520	
1W-2 Women's Restroom South - Lavatory Faucet-	1	E.Coli	--	Absent	Absent	Absent	Absent
1W-2 Women's Restroom South - Lavatory Faucet-	1	Lead	ppb	0	0	3.1	0
1W-2 Women's Restroom South - Lavatory Faucet-	1	Total Coliform	--	Absent	Absent	Absent	Absent
119-21 Faucet/Eyewash	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
119-21 Faucet/Eyewash	1	Copper	ppb	1200	210	82	74
119-21 Faucet/Eyewash	1	E.Coli	--	Absent	Absent	Absent	Absent
119-21 Faucet/Eyewash	1	Lead	ppb	0	3.5	0	0
119-21 Faucet/Eyewash	1	Total Coliform	--	Absent	Absent	Absent	Absent
119-16A Shower	1	Legionella Culture	CFU/mL		ND		ND
119-16A Shower	1	Copper	ppb		330		190
119-16A Shower	1	E.Coli	--		Absent		Absent

119-16A Shower	1	Lead	ppb		0		0
119-16A Shower	1	Total Coliform	--		Absent		Absent
119-17 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
119-17 Toilet/Sink Combo	1	Copper	ppb	1200	960	150	70
119-17 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent
119-17 Toilet/Sink Combo	1	Lead	ppb	0	0	0	0
119-17 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent
119-19 Food Storage Room-Sink/Faucet	1	Legionella Culture	CFU/mL				
119-19 Food Storage Room-Sink/Faucet	1	Copper	ppb				
119-19 Food Storage Room-Sink/Faucet	1	E.Coli	--				
119-19 Food Storage Room-Sink/Faucet	1	Lead	ppb				
119-19 Food Storage Room-Sink/Faucet	1	Total Coliform	--				
119-11 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
119-11 Toilet/Sink Combo	1	Copper	ppb	2300	110	140	51
119-11 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent
119-11 Toilet/Sink Combo	1	Lead	ppb	0	1.5	0	0
119-11 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent
119-10 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
119-10 Toilet/Sink Combo	1	Copper	ppb	2500	130	150	56
119-10 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent
119-10 Toilet/Sink Combo	1	Lead	ppb	0	2	2.1	0
119-10 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent
119-07 Toilet/Sink Combo-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
119-07 Toilet/Sink Combo-Left	1	Copper	ppb	1100	120	140	61
119-07 Toilet/Sink Combo-Left	1	E.Coli	--	Absent	Absent	Absent	Absent
119-07 Toilet/Sink Combo-Left	1	Lead	ppb	0	0	0	0
119-07 Toilet/Sink Combo-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent
119-07 Toilet/Sink Combo-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
119-07 Toilet/Sink Combo-Right	1	Copper	ppb	910	120	140	70
119-07 Toilet/Sink Combo-Right	1	E.Coli	--	Absent	Absent	Absent	Absent
119-07 Toilet/Sink Combo-Right	1	Lead	ppb	0	0	0	0

119-07 Toilet/Sink Combo-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent
119-08 Toilet/Sink Combo-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
119-08 Toilet/Sink Combo-Left	1	Copper	ppb	920	130	130	63
119-08 Toilet/Sink Combo-Left	1	E.Coli	--	Absent	Absent	Absent	Absent
119-08 Toilet/Sink Combo-Left	1	Lead	ppb	0	0	0	0
119-08 Toilet/Sink Combo-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent
119-08 Toilet/Sink Combo-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
119-08 Toilet/Sink Combo-Right	1	Copper	ppb	1100	490	150	61
119-08 Toilet/Sink Combo-Right	1	E.Coli	--	Absent	Absent	Absent	Absent
119-08 Toilet/Sink Combo-Right	1	Lead	ppb	0	1.2	0	0
119-08 Toilet/Sink Combo-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent
128-01 Lactation Room A-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
128-01 Lactation Room A-Sink/Faucet	1	Copper	ppb	1500	370	220	120
128-01 Lactation Room A-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
128-01 Lactation Room A-Sink/Faucet	1	Lead	ppb	0	0	0	0
128-01 Lactation Room A-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent
128-02 Lactation Room B-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
128-02 Lactation Room B-Sink/Faucet	1	Copper	ppb	1200	350	230	130
128-02 Lactation Room B-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
128-02 Lactation Room B-Sink/Faucet	1	Lead	ppb	0	0	1.1	0
128-02 Lactation Room B-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent
128-03 Lactation Room C-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
128-03 Lactation Room C-Sink/Faucet	1	Copper	ppb	1200	340	140	81
128-03 Lactation Room C-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
128-03 Lactation Room C-Sink/Faucet	1	Lead	ppb	0	0	0	0
128-03 Lactation Room C-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent
128-04 Lactation Room D-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
128-04 Lactation Room D-Sink/Faucet	1	Copper	ppb	1200	290	330	350
128-04 Lactation Room D-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
128-04 Lactation Room D-Sink/Faucet	1	Lead	ppb	0	0	0	0
128-04 Lactation Room D-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent

119-02 Mailroom - Faucet	1	Legionella Culture	CFU/mL				
119-02 Mailroom - Faucet	1	Copper	ppb				
119-02 Mailroom - Faucet	1	E.Coli	--				
119-02 Mailroom - Faucet	1	Lead	ppb				
119-02 Mailroom - Faucet	1	Total Coliform	--				
C105-1 Janitor's Closet - Mop/Slop Sink	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
C105-1 Janitor's Closet - Mop/Slop Sink	1	Copper	ppb	190	140	470	220
C105-1 Janitor's Closet - Mop/Slop Sink	1	E.Coli	--	Absent	Absent	Absent	Absent
C105-1 Janitor's Closet - Mop/Slop Sink	1	Lead	ppb	0	0	0	0
C105-1 Janitor's Closet - Mop/Slop Sink	1	Total Coliform	--	Absent	Absent	Absent	Absent
1 Corridor North - Drinking Fountain-Left	1	Legionella Culture	CFU/mL				
1 Corridor North - Drinking Fountain-Left	1	Copper	ppb				
1 Corridor North - Drinking Fountain-Left	1	E.Coli	--				
1 Corridor North - Drinking Fountain-Left	1	Lead	ppb				
1 Corridor North - Drinking Fountain-Left	1	Total Coliform	--				
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	Copper	ppb	83	62	50	84
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	E.Coli	--	Absent	Absent	Absent	Absent
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	Lead	ppb	1.3	1.5	0	0
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	Total Coliform	--	Absent	Absent	Absent	Absent
1U-1 Loading Dock - Lavatory Faucet	1	Legionella Culture	CFU/mL				
1U-1 Loading Dock - Lavatory Faucet	1	Copper	ppb				
1U-1 Loading Dock - Lavatory Faucet	1	E.Coli	--				
1U-1 Loading Dock - Lavatory Faucet	1	Lead	ppb				
1U-1 Loading Dock - Lavatory Faucet	1	Total Coliform	--				
113-6 JLL Kitchenette-Kitchen Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
113-6 JLL Kitchenette-Kitchen Faucet	1	Copper	ppb	790	1700	870	690
113-6 JLL Kitchenette-Kitchen Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
113-6 JLL Kitchenette-Kitchen Faucet	1	Lead	ppb	7.1	0	2.2	0
113-6 JLL Kitchenette-Kitchen Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent
123-05 Health Unit - Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND

123-05 Health Unit - Sink/Faucet	1	Copper	ppb	480	410	320	220
123-05 Health Unit - Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
123-05 Health Unit - Sink/Faucet	1	Lead	ppb	0	0	0	0
123-05 Health Unit - Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent
123-08 Health Unit-Lavatory Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
123-08 Health Unit-Lavatory Faucet	1	Copper	ppb	4100	1900	1600	1200
123-08 Health Unit-Lavatory Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
123-08 Health Unit-Lavatory Faucet	1	Lead	ppb	0	0	0	0
123-08 Health Unit-Lavatory Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent
123-07 Health Unit-Lavatory Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
123-07 Health Unit-Lavatory Faucet	1	Copper	ppb	1800	2200	1300	1200
123-07 Health Unit-Lavatory Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent
123-07 Health Unit-Lavatory Faucet	1	Lead	ppb	0	0	0	0
123-07 Health Unit-Lavatory Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-05 Men-Lavatory Faucet-Left	1	Legionella Culture	CFU/mL				
126-05 Men-Lavatory Faucet-Left	1	Copper	ppb				
126-05 Men-Lavatory Faucet-Left	1	E.Coli	--				
126-05 Men-Lavatory Faucet-Left	1	Lead	ppb				
126-05 Men-Lavatory Faucet-Left	1	Total Coliform	--				
126-05 Men-Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-05 Men-Lavatory Faucet-Center	1	Copper	ppb	1100	720	1300	630
126-05 Men-Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent	Absent	Absent
126-05 Men-Lavatory Faucet-Center	1	Lead	ppb	0	3.1	0	0
126-05 Men-Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-05 Men-Lavatory Faucet-Right	1	Legionella Culture	CFU/mL				
126-05 Men-Lavatory Faucet-Right	1	Copper	ppb				
126-05 Men-Lavatory Faucet-Right	1	E.Coli	--				
126-05 Men-Lavatory Faucet-Right	1	Lead	ppb				
126-05 Men-Lavatory Faucet-Right	1	Total Coliform	--				
126-06 Shower Room - Shower-North-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-06 Shower Room - Shower-North-Left	1	Copper	ppb	1300	960	560	490

126-06 Shower Room - Shower-North-Left	1	E.Coli	--	Absent	Absent	Absent	Absent
126-06 Shower Room - Shower-North-Left	1	Lead	ppb	0	0	0	0
126-06 Shower Room - Shower-North-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-06 Shower Room-Shower-North-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-06 Shower Room-Shower-North-Center	1	Copper	ppb	1100	820	510	160
126-06 Shower Room-Shower-North-Center	1	E.Coli	--	Absent	Absent	Absent	Absent
126-06 Shower Room-Shower-North-Center	1	Lead	ppb	0	0	0	0
126-06 Shower Room-Shower-North-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-06 Shower Room - Shower-North-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-06 Shower Room - Shower-North-Right	1	Copper	ppb	910	810	370	330
126-06 Shower Room - Shower-North-Right	1	E.Coli	--	Absent	Absent	Absent	Absent
126-06 Shower Room - Shower-North-Right	1	Lead	ppb	0	0	0	0
126-06 Shower Room - Shower-North-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-06 Shower Room - Shower-South-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-06 Shower Room - Shower-South-Left	1	Copper	ppb	1100	860	310	280
126-06 Shower Room - Shower-South-Left	1	E.Coli	--	Absent	Absent	Absent	Absent
126-06 Shower Room - Shower-South-Left	1	Lead	ppb	0	0	0	0
126-06 Shower Room - Shower-South-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-06 Shower Room-Shower-South-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-06 Shower Room-Shower-South-Center	1	Copper	ppb	1100	830	300	240
126-06 Shower Room-Shower-South-Center	1	E.Coli	--	Absent	Absent	Absent	Absent
126-06 Shower Room-Shower-South-Center	1	Lead	ppb	0	0	0	0
126-06 Shower Room-Shower-South-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-06 Shower Room - Shower-South-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-06 Shower Room - Shower-South-Right	1	Copper	ppb	1200	660	180	230
126-06 Shower Room - Shower-South-Right	1	E.Coli	--	Absent	Absent	Absent	Absent
126-06 Shower Room - Shower-South-Right	1	Lead	ppb	0	0	0	0
126-06 Shower Room - Shower-South-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-02 Women-Lavatory Faucet-Left	1	Legionella Culture	CFU/mL				
126-02 Women-Lavatory Faucet-Left	1	Copper	ppb				
126-02 Women-Lavatory Faucet-Left	1	E.Coli	--				

126-02 Women-Lavatory Faucet-Left	1	Lead	ppb				
126-02 Women-Lavatory Faucet-Left	1	Total Coliform	--				
126-02 Women-Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-02 Women-Lavatory Faucet-Center	1	Copper	ppb	1800	590	2200	860
126-02 Women-Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent	Absent	Absent
126-02 Women-Lavatory Faucet-Center	1	Lead	ppb	13	1.5	0	0
126-02 Women-Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-02 Women-Lavatory Faucet-Right	1	Legionella Culture	CFU/mL				
126-02 Women-Lavatory Faucet-Right	1	Copper	ppb				
126-02 Women-Lavatory Faucet-Right	1	E.Coli	--				
126-02 Women-Lavatory Faucet-Right	1	Lead	ppb				
126-02 Women-Lavatory Faucet-Right	1	Total Coliform	--				
126-03 Women-Shower-1st from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-03 Women-Shower-1st from L to R	1	Copper	ppb	930	920	99	240
126-03 Women-Shower-1st from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent
126-03 Women-Shower-1st from L to R	1	Lead	ppb	0	0	0	0
126-03 Women-Shower-1st from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-03 Women-Shower-2nd from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-03 Women-Shower-2nd from L to R	1	Copper	ppb	1100	670	130	250
126-03 Women-Shower-2nd from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent
126-03 Women-Shower-2nd from L to R	1	Lead	ppb	0	0	0	0
126-03 Women-Shower-2nd from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-03 Women-Shower-3rd from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-03 Women-Shower-3rd from L to R	1	Copper	ppb	1100	610	220	200
126-03 Women-Shower-3rd from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent
126-03 Women-Shower-3rd from L to R	1	Lead	ppb	0	0	0	0
126-03 Women-Shower-3rd from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent
126-03 Women-Shower-4th from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND
126-03 Women-Shower-4th from L to R	1	Copper	ppb	740	580	88	160
126-03 Women-Shower-4th from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent
126-03 Women-Shower-4th from L to R	1	Lead	ppb	0	0	0	0

126-03 Women-Shower-4th from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent
2 Corridor West - Drinking Fountain-Left	2	Legionella Culture	CFU/mL				
2 Corridor West - Drinking Fountain-Left	2	Copper	ppb				
2 Corridor West - Drinking Fountain-Left	2	E.Coli	--				
2 Corridor West - Drinking Fountain-Left	2	Lead	ppb				
2 Corridor West - Drinking Fountain-Left	2	Total Coliform	--				
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Legionella Culture	CFU/mL				
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Copper	ppb				
2W-2 Women's Restroom West - Lavatory Faucet-L	2	E.Coli	--				
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Lead	ppb				
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Total Coliform	--				
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Legionella Culture	CFU/mL	ND	ND	ND	ND
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Copper	ppb	1200	260	2500	470
2W-2 Women's Restroom West - Lavatory Faucet-C	2	E.Coli	--	Absent	Absent	Absent	Absent
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Lead	ppb	0	0	0	0
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Total Coliform	--	Absent	Absent	Absent	Absent
2W-2 Women's Restroom West - Lavatory Faucet-F	2	Legionella Culture	CFU/mL				
2W-2 Women's Restroom West - Lavatory Faucet-F	2	Copper	ppb				
2W-2 Women's Restroom West - Lavatory Faucet-F	2	E.Coli	--				
2W-2 Women's Restroom West - Lavatory Faucet-F	2	Lead	ppb				
2W-2 Women's Restroom West - Lavatory Faucet-F	2	Total Coliform	--				
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL				
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Copper	ppb				
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	E.Coli	--				
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Lead	ppb				
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Total Coliform	--				
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Legionella Culture	CFU/mL	ND	ND	ND	ND
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Copper	ppb	660	300	870	350
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	E.Coli	--	Absent	Absent	Absent	Absent
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Lead	ppb	13	0	4.3	0
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Total Coliform	--	Absent	Absent	Absent	Absent

2W-1 Women's Restroom East - Lavatory Faucet-L	2	Legionella Culture	CFU/mL				
2W-1 Women's Restroom East - Lavatory Faucet-L	2	Copper	ppb				
2W-1 Women's Restroom East - Lavatory Faucet-L	2	E.Coli	--				
2W-1 Women's Restroom East - Lavatory Faucet-L	2	Lead	ppb				
2W-1 Women's Restroom East - Lavatory Faucet-L	2	Total Coliform	--				
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Legionella Culture	CFU/mL				
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Copper	ppb				
2W-1 Women's Restroom East - Lavatory Faucet-C	2	E.Coli	--				
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Lead	ppb				
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Total Coliform	--				
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Legionella Culture	CFU/mL	ND	ND	ND	ND
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Copper	ppb	2600	210	520	340
2W-1 Women's Restroom East - Lavatory Faucet-R	2	E.Coli	--	Absent	Absent	Absent	Absent
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Lead	ppb	12	0	0	0
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Total Coliform	--	Absent	Absent	Absent	Absent
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL				
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Copper	ppb				
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	E.Coli	--				
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Lead	ppb				
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Total Coliform	--				
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Legionella Culture	CFU/mL	13.6	ND	ND	ND
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Copper	ppb	2200	210	3900	360
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	E.Coli	--	Absent	Absent	Absent	Absent
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Lead	ppb	0	0	11	0
2M-1 Men's Restroom East - Lavatory Faucet-Right	2	Total Coliform	--	Absent	Absent	Absent	Absent
234 Kitchen Faucet (209-04)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND
234 Kitchen Faucet (209-04)	2	Copper	ppb	810	770	190	250
234 Kitchen Faucet (209-04)	2	E.Coli	--	Absent	Absent	Absent	Absent
234 Kitchen Faucet (209-04)	2	Lead	ppb	0	0	0	0
234 Kitchen Faucet (209-04)	2	Total Coliform	--	Absent	Absent	Absent	Absent
Break Room North West - Kitchen Faucet (207-14)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND

Break Room North West - Kitchen Faucet (207-14)	2	Copper	ppb	1100	650	280	810
Break Room North West - Kitchen Faucet (207-14)	2	E.Coli	--	Absent	Absent	Absent	Absent
Break Room North West - Kitchen Faucet (207-14)	2	Lead	ppb	0	0	0	0
Break Room North West - Kitchen Faucet (207-14)	2	Total Coliform	--	Absent	Absent	Absent	Absent
Break Room North East Kitchen - Faucet (207-39)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND
Break Room North East Kitchen - Faucet (207-39)	2	Copper	ppb	1200	660	250	240
Break Room North East Kitchen - Faucet (207-39)	2	E.Coli	--	Absent	Absent	Absent	Absent
Break Room North East Kitchen - Faucet (207-39)	2	Lead	ppb	0	0	0	0
Break Room North East Kitchen - Faucet (207-39)	2	Total Coliform	--	Absent	Absent	Absent	Absent
Break Room South East Kitchen - Faucet (207-49)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND
Break Room South East Kitchen - Faucet (207-49)	2	Copper	ppb	77	100	630	35
Break Room South East Kitchen - Faucet (207-49)	2	E.Coli	--	Absent	Absent	Absent	Absent
Break Room South East Kitchen - Faucet (207-49)	2	Lead	ppb	0	0	0	0
Break Room South East Kitchen - Faucet (207-49)	2	Total Coliform	--	Absent	Absent	Absent	Absent
E201 Restroom - Lavatory Faucet	2	Legionella Culture	CFU/mL				
E201 Restroom - Lavatory Faucet	2	Copper	ppb				
E201 Restroom - Lavatory Faucet	2	E.Coli	--				
E201 Restroom - Lavatory Faucet	2	Lead	ppb				
E201 Restroom - Lavatory Faucet	2	Total Coliform	--				
C207 Janitor's Closet-Mop/Slop Sink	2	Legionella Culture	CFU/mL				
C207 Janitor's Closet-Mop/Slop Sink	2	Copper	ppb				
C207 Janitor's Closet-Mop/Slop Sink	2	E.Coli	--				
C207 Janitor's Closet-Mop/Slop Sink	2	Lead	ppb				
C207 Janitor's Closet-Mop/Slop Sink	2	Total Coliform	--				
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Legionella Culture	CFU/mL				
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Copper	ppb				
3W-2 Women's Restroom West - Lavatory Faucet-L	3	E.Coli	--				
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Lead	ppb				
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Total Coliform	--				
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Legionella Culture	CFU/mL	ND	1.6	ND	ND
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Copper	ppb	480	98	290	190

3W-2 Women's Restroom West - Lavatory Faucet-C	3	E.Coli	--	Absent	Absent	Absent	Absent
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Lead	ppb	0	0	1.1	6
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Total Coliform	--	Absent	Absent	Absent	Absent
3W-2 Women's Restroom West - Lavatory Faucet-F	3	Legionella Culture	CFU/mL				
3W-2 Women's Restroom West - Lavatory Faucet-F	3	Copper	ppb				
3W-2 Women's Restroom West - Lavatory Faucet-F	3	E.Coli	--				
3W-2 Women's Restroom West - Lavatory Faucet-F	3	Lead	ppb				
3W-2 Women's Restroom West - Lavatory Faucet-F	3	Total Coliform	--				
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	Legionella Culture	CFU/mL	ND	ND	ND	ND
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	Copper	ppb	440	270	170	270
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	E.Coli	--	Absent	Absent	Absent	Absent
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	Lead	ppb	0	0	0	0
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	Total Coliform	--	Absent	Absent		
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Legionella Culture	CFU/mL				
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Copper	ppb				
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	E.Coli	--				
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Lead	ppb				
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Total Coliform	--				
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	Legionella Culture	CFU/mL	ND	1.6	2.8	ND
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	Copper	ppb	3300	170	330	79
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	E.Coli	--	Absent	Absent	Absent	Absent
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	Lead	ppb	43	0	4.4	5.2
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	Total Coliform	--	Absent	Absent	Absent	Absent
3W-1 Women's Restroom East - Lavatory Faucet-L	3	Legionella Culture	CFU/mL				
3W-1 Women's Restroom East - Lavatory Faucet-L	3	Copper	ppb				
3W-1 Women's Restroom East - Lavatory Faucet-L	3	E.Coli	--				
3W-1 Women's Restroom East - Lavatory Faucet-L	3	Lead	ppb				
3W-1 Women's Restroom East - Lavatory Faucet-L	3	Total Coliform	--				
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Legionella Culture	CFU/mL	ND	0.4	0.4	ND
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Copper	ppb	1200	270	500	670
3W-1 Women's Restroom East - Lavatory Faucet-C	3	E.Coli	--	Absent	Absent	Absent	Absent

3W-1 Women's Restroom East - Lavatory Faucet-C	3	Lead	ppb	16	0	6.3	2.3
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Total Coliform	--	Absent	Absent	Absent	Absent
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Legionella Culture	CFU/mL				
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Copper	ppb				
3W-1 Women's Restroom East - Lavatory Faucet-R	3	E.Coli	--				
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Lead	ppb				
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Total Coliform	--				
3 Corridor East - Drinking Fountain-Left	3	Legionella Culture	CFU/mL				
3 Corridor East - Drinking Fountain-Left	3	Copper	ppb				
3 Corridor East - Drinking Fountain-Left	3	E.Coli	--				
3 Corridor East - Drinking Fountain-Left	3	Lead	ppb				
3 Corridor East - Drinking Fountain-Left	3	Total Coliform	--				
C307 Janitor's Closet-Mop/Slop Sink	3	Legionella Culture	CFU/mL				
C307 Janitor's Closet-Mop/Slop Sink	3	Copper	ppb				
C307 Janitor's Closet-Mop/Slop Sink	3	E.Coli	--				
C307 Janitor's Closet-Mop/Slop Sink	3	Lead	ppb				
C307 Janitor's Closet-Mop/Slop Sink	3	Total Coliform	--				
4W-1 Women's Restroom East - Lavatory Faucet-L	4	Legionella Culture	CFU/mL				
4W-1 Women's Restroom East - Lavatory Faucet-L	4	Copper	ppb				
4W-1 Women's Restroom East - Lavatory Faucet-L	4	E.Coli	--				
4W-1 Women's Restroom East - Lavatory Faucet-L	4	Lead	ppb				
4W-1 Women's Restroom East - Lavatory Faucet-L	4	Total Coliform	--				
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Legionella Culture	CFU/mL	7.2	4	1.6	ND
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Copper	ppb	1100	130	71	280
4W-1 Women's Restroom East - Lavatory Faucet-C	4	E.Coli	--	Absent	Absent	Absent	Absent
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Lead	ppb	52	0	0	0
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Total Coliform	--	Absent	Absent	Absent	Absent
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Legionella Culture	CFU/mL				
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Copper	ppb				
4W-1 Women's Restroom East - Lavatory Faucet-R	4	E.Coli	--				
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Lead	ppb				

4W-1 Women's Restroom East - Lavatory Faucet-R	4	Total Coliform	--				
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL				
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Copper	ppb				
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	E.Coli	--				
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Lead	ppb				
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Total Coliform	--				
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	Legionella Culture	CFU/mL	2.4	ND	ND	ND
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	Copper	ppb	500	300	110	420
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	E.Coli	--	Absent	Absent	Absent	Absent
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	Lead	ppb	0	0	7.3	0
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	Total Coliform	--	Absent	Absent	Absent	Absent
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Legionella Culture	CFU/mL				
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Copper	ppb				
4W-2 Women's Restroom West - Lavatory Faucet-L	4	E.Coli	--				
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Lead	ppb				
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Total Coliform	--				
4W-2 Women's Restroom West - Lavatory Faucet-C	4	Legionella Culture	CFU/mL	ND	ND	ND	ND
4W-2 Women's Restroom West - Lavatory Faucet-C	4	Copper	ppb	4700	170	2000	230
4W-2 Women's Restroom West - Lavatory Faucet-C	4	E.Coli	--	Absent	Absent	Absent	Absent
4W-2 Women's Restroom West - Lavatory Faucet-C	4	Lead	ppb	59	0	34	0
4W-2 Women's Restroom West - Lavatory Faucet-C	4	Total Coliform	--	Absent	Absent	Absent	Absent
4W-2 Women West-Lavatory Faucet-Right	4	Legionella Culture	CFU/mL				
4W-2 Women West-Lavatory Faucet-Right	4	Copper	ppb				
4W-2 Women West-Lavatory Faucet-Right	4	E.Coli	--				
4W-2 Women West-Lavatory Faucet-Right	4	Lead	ppb				
4W-2 Women West-Lavatory Faucet-Right	4	Total Coliform	--				
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL				
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Copper	ppb				
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	E.Coli	--				
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Lead	ppb				
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Total Coliform	--				

4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	Legionella Culture	CFU/mL	ND	ND	ND	ND
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	Copper	ppb	1800	150	180	340
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	E.Coli	--	Absent	Absent	Absent	Absent
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	Lead	ppb	0	0	1.1	0
4M-2 Men's Restroom West - Lavatory Faucet-Righ	4	Total Coliform	--	Absent	Absent	Absent	Absent
4 Corridor West - Drinking Fountain-Left	4	Legionella Culture	CFU/mL				
4 Corridor West - Drinking Fountain-Left	4	Copper	ppb				
4 Corridor West - Drinking Fountain-Left	4	E.Coli	--				
4 Corridor West - Drinking Fountain-Left	4	Lead	ppb				
4 Corridor West - Drinking Fountain-Left	4	Total Coliform	--				
Suite 410 Kitchenette Faucet (NW)	4	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 410 Kitchenette Faucet (NW)	4	Copper	ppb	1800	890	530	520
Suite 410 Kitchenette Faucet (NW)	4	E.Coli	--	Absent	Absent	Absent	Absent
Suite 410 Kitchenette Faucet (NW)	4	Lead	ppb	0	0	0	0
Suite 410 Kitchenette Faucet (NW)	4	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 415 Kitchenette - Faucet (N)	4	Legionella Culture	CFU/mL	ND	ND		
Suite 415 Kitchenette - Faucet (N)	4	Copper	ppb	82	250		
Suite 415 Kitchenette - Faucet (N)	4	E.Coli	--	Absent	Absent		
Suite 415 Kitchenette - Faucet (N)	4	Lead	ppb	0	0		
Suite 415 Kitchenette - Faucet (N)	4	Total Coliform	--	Absent	Absent		
Suite 416 Kitchenette - Faucet (NE) - North	4	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 416 Kitchenette - Faucet (NE) - North	4	Copper	ppb	760	990	230	1500
Suite 416 Kitchenette - Faucet (NE) - North	4	E.Coli	--	Absent	Absent	Absent	Absent
Suite 416 Kitchenette - Faucet (NE) - North	4	Lead	ppb	0	0	0	0
Suite 416 Kitchenette - Faucet (NE) - North	4	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 420 Kitchenette - Faucet (NE) - South	4	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 420 Kitchenette - Faucet (NE) - South	4	Copper	ppb	750	540	140	140
Suite 420 Kitchenette - Faucet (NE) - South	4	E.Coli	--	Absent	Absent	Absent	Absent
Suite 420 Kitchenette - Faucet (NE) - South	4	Lead	ppb	0	0	0	0
Suite 420 Kitchenette - Faucet (NE) - South	4	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 435 Kitchenette Faucet (SE)	4	Legionella Culture	CFU/mL	ND	ND	ND	ND

Suite 435 Kitchenette Faucet (SE)	4	Copper	ppb	610	490	83	100
Suite 435 Kitchenette Faucet (SE)	4	E.Coli	--	Absent	Absent	Absent	Absent
Suite 435 Kitchenette Faucet (SE)	4	Lead	ppb	0	0	0	0
Suite 435 Kitchenette Faucet (SE)	4	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	Copper	ppb	170	200	80	300
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	E.Coli	--	Absent	Absent	Absent	Absent
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	Lead	ppb	0	0	0	0
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 435 Kitchenette Faucet (SE) A (Second fixture)	4	Legionella Culture	CFU/mL	ND	ND	ND	ND
C407 Janitor's Closet-Mop/Slop Sink	4	Legionella Culture	CFU/mL				
C407 Janitor's Closet-Mop/Slop Sink	4	Copper	ppb				
C407 Janitor's Closet-Mop/Slop Sink	4	E.Coli	--				
C407 Janitor's Closet-Mop/Slop Sink	4	Lead	ppb				
C407 Janitor's Closet-Mop/Slop Sink	4	Total Coliform	--				
Suite 540 Kitchenette - Faucet (507-25)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 540 Kitchenette - Faucet (507-25)	5	Copper	ppb	300	600	910	870
Suite 540 Kitchenette - Faucet (507-25)	5	E.Coli	--	Absent	Absent	Absent	Absent
Suite 540 Kitchenette - Faucet (507-25)	5	Lead	ppb	0	0	0	0
Suite 540 Kitchenette - Faucet (507-25)	5	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Copper	ppb	1600	830	1000	1200
Suite 535 Break Room-Kitchen Faucet (507-36)	5	E.Coli	--	Absent	Absent	Absent	Absent
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Lead	ppb	0	0	0	0
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Total Coliform	--	Absent	Absent	Absent	Absent
540 Faucet (507-26)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND
540 Faucet (507-26)	5	Copper	ppb	770	550	480	680
540 Faucet (507-26)	5	E.Coli	--	Absent	Absent	Absent	Absent
540 Faucet (507-26)	5	Lead	ppb	0	0	0	0
540 Faucet (507-26)	5	Total Coliform	--	Absent	Absent	Absent	Absent
540 Faucet (507-26) A (Second fixture)	5	E.Coli	--				
540 Faucet (507-26) A (Second fixture)	5	Total Coliform	--				

540 Faucet (507-26) A (Second fixture)	5	Lead	ppb				
540 Faucet (507-26) A (Second fixture)	5	Copper	ppb				
540 Faucet (507-26) A (Second fixture)	5	Legionella Culture	CFU/mL				
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Legionella Culture	CFU/mL				
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Copper	ppb				
5W-2 Women's Restroom West - Lavatory Faucet-L	5	E.Coli	--				
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Lead	ppb				
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Total Coliform	--				
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Legionella Culture	CFU/mL	ND	ND	ND	ND
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Copper	ppb	920	230	210	210
5W-2 Women's Restroom West - Lavatory Faucet-C	5	E.Coli	--	Absent	Absent	Absent	Absent
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Lead	ppb	25	0	1.6	0
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Total Coliform	--	Absent	Absent	Absent	Absent
5W-2 Women's Restroom West - Lavatory Faucet-F	5	Legionella Culture	CFU/mL				
5W-2 Women's Restroom West - Lavatory Faucet-F	5	Copper	ppb				
5W-2 Women's Restroom West - Lavatory Faucet-F	5	E.Coli	--				
5W-2 Women's Restroom West - Lavatory Faucet-F	5	Lead	ppb				
5W-2 Women's Restroom West - Lavatory Faucet-F	5	Total Coliform	--				
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL				
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Copper	ppb				
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	E.Coli	--				
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Lead	ppb				
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Total Coliform	--				
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	Legionella Culture	CFU/mL	ND	4	ND	0.8
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	Copper	ppb	1300	410	2200	270
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	E.Coli	--	Absent	Absent	Absent	Absent
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	Lead	ppb	0	0	15	0
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	Total Coliform	--	Absent	Absent	Absent	Absent
5 Corridor West - Drinking Fountain-Right	5	Legionella Culture	CFU/mL				
5 Corridor West - Drinking Fountain-Right	5	Copper	ppb				
5 Corridor West - Drinking Fountain-Right	5	E.Coli	--				

5 Corridor West - Drinking Fountain-Right	5	Lead	ppb				
5 Corridor West - Drinking Fountain-Right	5	Total Coliform	--				
Suite 540 Kitchenette - Faucet (507-15)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 540 Kitchenette - Faucet (507-15)	5	Copper	ppb	970	940	830	380
Suite 540 Kitchenette - Faucet (507-15)	5	E.Coli	--	Absent	Absent	Absent	Absent
Suite 540 Kitchenette - Faucet (507-15)	5	Lead	ppb	0	0	0	0
Suite 540 Kitchenette - Faucet (507-15)	5	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 540 Training Lobby - Faucet (507-12)	5	Legionella Culture	CFU/mL				
Suite 540 Training Lobby - Faucet (507-12)	5	Copper	ppb				
Suite 540 Training Lobby - Faucet (507-12)	5	E.Coli	--				
Suite 540 Training Lobby - Faucet (507-12)	5	Lead	ppb				
Suite 540 Training Lobby - Faucet (507-12)	5	Total Coliform	--				
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL				
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Copper	ppb			570	470
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	E.Coli	--			Absent	Absent
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Lead	ppb			7	0
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Total Coliform	--			Absent	Absent
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	Legionella Culture	CFU/mL	ND	ND	ND	0.4
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	Copper	ppb	860	75		
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	E.Coli	--	Absent	Absent		
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	Lead	ppb	22	0		
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	Total Coliform	--	Absent	Absent		
5W-1 Women's Restroom East - Lavatory Faucet-L	5	Legionella Culture	CFU/mL				
5W-1 Women's Restroom East - Lavatory Faucet-L	5	Copper	ppb				
5W-1 Women's Restroom East - Lavatory Faucet-L	5	E.Coli	--				
5W-1 Women's Restroom East - Lavatory Faucet-L	5	Lead	ppb				
5W-1 Women's Restroom East - Lavatory Faucet-L	5	Total Coliform	--				
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Legionella Culture	CFU/mL	0.8	ND	ND	ND
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Copper	ppb	2000	1300	360	400
5W-1 Women's Restroom East - Lavatory Faucet-C	5	E.Coli	--	Absent	Absent	Absent	Absent
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Lead	ppb	51	0	4.6	1.1

5W-1 Women's Restroom East - Lavatory Faucet-C	5	Total Coliform	--	Absent	Absent	Absent	Absent
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Legionella Culture	CFU/mL				
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Copper	ppb				
5W-1 Women's Restroom East - Lavatory Faucet-R	5	E.Coli	--				
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Lead	ppb				
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Total Coliform	--				
Suite 530 Kitchenette - Faucet (509-10)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 530 Kitchenette - Faucet (509-10)	5	Copper	ppb	92	160	390	520
Suite 530 Kitchenette - Faucet (509-10)	5	E.Coli	--	Absent	Absent	Absent	Absent
Suite 530 Kitchenette - Faucet (509-10)	5	Lead	ppb	0	0	0	0
Suite 530 Kitchenette - Faucet (509-10)	5	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 520 Kitchenette Faucet (508-13)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 520 Kitchenette Faucet (508-13)	5	Copper	ppb	1700	1000	900	1600
Suite 520 Kitchenette Faucet (508-13)	5	E.Coli	--	Absent	Absent	Absent	Absent
Suite 520 Kitchenette Faucet (508-13)	5	Lead	ppb	0	0	0	0
Suite 520 Kitchenette Faucet (508-13)	5	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 532 Lactation Room - Faucet	5	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 532 Lactation Room - Faucet	5	Copper	ppb	810	780	1600	790
Suite 532 Lactation Room - Faucet	5	E.Coli	--	Absent	Absent	Absent	Absent
Suite 532 Lactation Room - Faucet	5	Lead	ppb	0	0	0	0
Suite 532 Lactation Room - Faucet	5	Total Coliform	--	Absent	Absent	Absent	Absent
Suite. 540 Kitchenette - Faucet	5	Legionella Culture	CFU/mL				
Suite. 540 Kitchenette - Faucet	5	Copper	ppb				
Suite. 540 Kitchenette - Faucet	5	E.Coli	--				
Suite. 540 Kitchenette - Faucet	5	Lead	ppb				
Suite. 540 Kitchenette - Faucet	5	Total Coliform	--				
C507 Janitor's Closet - Mop/Slop Sink	5	Legionella Culture	CFU/mL				
C507 Janitor's Closet - Mop/Slop Sink	5	Copper	ppb				
C507 Janitor's Closet - Mop/Slop Sink	5	E.Coli	--				
C507 Janitor's Closet - Mop/Slop Sink	5	Lead	ppb				
C507 Janitor's Closet - Mop/Slop Sink	5	Total Coliform	--				

Suite 614 Room-Kitchen Faucet (610-03)	6	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 614 Room-Kitchen Faucet (610-03)	6	Copper	ppb	310	340	300	250
Suite 614 Room-Kitchen Faucet (610-03)	6	E.Coli	--	Absent	Absent	Absent	Absent
Suite 614 Room-Kitchen Faucet (610-03)	6	Lead	ppb	0	0	0	0
Suite 614 Room-Kitchen Faucet (610-03)	6	Total Coliform	--	Absent	Absent	Absent	Absent
C607-Janitor's Closet - Mop/Slop Sink	6	Legionella Culture	CFU/mL				
C607-Janitor's Closet - Mop/Slop Sink	6	Copper	ppb				
C607-Janitor's Closet - Mop/Slop Sink	6	E.Coli	--				
C607-Janitor's Closet - Mop/Slop Sink	6	Lead	ppb				
C607-Janitor's Closet - Mop/Slop Sink	6	Total Coliform	--				
6 Corridor West - Drinking Fountain-Left	6	Legionella Culture	CFU/mL				
6 Corridor West - Drinking Fountain-Left	6	Copper	ppb				
6 Corridor West - Drinking Fountain-Left	6	E.Coli	--				
6 Corridor West - Drinking Fountain-Left	6	Lead	ppb				
6 Corridor West - Drinking Fountain-Left	6	Total Coliform	--				
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Legionella Culture	CFU/mL				
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Copper	ppb				
6W-2 Women's Restroom West - Lavatory Faucet-L	6	E.Coli	--				
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Lead	ppb				
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Total Coliform	--				
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Legionella Culture	CFU/mL	ND	ND	ND	ND
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Copper	ppb	560	300	1100	360
6W-2 Women's Restroom West - Lavatory Faucet-C	6	E.Coli	--	Absent	Absent	Absent	Absent
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Lead	ppb	0	0	48	0
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Total Coliform	--	Absent	Absent	Absent	Absent
6W-2 Women's Restroom West - Lavatory Faucet-F	6	Legionella Culture	CFU/mL				
6W-2 Women's Restroom West - Lavatory Faucet-F	6	Copper	ppb				
6W-2 Women's Restroom West - Lavatory Faucet-F	6	E.Coli	--				
6W-2 Women's Restroom West - Lavatory Faucet-F	6	Lead	ppb				
6W-2 Women's Restroom West - Lavatory Faucet-F	6	Total Coliform	--				
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL				

6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Copper	ppb				
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	E.Coli	--				
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Lead	ppb				
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Total Coliform	--				
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	Legionella Culture	CFU/mL	ND	ND	ND	ND
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	Copper	ppb	1200	340	1200	310
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	E.Coli	--	Absent	Absent	Absent	Absent
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	Lead	ppb	25	0	61	0
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Legionella Culture	CFU/mL	ND	ND		
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Copper	ppb	970	490		
Suite 615 Break Room-Kitchen Faucet (607-06)	6	E.Coli	--	Absent	Absent		
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Lead	ppb	0	0		
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Total Coliform	--	Absent	Absent		
Suite 615 Break Room-Kitchen Faucet (607-06A) /	6	Copper	ppb	750	760		
Suite 615 Break Room-Kitchen Faucet (607-06A) /	6	E.Coli	--	Absent	Absent		
Suite 615 Break Room-Kitchen Faucet (607-06A) /	6	Lead	ppb	0	0		
Suite 615 Break Room-Kitchen Faucet (607-06A) /	6	Total Coliform	--	Absent	Absent		
Suite 615 Break Room-Kitchen Faucet (607-06A) /	6	Legionella Culture	CFU/mL	ND	ND		
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL				
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Copper	ppb				
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	E.Coli	--				
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Lead	ppb				
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Total Coliform	--				
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	Legionella Culture	CFU/mL	ND	ND	ND	ND
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	Copper	ppb	1100	350	850	680
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	E.Coli	--	Absent	Absent	Absent	Absent
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	Lead	ppb	18	0	27	0
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	Total Coliform	--	Absent	Absent	Absent	Absent
6W-1 Women's Restroom East - Lavatory Faucet-L	6	Legionella Culture	CFU/mL				
6W-1 Women's Restroom East - Lavatory Faucet-L	6	Copper	ppb				

6W-1 Women's Restroom East - Lavatory Faucet-L	6	E.Coli	--				
6W-1 Women's Restroom East - Lavatory Faucet-L	6	Lead	ppb				
6W-1 Women's Restroom East - Lavatory Faucet-L	6	Total Coliform	--				
6W-1 Women's Restroom East - Lavatory Faucet-C	6	Legionella Culture	CFU/mL	ND	ND	6.4	ND
6W-1 Women's Restroom East - Lavatory Faucet-C	6	Copper	ppb	1200	300	1900	340
6W-1 Women's Restroom East - Lavatory Faucet-C	6	E.Coli	--	Absent	Absent	Absent	Absent
6W-1 Women's Restroom East - Lavatory Faucet-C	6	Lead	ppb	17	0	67	0
6W-1 Women's Restroom East - Lavatory Faucet-C	6	Total Coliform	--	Absent	Absent	Absent	Absent
6W-1 Women's Restroom East - Lavatory Faucet-R	6	Legionella Culture	CFU/mL				
6W-1 Women's Restroom East - Lavatory Faucet-R	6	Copper	ppb				
6W-1 Women's Restroom East - Lavatory Faucet-R	6	E.Coli	--				
6W-1 Women's Restroom East - Lavatory Faucet-R	6	Lead	ppb				
6W-1 Women's Restroom East - Lavatory Faucet-R	6	Total Coliform	--				
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Legionella Culture	CFU/mL			ND	ND
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Copper	ppb			460	510
Suite 620 Break Room-Kitchen Faucet (608-12)	6	E.Coli	--			Absent	Absent
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Lead	ppb			0	0
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Total Coliform	--			Absent	Absent
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Copper	ppb			460	240
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	E.Coli	--			Absent	Absent
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Lead	ppb			0	0
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Total Coliform	--			Absent	Absent
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Legionella Culture	CFU/mL			ND	ND
Suite 608 Kitchen - Faucet	6	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 608 Kitchen - Faucet	6	Copper	ppb	400	240	110	380
Suite 608 Kitchen - Faucet	6	E.Coli	--	Absent	Absent	Absent	Absent
Suite 608 Kitchen - Faucet	6	Lead	ppb	0	0	0	0
Suite 608 Kitchen - Faucet	6	Total Coliform	--	Absent	Absent	Absent	Absent
C707-Janitor's Closet-Mop/Slop Sink	7	Legionella Culture	CFU/mL				
C707-Janitor's Closet-Mop/Slop Sink	7	Copper	ppb				
C707-Janitor's Closet-Mop/Slop Sink	7	E.Coli	--				

C707-Janitor's Closet-Mop/Slop Sink	7	Lead	ppb				
C707-Janitor's Closet-Mop/Slop Sink	7	Total Coliform	--				
7 Corridor East - Drinking Fountain-Left	7	Legionella Culture	CFU/mL				
7 Corridor East - Drinking Fountain-Left	7	Copper	ppb				
7 Corridor East - Drinking Fountain-Left	7	E.Coli	--				
7 Corridor East - Drinking Fountain-Left	7	Lead	ppb				
7 Corridor East - Drinking Fountain-Left	7	Total Coliform	--				
Suite 707-01 Break Room - Faucet (707-2)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 707-01 Break Room - Faucet (707-2)	7	Copper	ppb	74	56	1100	66
Suite 707-01 Break Room - Faucet (707-2)	7	E.Coli	--	Absent	Absent	Absent	Absent
Suite 707-01 Break Room - Faucet (707-2)	7	Lead	ppb	0	0	0	0
Suite 707-01 Break Room - Faucet (707-2)	7	Total Coliform	--	Absent	Absent	Absent	Absent
7W-2 Women's Restroom West - Lavatory Faucet-L	7	Legionella Culture	CFU/mL				
7W-2 Women's Restroom West - Lavatory Faucet-L	7	Copper	ppb				
7W-2 Women's Restroom West - Lavatory Faucet-L	7	E.Coli	--				
7W-2 Women's Restroom West - Lavatory Faucet-L	7	Lead	ppb				
7W-2 Women's Restroom West - Lavatory Faucet-L	7	Total Coliform	--				
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Legionella Culture	CFU/mL	ND	ND	2.0	0.4
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Copper	ppb	660	270	1600	410
7W-2 Women's Restroom West - Lavatory Faucet-C	7	E.Coli	--	Absent	Absent	Absent	Absent
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Lead	ppb	0	0	42	0
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Total Coliform	--	Absent	Absent	Absent	Absent
7W-2 Women's Restroom West - Lavatory Faucet-F	7	Legionella Culture	CFU/mL				
7W-2 Women's Restroom West - Lavatory Faucet-F	7	Copper	ppb				
7W-2 Women's Restroom West - Lavatory Faucet-F	7	E.Coli	--				
7W-2 Women's Restroom West - Lavatory Faucet-F	7	Lead	ppb				
7W-2 Women's Restroom West - Lavatory Faucet-F	7	Total Coliform	--				
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL				
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Copper	ppb				
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	E.Coli	--				
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Lead	ppb				

7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Total Coliform	--				
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Legionella Culture	CFU/mL	ND	ND	ND	ND
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Copper	ppb	780	340	880	350
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	E.Coli	--	Absent	Absent	Absent	Absent
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Lead	ppb	0	0	77	0
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Total Coliform	--	Absent	Absent	Absent	Absent
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL				
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Copper	ppb				
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	E.Coli	--				
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Lead	ppb				
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Total Coliform	--				
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	Legionella Culture	CFU/mL	ND	ND	ND	ND
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	Copper	ppb	490	280	940	260
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	E.Coli	--	Absent	Absent	Absent	Absent
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	Lead	ppb	0	0	12	0
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	Total Coliform	--	Absent	Absent	Absent	Absent
7W-1 Women's Restroom East - Lavatory Faucet-L	7	Legionella Culture	CFU/mL				
7W-1 Women's Restroom East - Lavatory Faucet-L	7	Copper	ppb				
7W-1 Women's Restroom East - Lavatory Faucet-L	7	E.Coli	--				
7W-1 Women's Restroom East - Lavatory Faucet-L	7	Lead	ppb				
7W-1 Women's Restroom East - Lavatory Faucet-L	7	Total Coliform	--				
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Legionella Culture	CFU/mL				
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Copper	ppb				
7W-1 Women's Restroom East - Lavatory Faucet-C	7	E.Coli	--				
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Lead	ppb				
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Total Coliform	--				
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Legionella Culture	CFU/mL	ND	ND	ND	ND
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Copper	ppb	650	110	1100	100
7W-1 Women's Restroom East - Lavatory Faucet-R	7	E.Coli	--	Absent	Absent	Absent	Absent
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Lead	ppb	0	0	19	0
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Total Coliform	--	Absent	Absent	Absent	Absent

Suite 710 Faucet (710-03)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 710 Faucet (710-03)	7	Copper	ppb	110	100	130	160
Suite 710 Faucet (710-03)	7	E.Coli	--	Absent	Absent	Absent	Absent
Suite 710 Faucet (710-03)	7	Lead	ppb	0	0	0	0
Suite 710 Faucet (710-03)	7	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 707-10 Faucet (707-07)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 707-10 Faucet (707-07)	7	Copper	ppb	230	170	970	700
Suite 707-10 Faucet (707-07)	7	E.Coli	--	Absent	Absent	Absent	Absent
Suite 707-10 Faucet (707-07)	7	Lead	ppb	0	0	0	0
Suite 707-10 Faucet (707-07)	7	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 810 Kitchen Faucet	8	Legionella Culture	CFU/mL	ND	ND	ND	0.4
Suite 810 Kitchen Faucet	8	Copper	ppb	270	430	420	350
Suite 810 Kitchen Faucet	8	E.Coli	--	Absent	Absent	Absent	Absent
Suite 810 Kitchen Faucet	8	Lead	ppb	0	0	0	0
Suite 810 Kitchen Faucet	8	Total Coliform	--	Absent	Absent	Absent	Absent
C807-Janitor's Closet-Mop/Slop Sink	8	Legionella Culture	CFU/mL				
C807-Janitor's Closet-Mop/Slop Sink	8	Copper	ppb				
C807-Janitor's Closet-Mop/Slop Sink	8	E.Coli	--				
C807-Janitor's Closet-Mop/Slop Sink	8	Lead	ppb				
C807-Janitor's Closet-Mop/Slop Sink	8	Total Coliform	--				
8 Corridor West - Drinking Fountain-Left	8	Legionella Culture	CFU/mL				
8 Corridor West - Drinking Fountain-Left	8	Copper	ppb				
8 Corridor West - Drinking Fountain-Left	8	E.Coli	--				
8 Corridor West - Drinking Fountain-Left	8	Lead	ppb				
8 Corridor West - Drinking Fountain-Left	8	Total Coliform	--				
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Legionella Culture	CFU/mL				
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Copper	ppb				
8W-2 Women's Restroom West - Lavatory Faucet-L	8	E.Coli	--				
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Lead	ppb				
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Total Coliform	--				
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Legionella Culture	CFU/mL	ND	ND	ND	ND

8W-2 Women's Restroom West - Lavatory Faucet-C	8	Copper	ppb	410	290	960	370
8W-2 Women's Restroom West - Lavatory Faucet-C	8	E.Coli	--	Absent	Absent	Absent	Absent
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Lead	ppb	0	0	88	0
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Total Coliform	--	Absent	Absent	Absent	Absent
8W-2 Women's Restroom West - Lavatory Faucet-F	8	Legionella Culture	CFU/mL				
8W-2 Women's Restroom West - Lavatory Faucet-F	8	Copper	ppb				
8W-2 Women's Restroom West - Lavatory Faucet-F	8	E.Coli	--				
8W-2 Women's Restroom West - Lavatory Faucet-F	8	Lead	ppb				
8W-2 Women's Restroom West - Lavatory Faucet-F	8	Total Coliform	--				
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL				
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Copper	ppb				
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	E.Coli	--				
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Lead	ppb				
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Total Coliform	--				
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Legionella Culture	CFU/mL	ND	ND	ND	ND
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Copper	ppb	540	300	420	640
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	E.Coli	--	Absent	Absent	Absent	Absent
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Lead	ppb	0	0	0	8.6
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Total Coliform	--	Absent	Absent	Absent	Absent
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL				
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Copper	ppb				
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	E.Coli	--				
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Lead	ppb				
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Total Coliform	--				
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	Legionella Culture	CFU/mL	ND	ND	ND	ND
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	Copper	ppb	700	350	740	340
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	E.Coli	--	Absent	Absent	Absent	Absent
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	Lead	ppb	0	0	12	0
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	Total Coliform	--	Absent	Absent	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-L	8	Legionella Culture	CFU/mL				
8W-1 Women's Restroom East - Lavatory Faucet-L	8	Copper	ppb				

8W-1 Women's Restroom East - Lavatory Faucet-L	8	E.Coli	--				
8W-1 Women's Restroom East - Lavatory Faucet-L	8	Lead	ppb				
8W-1 Women's Restroom East - Lavatory Faucet-L	8	Total Coliform	--				
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Legionella Culture	CFU/mL	0.4	ND	ND	12.0
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Copper	ppb	740	380	600	440
8W-1 Women's Restroom East - Lavatory Faucet-C	8	E.Coli	--	Absent	Absent	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Lead	ppb	0	0	12	0
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Total Coliform	--	Absent	Absent	Absent	Absent
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Legionella Culture	CFU/mL				
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Copper	ppb				
8W-1 Women's Restroom East - Lavatory Faucet-R	8	E.Coli	--				
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Lead	ppb				
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Total Coliform	--				
Suite 808A Break Room Faucet (809-02)	8	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 808A Break Room Faucet (809-02)	8	Copper	ppb	350	300	290	290
Suite 808A Break Room Faucet (809-02)	8	E.Coli	--	Absent	Absent	Absent	Absent
Suite 808A Break Room Faucet (809-02)	8	Lead	ppb	0	0	0	0
Suite 808A Break Room Faucet (809-02)	8	Total Coliform	--	Absent	Absent	Absent	Absent
C907-Janitor's Closet-Mop/Slop Sink	9	Legionella Culture	CFU/mL				
C907-Janitor's Closet-Mop/Slop Sink	9	Copper	ppb				
C907-Janitor's Closet-Mop/Slop Sink	9	E.Coli	--				
C907-Janitor's Closet-Mop/Slop Sink	9	Lead	ppb				
C907-Janitor's Closet-Mop/Slop Sink	9	Total Coliform	--				
9 Corridor East - Drinking Fountain-Left	9	Legionella Culture	CFU/mL				
9 Corridor East - Drinking Fountain-Left	9	Copper	ppb				
9 Corridor East - Drinking Fountain-Left	9	E.Coli	--				
9 Corridor East - Drinking Fountain-Left	9	Lead	ppb				
9 Corridor East - Drinking Fountain-Left	9	Total Coliform	--				
Suite 907A Break Room Faucet (907-22)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 907A Break Room Faucet (907-22)	9	Copper	ppb	510	810	370	700
Suite 907A Break Room Faucet (907-22)	9	E.Coli	--	Absent	Absent	Absent	Absent

Suite 907A Break Room Faucet (907-22)	9	Lead	ppb	0	0	0	0
Suite 907A Break Room Faucet (907-22)	9	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 910A Faucet (910-05)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 910A Faucet (910-05)	9	Copper	ppb	650	700	710	700
Suite 910A Faucet (910-05)	9	E.Coli	--	Absent	Absent	Absent	Absent
Suite 910A Faucet (910-05)	9	Lead	ppb	0	0	0	0
Suite 910A Faucet (910-05)	9	Total Coliform	--	Absent	Absent	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Legionella Culture	CFU/mL				
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Copper	ppb				
9W-2 Women's Restroom West - Lavatory Faucet-L	9	E.Coli	--				
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Lead	ppb				
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Total Coliform	--				
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Legionella Culture	CFU/mL	ND	0.4	ND	0.8
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Copper	ppb	510	270	710	440
9W-2 Women's Restroom West - Lavatory Faucet-C	9	E.Coli	--	Absent	Absent	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Lead	ppb	0	0	26	0
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Total Coliform	--	Absent	Absent	Absent	Absent
9W-2 Women's Restroom West - Lavatory Faucet-F	9	Legionella Culture	CFU/mL				
9W-2 Women's Restroom West - Lavatory Faucet-F	9	Copper	ppb				
9W-2 Women's Restroom West - Lavatory Faucet-F	9	E.Coli	--				
9W-2 Women's Restroom West - Lavatory Faucet-F	9	Lead	ppb				
9W-2 Women's Restroom West - Lavatory Faucet-F	9	Total Coliform	--				
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL				
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Copper	ppb				
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	E.Coli	--				
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Lead	ppb				
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Total Coliform	--				
9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	Legionella Culture	CFU/mL	ND	ND	ND	ND
9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	Copper	ppb	1500	330	520	410
9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	E.Coli	--	Absent	Absent	Absent	Absent
9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	Lead	ppb	0	0	0	0

9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	Total Coliform	--	Absent	Absent	Absent	Absent
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL				
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Copper	ppb				
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	E.Coli	--				
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Lead	ppb				
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Total Coliform	--				
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	Legionella Culture	CFU/mL	ND	ND	1.6	0.4
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	Copper	ppb	4000	310	470	330
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	E.Coli	--	Absent	Absent	Absent	Absent
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	Lead	ppb	0	0	0	0
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	Total Coliform	--	Absent	Absent	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-L	9	Legionella Culture	CFU/mL				
9W-1 Women's Restroom East - Lavatory Faucet-L	9	Copper	ppb				
9W-1 Women's Restroom East - Lavatory Faucet-L	9	E.Coli	--				
9W-1 Women's Restroom East - Lavatory Faucet-L	9	Lead	ppb				
9W-1 Women's Restroom East - Lavatory Faucet-L	9	Total Coliform	--				
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Legionella Culture	CFU/mL	4	ND	115.2	ND
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Copper	ppb	430	220	850	610
9W-1 Women's Restroom East - Lavatory Faucet-C	9	E.Coli	--	Absent	Absent	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Lead	ppb	0	0	6.6	0
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Total Coliform	--	Absent	Absent	Absent	Absent
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Legionella Culture	CFU/mL				
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Copper	ppb				
9W-1 Women's Restroom East - Lavatory Faucet-R	9	E.Coli	--				
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Lead	ppb				
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Total Coliform	--				
Suite 908 Break Room Faucet (908-15)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 908 Break Room Faucet (908-15)	9	Copper	ppb	840	680	740	830
Suite 908 Break Room Faucet (908-15)	9	E.Coli	--	Absent	Absent	Absent	Absent
Suite 908 Break Room Faucet (908-15)	9	Lead	ppb	0	0	0	0
Suite 908 Break Room Faucet (908-15)	9	Total Coliform	--	Absent	Absent	Absent	Absent

C1007-Janitor's Closet-Mop/Slop Sink	10	Legionella Culture	CFU/mL				
C1007-Janitor's Closet-Mop/Slop Sink	10	Copper	ppb				
C1007-Janitor's Closet-Mop/Slop Sink	10	E.Coli	--				
C1007-Janitor's Closet-Mop/Slop Sink	10	Lead	ppb				
C1007-Janitor's Closet-Mop/Slop Sink	10	Total Coliform	--				
10 Corridor West - Drinking Fountain-Left	10	Legionella Culture	CFU/mL				
10 Corridor West - Drinking Fountain-Left	10	Copper	ppb				
10 Corridor West - Drinking Fountain-Left	10	E.Coli	--				
10 Corridor West - Drinking Fountain-Left	10	Lead	ppb				
10 Corridor West - Drinking Fountain-Left	10	Total Coliform	--				
Suite 1010 Lavatory Faucet	10	Legionella Culture	CFU/mL				
Suite 1010 Lavatory Faucet	10	Copper	ppb				
Suite 1010 Lavatory Faucet	10	E.Coli	--				
Suite 1010 Lavatory Faucet	10	Lead	ppb				
Suite 1010 Lavatory Faucet	10	Total Coliform	--				
Suite 1010 Kitchenette Faucet	10	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 1010 Kitchenette Faucet	10	Copper	ppb	1000	1100	110	78
Suite 1010 Kitchenette Faucet	10	E.Coli	--	Absent	Absent	Absent	Absent
Suite 1010 Kitchenette Faucet	10	Lead	ppb	0	0	0	0
Suite 1010 Kitchenette Faucet	10	Total Coliform	--	Absent	Absent	Absent	Absent
10W-2 Women's Restroom West - Lavatory Faucet	10	Legionella Culture	CFU/mL				
10W-2 Women's Restroom West - Lavatory Faucet	10	Copper	ppb				
10W-2 Women's Restroom West - Lavatory Faucet	10	E.Coli	--				
10W-2 Women's Restroom West - Lavatory Faucet	10	Lead	ppb				
10W-2 Women's Restroom West - Lavatory Faucet	10	Total Coliform	--				
10W-2 Women's Restroom West - Lavatory Faucet	10	Legionella Culture	CFU/mL	ND	ND	ND	ND
10W-2 Women's Restroom West - Lavatory Faucet	10	Copper	ppb	360	230	410	340
10W-2 Women's Restroom West - Lavatory Faucet	10	E.Coli	--	Absent	Absent		
10W-2 Women's Restroom West - Lavatory Faucet	10	Lead	ppb	0	0	3.5	0
10W-2 Women's Restroom West - Lavatory Faucet	10	Total Coliform	--	Absent	Absent		
10W-2 Women's Restroom West - Lavatory Faucet	10	Legionella Culture	CFU/mL				

10W-2 Women's Restroom West - Lavatory Faucet	10	Copper	ppb				
10W-2 Women's Restroom West - Lavatory Faucet	10	E.Coli	--				
10W-2 Women's Restroom West - Lavatory Faucet	10	Lead	ppb				
10W-2 Women's Restroom West - Lavatory Faucet	10	Total Coliform	--				
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL				
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Copper	ppb				
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	E.Coli	--				
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Lead	ppb				
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Total Coliform	--				
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Legionella Culture	CFU/mL	ND	ND	ND	ND
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Copper	ppb	400	310	380	370
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	E.Coli	--	Absent	Absent	Absent	Absent
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Lead	ppb	0	0	1.2	0
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Total Coliform	--	Absent	Absent	Absent	Absent
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL				
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Copper	ppb				
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	E.Coli	--				
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Lead	ppb				
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Total Coliform	--				
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Legionella Culture	CFU/mL	ND	ND	ND	ND
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Copper	ppb	500	350	480	350
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	E.Coli	--	Absent	Absent	Absent	Absent
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Lead	ppb	0	0	20	0
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Total Coliform	--	Absent	Absent	Absent	Absent
10W-1 Women's Restroom East - Lavatory Faucet	10	Legionella Culture	CFU/mL				
10W-1 Women's Restroom East - Lavatory Faucet	10	Copper	ppb				
10W-1 Women's Restroom East - Lavatory Faucet	10	E.Coli	--				
10W-1 Women's Restroom East - Lavatory Faucet	10	Lead	ppb				
10W-1 Women's Restroom East - Lavatory Faucet	10	Total Coliform	--				
10W-1 Women's Restroom East - Lavatory Faucet	10	Legionella Culture	CFU/mL				
10W-1 Women's Restroom East - Lavatory Faucet	10	Copper	ppb				

10W-1 Women's Restroom East - Lavatory Faucet-	10	E.Coli	--				
10W-1 Women's Restroom East - Lavatory Faucet-	10	Lead	ppb				
10W-1 Women's Restroom East - Lavatory Faucet-	10	Total Coliform	--				
10W-1 Women's Restroom East - Lavatory Faucet-	10	Legionella Culture	CFU/mL	ND	ND	ND	ND
10W-1 Women's Restroom East - Lavatory Faucet-	10	Copper	ppb	420	280	820	330
10W-1 Women's Restroom East - Lavatory Faucet-	10	E.Coli	--	Absent	Absent	Absent	Absent
10W-1 Women's Restroom East - Lavatory Faucet-	10	Lead	ppb	0	0	12	0
10W-1 Women's Restroom East - Lavatory Faucet-	10	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	Copper	ppb	760	640	640	610
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	E.Coli	--	Absent	Absent	Absent	Absent
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	Lead	ppb	0	0	0	0
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Copper	ppb	530	710	210	200
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	E.Coli	--	Absent	Absent	Absent	Absent
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Lead	ppb	0	0	0	0
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Total Coliform	--	Absent	Absent	Absent	Absent
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Legionella Culture	CFU/mL	ND	ND	ND	ND
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Copper	ppb	560	450	770	900
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	E.Coli	--	Absent	Absent	Absent	Absent
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Lead	ppb	1	0	0	0
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Total Coliform	--	Absent	Absent	Absent	Absent
EC Roof -Cooling Tower	EC Roof	Legionella Culture	CFU/mL				
EC Roof -Cooling Tower	EC Roof	E.Coli	--				
EC Roof -Cooling Tower	EC Roof	Total Coliform	--				
EC Roof -Cooling Tower	EC Roof	Copper	ppb				
EC Roof -Cooling Tower	EC Roof	Lead	ppb				
Water Cooler 108 Left	1	Legionella Culture	CFU/mL		ND		ND
Water Cooler 108 Left	1	Copper	ppb		0		0
Water Cooler 108 Left	1	E.Coli	--		Absent		Absent

Water Cooler 108 Left	1	Lead	ppb		0		0
Water Cooler 108 Left	1	Total Coliform	--		Absent		Absent
Water Cooler 108 Right	1	Legionella Culture	CFU/mL		ND		ND
Water Cooler 108 Right	1	Copper	ppb		0		0
Water Cooler 108 Right	1	E.Coli	--		Absent		Absent
Water Cooler 108 Right	1	Lead	ppb		0		0
Water Cooler 108 Right	1	Total Coliform	--		Absent		Absent
Water Cooler #3	1	Legionella Culture	CFU/mL				ND
Water Cooler #3	1	Copper	ppb		0		0
Water Cooler #3	1	E.Coli	--		Absent		Absent
Water Cooler #3	1	Lead	ppb		0		0
Water Cooler #3	1	Total Coliform	--		Absent		Absent
Water Cooler Loading Dock	1	Legionella Culture	CFU/mL		ND		
Water Cooler Loading Dock	1	Copper	ppb		0		
Water Cooler Loading Dock	1	E.Coli	--		Absent		
Water Cooler Loading Dock	1	Lead	ppb		0		
Water Cooler Loading Dock	1	Total Coliform	--		Absent		