

Color key:

Below established thresholds for legionella, metals, and total coliform/E. coli

Above established thresholds for legionella, metals, and total coliform/E. coli

Positive for legionella, but below the established threshold

Notes:

[1] U.S. EPA Primary Drinking Water Standards establish action levels for lead and copper as 15 ppb and 1,300 ppb, respectively.

[2] CDC guidance defines < 1 CFU/mL for potable sources as the threshold for systems where legionella growth appears to be well controlled.

[3] ppb means parts per billion.

[4] CFU/mL means Colony Forming Units per milliliter.

[5] ND means Legionella was not detected in the sample analyzed.

[6] Column headers indicate when samples were pulled pre or post-filter.

985 Michigan Federal Building Water Testing Summary				Monthly Round 1 (3/26 -3/27)		Monthly Round 2 (4/23 -4/24)		Monthly Round 3 (5/28 -5/29)		Monthly Round 4 (6/25-6/26)	
Plumbing Outlet Unique Identifier (for publication)	Floor	Analysis	Units	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER	PRE FILTER	POST FILTER
LL15-1 Meter Room-Water Main Service Line	LL	E.Coli	--		Absent		Absent				
LL15-1 Meter Room-Water Main Service Line	LL	Total Coliform	--		Absent		Absent				
LL15-1 Meter Room-Water Main Service Line	LL	Lead	ppb		2.6		0		0		0
LL15-1 Meter Room-Water Main Service Line	LL	Copper	ppb		40		12		86		24
LL15-1 Meter Room-Water Main Service Line	LL	Legionella Culture	CFU/mL		ND		ND		ND		ND
LL16 Fire Pump Room-Water Main Service Line	LL	E.Coli	--		Absent		Absent				
LL16 Fire Pump Room-Water Main Service Line	LL	Total Coliform	--		Absent		Absent				
LL16 Fire Pump Room-Water Main Service Line	LL	Lead	ppb		0		12		0		0
LL16 Fire Pump Room-Water Main Service Line	LL	Copper	ppb		27		0		22		27
LL16 Fire Pump Room-Water Main Service Line	LL	Legionella Culture	CFU/mL		ND		ND		ND		ND
Print, Postal Sorting Area Faucet	LL	Copper	ppb	300	270	250	240	260	210	280	260
Print, Postal Sorting Area Faucet	LL	E.Coli	--			Absent	Absent				
Print, Postal Sorting Area Faucet	LL	Lead	ppb	0	0	0	0	0	0	0	0
Print, Postal Sorting Area Faucet	LL	Total Coliform	--			Absent	Absent				
Print, Postal Sorting Area Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND			ND	ND

LLW-1 Women-Lavatory Faucet-Left	LL	E.Coli	--								
LLW-1 Women-Lavatory Faucet-Left	LL	Total Coliform	--								
LLW-1 Women-Lavatory Faucet-Left	LL	Lead	ppb								
LLW-1 Women-Lavatory Faucet-Left	LL	Copper	ppb								
LLW-1 Women-Lavatory Faucet-Left	LL	Legionella Culture	CFU/mL								
LLW-1 Women-Lavatory Faucet-Right	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
LLW-1 Women-Lavatory Faucet-Right	LL	Copper	ppb	760	410	790	500	590	360	530	430
LLW-1 Women-Lavatory Faucet-Right	LL	E.Coli	--	Absent	Absent	Absent	Absent				
LLW-1 Women-Lavatory Faucet-Right	LL	Lead	ppb	5.6	0	1.9	0	0	0	0	1.3
LLW-1 Women-Lavatory Faucet-Right	LL	Total Coliform	--	Absent	Absent	Absent	Absent				
LLM-1 Men-Lavatory Faucet-Left	LL	Legionella Culture	CFU/mL								
LLM-1 Men-Lavatory Faucet-Left	LL	Copper	ppb								
LLM-1 Men-Lavatory Faucet-Left	LL	E.Coli	--								
LLM-1 Men-Lavatory Faucet-Left	LL	Lead	ppb								
LLM-1 Men-Lavatory Faucet-Left	LL	Total Coliform	--								
LLM-1 Men-Lavatory Faucet-Right	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
LLM-1 Men-Lavatory Faucet-Right	LL	Copper	ppb	160	140	480	450	450	390	440	380
LLM-1 Men-Lavatory Faucet-Right	LL	E.Coli	--	Absent	Absent	Absent	Absent				
LLM-1 Men-Lavatory Faucet-Right	LL	Lead	ppb	0	0	0	0	0	0	1.5	0
LLM-1 Men-Lavatory Faucet-Right	LL	Total Coliform	--	Absent	Absent	Absent	Absent				
LL Corridor North - Drinking Fountain-Left	LL	Legionella Culture	CFU/mL								
LL Corridor North - Drinking Fountain-Left	LL	Copper	ppb								
LL Corridor North - Drinking Fountain-Left	LL	E.Coli	--								
LL Corridor North - Drinking Fountain-Left	LL	Lead	ppb								
LL Corridor North - Drinking Fountain-Left	LL	Total Coliform	--								
LL15 Men's Restroom - Lavatory Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
LL15 Men's Restroom - Lavatory Faucet	LL	Copper	ppb	870	1400	210	290	160	260	150	180
LL15 Men's Restroom - Lavatory Faucet	LL	E.Coli	--	Absent	Absent	Absent	Absent				
LL15 Men's Restroom - Lavatory Faucet	LL	Lead	ppb	1.7	0	0	0	0	0	0	0
LL15 Men's Restroom - Lavatory Faucet	LL	Total Coliform	--	Absent	Absent	Absent	Absent				
LL15 Women's Restroom - Lavatory Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
LL15 Women's Restroom - Lavatory Faucet	LL	Copper	ppb	1100	1200	350	510	320	310	330	260

LL15 Women's Restroom - Lavatory Faucet	LL	E.Coli	--	Absent	Absent	Absent	Absent				
LL15 Women's Restroom - Lavatory Faucet	LL	Lead	ppb	0	0	0	0	1.3	0	1.0	0
LL15 Women's Restroom - Lavatory Faucet	LL	Total Coliform	--	Absent	Absent	Absent	Absent				
LL15 Break Room-Kitchen Faucet	LL	E.Coli	--	Absent	Absent	Absent	Absent				
LL15 Break Room-Kitchen Faucet	LL	Total Coliform	--	Absent	Absent	Absent	Absent				
LL15 Break Room-Kitchen Faucet	LL	Lead	ppb	3.3	0	0	0	0	0	0	0
LL15 Break Room-Kitchen Faucet	LL	Copper	ppb	200	180	440	210	350	210	130	140
LL15 Break Room-Kitchen Faucet	LL	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Legionella Culture	CFU/mL	0.4	ND	ND	ND	0.4	ND	ND	ND
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Copper	ppb	300	170	190	92	310	120	160	110
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	E.Coli	--	Absent	Absent	Absent	Absent				
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Lead	ppb	3.1	0	2	0	1.2	0	1.1	0
CLL09-1 Janitor's Closet - Mop/Slop Sink	LL	Total Coliform	--	Absent	Absent	Absent	Absent				
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Copper	ppb	450	270	760	230	530	290	270	260
108-4 Cafe Prep. - Kitchen Faucet-Large	1	E.Coli	--	Absent	Absent	Absent	Absent				
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Lead	ppb	0	0	0	0	0	0	0	0
108-4 Cafe Prep. - Kitchen Faucet-Large	1	Total Coliform	--	Absent	Absent	Absent	Absent				
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.4	ND	ND	ND
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Copper	ppb	340	440	1700	910	780	610	1400	300
108-4 Cafe Prep. - Kitchen Faucet-Small	1	E.Coli	--	Absent	Absent	Absent	Absent				
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Lead	ppb	0	0	0	0	0	0	0	0
108-4 Cafe Prep. - Kitchen Faucet-Small	1	Total Coliform	--	Absent	Absent	Absent	Absent				
GSA Suite Kitchenette-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
GSA Suite Kitchenette-Sink/Faucet	1	Copper	ppb	1200	290	410	390	930	450	680	140
GSA Suite Kitchenette-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
GSA Suite Kitchenette-Sink/Faucet	1	Lead	ppb	0	0	0	0	0	0	0	0
GSA Suite Kitchenette-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
1 Corridor South - Drinking Fountain-Left	1	Legionella Culture	CFU/mL								
1 Corridor South - Drinking Fountain-Left	1	Copper	ppb								
1 Corridor South - Drinking Fountain-Left	1	E.Coli	--								
1 Corridor South - Drinking Fountain-Left	1	Lead	ppb								

1 Corridor South - Drinking Fountain-Left	1	Total Coliform	--								
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Legionella Culture	CFU/mL								
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Copper	ppb								
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	E.Coli	--								
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Lead	ppb								
1M-1 Men's Restroom North - Lavatory Faucet-Left	1	Total Coliform	--								
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	1.2	ND	ND	ND
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	Copper	ppb	2800	250	440	260	1700	630	610	890
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	E.Coli	--	Absent	Absent	Absent	Absent				
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	Lead	ppb	28	0	6.6	0	0	0	0	0
1M-1 Men's Restroom North - Lavatory Faucet-Cer	1	Total Coliform	--	Absent	Absent	Absent	Absent				
1M-1 Men's Restroom North - Lavatory Faucet-Rigt	1	Legionella Culture	CFU/mL								
1M-1 Men's Restroom North - Lavatory Faucet-Rigt	1	Copper	ppb								
1M-1 Men's Restroom North - Lavatory Faucet-Rigt	1	E.Coli	--								
1M-1 Men's Restroom North - Lavatory Faucet-Rigt	1	Lead	ppb								
1M-1 Men's Restroom North - Lavatory Faucet-Rigt	1	Total Coliform	--								
1M-2 Men's Restroom South - Lavatory Faucet-Lef	1	Legionella Culture	CFU/mL								
1M-2 Men's Restroom South - Lavatory Faucet-Lef	1	Copper	ppb								
1M-2 Men's Restroom South - Lavatory Faucet-Lef	1	E.Coli	--								
1M-2 Men's Restroom South - Lavatory Faucet-Lef	1	Lead	ppb								
1M-2 Men's Restroom South - Lavatory Faucet-Lef	1	Total Coliform	--								
1M-2 Men's Restroom South - Lavatory Faucet-Rigt	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
1M-2 Men's Restroom South - Lavatory Faucet-Rigt	1	Copper	ppb	4100	1100	890	1300	830	1000	510	720
1M-2 Men's Restroom South - Lavatory Faucet-Rigt	1	E.Coli	--	Absent	Absent	Absent	Absent				
1M-2 Men's Restroom South - Lavatory Faucet-Rigt	1	Lead	ppb	0	0	0	0	0	0	0	0
1M-2 Men's Restroom South - Lavatory Faucet-Rigt	1	Total Coliform	--	Absent	Absent	Absent	Absent				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Legionella Culture	CFU/mL								
1W-1 Women's Restroom North - Lavatory Faucet-	1	Copper	ppb								
1W-1 Women's Restroom North - Lavatory Faucet-	1	E.Coli	--								
1W-1 Women's Restroom North - Lavatory Faucet-	1	Lead	ppb								
1W-1 Women's Restroom North - Lavatory Faucet-	1	Total Coliform	--								
1W-1 Women's Restroom North - Lavatory Faucet-	1	Legionella Culture	CFU/mL								

1W-1 Women's Restroom North - Lavatory Faucet-	1	Copper	ppb								
1W-1 Women's Restroom North - Lavatory Faucet-	1	E.Coli	--								
1W-1 Women's Restroom North - Lavatory Faucet-	1	Lead	ppb								
1W-1 Women's Restroom North - Lavatory Faucet-	1	Total Coliform	--								
1W-1 Women's Restroom North - Lavatory Faucet-	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.8	ND	ND	ND
1W-1 Women's Restroom North - Lavatory Faucet-	1	Copper	ppb	3000	390	740	360	2300	640	1800	680
1W-1 Women's Restroom North - Lavatory Faucet-	1	E.Coli	--	Absent	Absent	Absent	Absent				
1W-1 Women's Restroom North - Lavatory Faucet-	1	Lead	ppb	12	0	2	0	0	0	0	0
1W-1 Women's Restroom North - Lavatory Faucet-	1	Total Coliform	--	Absent	Absent	Absent	Absent				
1W-2 Women's Restroom South - Lavatory Faucet-	1	Legionella Culture	CFU/mL								
1W-2 Women's Restroom South - Lavatory Faucet-	1	Copper	ppb								
1W-2 Women's Restroom South - Lavatory Faucet-	1	E.Coli	--								
1W-2 Women's Restroom South - Lavatory Faucet-	1	Lead	ppb								
1W-2 Women's Restroom South - Lavatory Faucet-	1	Total Coliform	--								
1W-2 Women's Restroom South - Lavatory Faucet-	1	Legionella Culture	CFU/mL	8	ND	4.8	ND	2.4	ND	ND	ND
1W-2 Women's Restroom South - Lavatory Faucet-	1	Copper	ppb	540	800	520		710	420	860	480
1W-2 Women's Restroom South - Lavatory Faucet-	1	E.Coli	--	Absent	Absent	Absent	Absent				
1W-2 Women's Restroom South - Lavatory Faucet-	1	Lead	ppb	0	0	3.1	0	0	0	0	0
1W-2 Women's Restroom South - Lavatory Faucet-	1	Total Coliform	--	Absent	Absent	Absent	Absent				
119-21 Faucet/Eyewash	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
119-21 Faucet/Eyewash	1	Copper	ppb	1200	210	82	74	610	130	850	170
119-21 Faucet/Eyewash	1	E.Coli	--	Absent	Absent	Absent	Absent				
119-21 Faucet/Eyewash	1	Lead	ppb	0	3.5	0	0	0	0	0	0
119-21 Faucet/Eyewash	1	Total Coliform	--	Absent	Absent	Absent	Absent				
119-16A Shower	1	Legionella Culture	CFU/mL		ND		ND		ND		ND
119-16A Shower	1	Copper	ppb		330		190		100		88
119-16A Shower	1	E.Coli	--		Absent		Absent				
119-16A Shower	1	Lead	ppb		0		0		0		0
119-16A Shower	1	Total Coliform	--		Absent		Absent				
119-17 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	ND	ND		ND		ND
119-17 Toilet/Sink Combo	1	Copper	ppb	1200	960	150	70		150		170
119-17 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent				

119-17 Toilet/Sink Combo	1	Lead	ppb	0	0	0	0		0		0
119-17 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent				
119-19 Food Storage Room-Sink/Faucet	1	Legionella Culture	CFU/mL								
119-19 Food Storage Room-Sink/Faucet	1	Copper	ppb								
119-19 Food Storage Room-Sink/Faucet	1	E.Coli	--								
119-19 Food Storage Room-Sink/Faucet	1	Lead	ppb								
119-19 Food Storage Room-Sink/Faucet	1	Total Coliform	--								
119-11 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	ND	ND		ND		ND
119-11 Toilet/Sink Combo	1	Copper	ppb	2300	110	140	51		68		69
119-11 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent				
119-11 Toilet/Sink Combo	1	Lead	ppb	0	1.5	0	0		0		0
119-11 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent				
119-10 Toilet/Sink Combo	1	Legionella Culture	CFU/mL	ND	ND	ND	ND		ND		ND
119-10 Toilet/Sink Combo	1	Copper	ppb	2500	130	150	56		84		60
119-10 Toilet/Sink Combo	1	E.Coli	--	Absent	Absent	Absent	Absent				
119-10 Toilet/Sink Combo	1	Lead	ppb	0	2	2.1	0		0		0
119-10 Toilet/Sink Combo	1	Total Coliform	--	Absent	Absent	Absent	Absent				
119-07 Toilet/Sink Combo-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND		ND		ND
119-07 Toilet/Sink Combo-Left	1	Copper	ppb	1100	120	140	61		110		74
119-07 Toilet/Sink Combo-Left	1	E.Coli	--	Absent	Absent	Absent	Absent				
119-07 Toilet/Sink Combo-Left	1	Lead	ppb	0	0	0	0		0		0
119-07 Toilet/Sink Combo-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent				
119-07 Toilet/Sink Combo-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND		ND		ND
119-07 Toilet/Sink Combo-Right	1	Copper	ppb	910	120	140	70		99		97
119-07 Toilet/Sink Combo-Right	1	E.Coli	--	Absent	Absent	Absent	Absent				
119-07 Toilet/Sink Combo-Right	1	Lead	ppb	0	0	0	0		0		0
119-07 Toilet/Sink Combo-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent				
119-08 Toilet/Sink Combo-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND		ND		ND
119-08 Toilet/Sink Combo-Left	1	Copper	ppb	920	130	130	63		110		100
119-08 Toilet/Sink Combo-Left	1	E.Coli	--	Absent	Absent	Absent	Absent				
119-08 Toilet/Sink Combo-Left	1	Lead	ppb	0	0	0	0		0		0
119-08 Toilet/Sink Combo-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent				

119-08 Toilet/Sink Combo-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND		ND		
119-08 Toilet/Sink Combo-Right	1	Copper	ppb	1100	490	150	61		130		
119-08 Toilet/Sink Combo-Right	1	E.Coli	--	Absent	Absent	Absent	Absent				
119-08 Toilet/Sink Combo-Right	1	Lead	ppb	0	1.2	0	0		0		
119-08 Toilet/Sink Combo-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent				
128-01 Lactation Room A-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
128-01 Lactation Room A-Sink/Faucet	1	Copper	ppb	1500	370	220	120	970	400	860	230
128-01 Lactation Room A-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
128-01 Lactation Room A-Sink/Faucet	1	Lead	ppb	0	0	0	0	0	0	0	0
128-01 Lactation Room A-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
128-02 Lactation Room B-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.4	ND	ND	ND
128-02 Lactation Room B-Sink/Faucet	1	Copper	ppb	1200	350	230	130	830	170	1700	150
128-02 Lactation Room B-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
128-02 Lactation Room B-Sink/Faucet	1	Lead	ppb	0	0	1.1	0	0	0	0	0
128-02 Lactation Room B-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
128-03 Lactation Room C-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
128-03 Lactation Room C-Sink/Faucet	1	Copper	ppb	1200	340	140	81	77	73	570	110
128-03 Lactation Room C-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
128-03 Lactation Room C-Sink/Faucet	1	Lead	ppb	0	0	0	0	0	0	0	0
128-03 Lactation Room C-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
128-04 Lactation Room D-Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
128-04 Lactation Room D-Sink/Faucet	1	Copper	ppb	1200	290	330	350	950	250	700	780
128-04 Lactation Room D-Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
128-04 Lactation Room D-Sink/Faucet	1	Lead	ppb	0	0	0	0	0	0	0	0
128-04 Lactation Room D-Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
119-02 Mailroom - Faucet	1	Legionella Culture	CFU/mL								
119-02 Mailroom - Faucet	1	Copper	ppb								
119-02 Mailroom - Faucet	1	E.Coli	--								
119-02 Mailroom - Faucet	1	Lead	ppb								
119-02 Mailroom - Faucet	1	Total Coliform	--								
C105-1 Janitor's Closet - Mop/Slop Sink	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
C105-1 Janitor's Closet - Mop/Slop Sink	1	Copper	ppb	190	140	470	220	160	130	390	120

C105-1 Janitor's Closet - Mop/Slop Sink	1	E.Coli	--	Absent	Absent	Absent	Absent				
C105-1 Janitor's Closet - Mop/Slop Sink	1	Lead	ppb	0	0	0	0	0	0	0	0
C105-1 Janitor's Closet - Mop/Slop Sink	1	Total Coliform	--	Absent	Absent	Absent	Absent				
1 Corridor North - Drinking Fountain-Left	1	Legionella Culture	CFU/mL								
1 Corridor North - Drinking Fountain-Left	1	Copper	ppb								
1 Corridor North - Drinking Fountain-Left	1	E.Coli	--								
1 Corridor North - Drinking Fountain-Left	1	Lead	ppb								
1 Corridor North - Drinking Fountain-Left	1	Total Coliform	--								
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.4	ND	ND	ND
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	Copper	ppb	83	62	50	84	200	51	34	37
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	E.Coli	--	Absent	Absent	Absent	Absent				
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	Lead	ppb	1.3	1.5	0	0	0	0	1.5	0
114-2 Loading Dock - Janitor's Closet - Mop/Slop S	1	Total Coliform	--	Absent	Absent	Absent	Absent				
1U-1 Loading Dock - Lavatory Faucet	1	Legionella Culture	CFU/mL								
1U-1 Loading Dock - Lavatory Faucet	1	Copper	ppb								
1U-1 Loading Dock - Lavatory Faucet	1	E.Coli	--								
1U-1 Loading Dock - Lavatory Faucet	1	Lead	ppb								
1U-1 Loading Dock - Lavatory Faucet	1	Total Coliform	--								
113-6 JLL Kitchenette-Kitchen Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
113-6 JLL Kitchenette-Kitchen Faucet	1	Copper	ppb	790	1700	870	690	250	130	820	1300
113-6 JLL Kitchenette-Kitchen Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
113-6 JLL Kitchenette-Kitchen Faucet	1	Lead	ppb	7.1	0	2.2	0	0	0	1.4	0
113-6 JLL Kitchenette-Kitchen Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
123-05 Health Unit - Sink/Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
123-05 Health Unit - Sink/Faucet	1	Copper	ppb	480	410	320	220	830	580	890	460
123-05 Health Unit - Sink/Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
123-05 Health Unit - Sink/Faucet	1	Lead	ppb	0	0	0	0	0	0	0	0
123-05 Health Unit - Sink/Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
123-08 Health Unit-Lavatory Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
123-08 Health Unit-Lavatory Faucet	1	Copper	ppb	4100	1900	1600	1200	880	820	2600	850
123-08 Health Unit-Lavatory Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
123-08 Health Unit-Lavatory Faucet	1	Lead	ppb	0	0	0	0	0	0	0	0



123-08 Health Unit-Lavatory Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
123-07 Health Unit-Lavatory Faucet	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
123-07 Health Unit-Lavatory Faucet	1	Copper	ppb	1800	2200	1300	1200	940	950	1600	1400
123-07 Health Unit-Lavatory Faucet	1	E.Coli	--	Absent	Absent	Absent	Absent				
123-07 Health Unit-Lavatory Faucet	1	Lead	ppb	0	0	0	0	0	0	0	0
123-07 Health Unit-Lavatory Faucet	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-05 Men-Lavatory Faucet-Left	1	Legionella Culture	CFU/mL								
126-05 Men-Lavatory Faucet-Left	1	Copper	ppb								
126-05 Men-Lavatory Faucet-Left	1	E.Coli	--								
126-05 Men-Lavatory Faucet-Left	1	Lead	ppb								
126-05 Men-Lavatory Faucet-Left	1	Total Coliform	--								
126-05 Men-Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-05 Men-Lavatory Faucet-Center	1	Copper	ppb	1100	720	1300	630	1300	1000	960	440
126-05 Men-Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-05 Men-Lavatory Faucet-Center	1	Lead	ppb	0	3.1	0	0	0	0	0	0
126-05 Men-Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-05 Men-Lavatory Faucet-Right	1	Legionella Culture	CFU/mL								
126-05 Men-Lavatory Faucet-Right	1	Copper	ppb								
126-05 Men-Lavatory Faucet-Right	1	E.Coli	--								
126-05 Men-Lavatory Faucet-Right	1	Lead	ppb								
126-05 Men-Lavatory Faucet-Right	1	Total Coliform	--								
126-06 Shower Room - Shower-North-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-06 Shower Room - Shower-North-Left	1	Copper	ppb	1300	960	560	490	700	500	480	260
126-06 Shower Room - Shower-North-Left	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-06 Shower Room - Shower-North-Left	1	Lead	ppb	0	0	0	0	0	0	0	0
126-06 Shower Room - Shower-North-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-06 Shower Room-Shower-North-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-06 Shower Room-Shower-North-Center	1	Copper	ppb	1100	820	510	160	600	410	510	220
126-06 Shower Room-Shower-North-Center	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-06 Shower Room-Shower-North-Center	1	Lead	ppb	0	0	0	0	0	0	0	0
126-06 Shower Room-Shower-North-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent				

126-06 Shower Room - Shower-North-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-06 Shower Room - Shower-North-Right	1	Copper	ppb	910	810	370	330	540	440	450	230
126-06 Shower Room - Shower-North-Right	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-06 Shower Room - Shower-North-Right	1	Lead	ppb	0	0	0	0	0	0	0	0
126-06 Shower Room - Shower-North-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-06 Shower Room - Shower-South-Left	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-06 Shower Room - Shower-South-Left	1	Copper	ppb	1100	860	310	280	570	420	480	110
126-06 Shower Room - Shower-South-Left	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-06 Shower Room - Shower-South-Left	1	Lead	ppb	0	0	0	0	0	0	0	0
126-06 Shower Room - Shower-South-Left	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-06 Shower Room-Shower-South-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-06 Shower Room-Shower-South-Center	1	Copper	ppb	1100	830	300	240	570	380	450	340
126-06 Shower Room-Shower-South-Center	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-06 Shower Room-Shower-South-Center	1	Lead	ppb	0	0	0	0	0	0	0	0
126-06 Shower Room-Shower-South-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-06 Shower Room - Shower-South-Right	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-06 Shower Room - Shower-South-Right	1	Copper	ppb	1200	660	180	230	610	430	530	210
126-06 Shower Room - Shower-South-Right	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-06 Shower Room - Shower-South-Right	1	Lead	ppb	0	0	0	0	0	0	0	0
126-06 Shower Room - Shower-South-Right	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-02 Women-Lavatory Faucet-Left	1	Legionella Culture	CFU/mL								
126-02 Women-Lavatory Faucet-Left	1	Copper	ppb								
126-02 Women-Lavatory Faucet-Left	1	E.Coli	--								
126-02 Women-Lavatory Faucet-Left	1	Lead	ppb								
126-02 Women-Lavatory Faucet-Left	1	Total Coliform	--								
126-02 Women-Lavatory Faucet-Center	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-02 Women-Lavatory Faucet-Center	1	Copper	ppb	1800	590	2200	860	1700	740	1800	920
126-02 Women-Lavatory Faucet-Center	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-02 Women-Lavatory Faucet-Center	1	Lead	ppb	13	1.5	0	0	0	0	0	0
126-02 Women-Lavatory Faucet-Center	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-02 Women-Lavatory Faucet-Right	1	Legionella Culture	CFU/mL								
126-02 Women-Lavatory Faucet-Right	1	Copper	ppb								

126-02 Women-Lavatory Faucet-Right	1	E.Coli	--								
126-02 Women-Lavatory Faucet-Right	1	Lead	ppb								
126-02 Women-Lavatory Faucet-Right	1	Total Coliform	--								
126-03 Women-Shower-1st from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-03 Women-Shower-1st from L to R	1	Copper	ppb	930	920	99	240	610	500	570	250
126-03 Women-Shower-1st from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-03 Women-Shower-1st from L to R	1	Lead	ppb	0	0	0	0	0	0	0	0
126-03 Women-Shower-1st from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-03 Women-Shower-2nd from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-03 Women-Shower-2nd from L to R	1	Copper	ppb	1100	670	130	250	570	420	480	180
126-03 Women-Shower-2nd from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-03 Women-Shower-2nd from L to R	1	Lead	ppb	0	0	0	0	0	0	0	0
126-03 Women-Shower-2nd from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-03 Women-Shower-3rd from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-03 Women-Shower-3rd from L to R	1	Copper	ppb	1100	610	220	200	700	460	730	210
126-03 Women-Shower-3rd from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-03 Women-Shower-3rd from L to R	1	Lead	ppb	0	0	0	0	0	0	0	0
126-03 Women-Shower-3rd from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent				
126-03 Women-Shower-4th from L to R	1	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
126-03 Women-Shower-4th from L to R	1	Copper	ppb	740	580	88	160	530	440	790	170
126-03 Women-Shower-4th from L to R	1	E.Coli	--	Absent	Absent	Absent	Absent				
126-03 Women-Shower-4th from L to R	1	Lead	ppb	0	0	0	0	0	0	0	0
126-03 Women-Shower-4th from L to R	1	Total Coliform	--	Absent	Absent	Absent	Absent				
2 Corridor West - Drinking Fountain-Left	2	Legionella Culture	CFU/mL								
2 Corridor West - Drinking Fountain-Left	2	Copper	ppb								
2 Corridor West - Drinking Fountain-Left	2	E.Coli	--								
2 Corridor West - Drinking Fountain-Left	2	Lead	ppb								
2 Corridor West - Drinking Fountain-Left	2	Total Coliform	--								
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Legionella Culture	CFU/mL								
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Copper	ppb								
2W-2 Women's Restroom West - Lavatory Faucet-L	2	E.Coli	--								
2W-2 Women's Restroom West - Lavatory Faucet-L	2	Lead	ppb								

2W-2 Women's Restroom West - Lavatory Faucet-L	2	Total Coliform	--								
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Copper	ppb	1200	260	2500	470	260	370	420	390
2W-2 Women's Restroom West - Lavatory Faucet-C	2	E.Coli	--	Absent	Absent	Absent	Absent				
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Lead	ppb	0	0	0	0	1.5	0	3.6	0
2W-2 Women's Restroom West - Lavatory Faucet-C	2	Total Coliform	--	Absent	Absent	Absent	Absent				
2W-2 Women's Restroom West - Lavatory Faucet-F	2	Legionella Culture	CFU/mL								
2W-2 Women's Restroom West - Lavatory Faucet-F	2	Copper	ppb								
2W-2 Women's Restroom West - Lavatory Faucet-F	2	E.Coli	--								
2W-2 Women's Restroom West - Lavatory Faucet-F	2	Lead	ppb								
2W-2 Women's Restroom West - Lavatory Faucet-F	2	Total Coliform	--								
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL								
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Copper	ppb								
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	E.Coli	--								
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Lead	ppb								
2M-2 Men's Restroom West - Lavatory Faucet-Left	2	Total Coliform	--								
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.8	ND	ND	ND
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Copper	ppb	660	300	870	350	360	340	610	530
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	E.Coli	--	Absent	Absent	Absent	Absent				
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Lead	ppb	13	0	4.3	0	2.4	0	2.2	0
2M-2 Men's Restroom West - Lavatory Faucet-Righ	2	Total Coliform	--	Absent	Absent	Absent	Absent				
2W-1 Women's Restroom East - Lavatory Faucet-L	2	Legionella Culture	CFU/mL								
2W-1 Women's Restroom East - Lavatory Faucet-L	2	Copper	ppb								
2W-1 Women's Restroom East - Lavatory Faucet-L	2	E.Coli	--								
2W-1 Women's Restroom East - Lavatory Faucet-L	2	Lead	ppb								
2W-1 Women's Restroom East - Lavatory Faucet-L	2	Total Coliform	--								
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Legionella Culture	CFU/mL								
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Copper	ppb								
2W-1 Women's Restroom East - Lavatory Faucet-C	2	E.Coli	--								
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Lead	ppb								
2W-1 Women's Restroom East - Lavatory Faucet-C	2	Total Coliform	--								
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	0.8

2W-1 Women's Restroom East - Lavatory Faucet-R	2	Copper	ppb	2600	210	520	340	340	350	550	330
2W-1 Women's Restroom East - Lavatory Faucet-R	2	E.Coli	--	Absent	Absent	Absent	Absent				
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Lead	ppb	12	0	0	0	0	0	0	0
2W-1 Women's Restroom East - Lavatory Faucet-R	2	Total Coliform	--	Absent	Absent	Absent	Absent				
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Legionella Culture	CFU/mL								
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Copper	ppb								
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	E.Coli	--								
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Lead	ppb								
2M-1 Men's Restroom East - Lavatory Faucet-Left	2	Total Coliform	--								
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	Legionella Culture	CFU/mL	13.6	ND	ND	ND	0.4	ND	ND	ND
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	Copper	ppb	2200	210	3900	360	460	300	310	320
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	E.Coli	--	Absent	Absent	Absent	Absent				
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	Lead	ppb	0	0	11	0	0	0	0	0
2M-1 Men's Restroom East - Lavatory Faucet-Righ	2	Total Coliform	--	Absent	Absent	Absent	Absent				
234 Kitchen Faucet (209-04)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
234 Kitchen Faucet (209-04)	2	Copper	ppb	810	770	190	250	1200	410	1800	280
234 Kitchen Faucet (209-04)	2	E.Coli	--	Absent	Absent	Absent	Absent				
234 Kitchen Faucet (209-04)	2	Lead	ppb	0	0	0	0	0	0	0	1
234 Kitchen Faucet (209-04)	2	Total Coliform	--	Absent	Absent	Absent	Absent				
Break Room North West - Kitchen Faucet (207-14)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Break Room North West - Kitchen Faucet (207-14)	2	Copper	ppb	1100	650	280	810	700	540	410	380
Break Room North West - Kitchen Faucet (207-14)	2	E.Coli	--	Absent	Absent	Absent	Absent				
Break Room North West - Kitchen Faucet (207-14)	2	Lead	ppb	0	0	0	0	0	0	0	0
Break Room North West - Kitchen Faucet (207-14)	2	Total Coliform	--	Absent	Absent	Absent	Absent				
Break Room North East Kitchen - Faucet (207-39)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Break Room North East Kitchen - Faucet (207-39)	2	Copper	ppb	1200	660	250	240	1600	800	1200	680
Break Room North East Kitchen - Faucet (207-39)	2	E.Coli	--	Absent	Absent	Absent	Absent				
Break Room North East Kitchen - Faucet (207-39)	2	Lead	ppb	0	0	0	0	0	0	0	0
Break Room North East Kitchen - Faucet (207-39)	2	Total Coliform	--	Absent	Absent	Absent	Absent				
Break Room South East Kitchen - Faucet (207-49)	2	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Break Room South East Kitchen - Faucet (207-49)	2	Copper	ppb	77	100	630	35	1400	960	980	280
Break Room South East Kitchen - Faucet (207-49)	2	E.Coli	--	Absent	Absent	Absent	Absent				

Break Room South East Kitchen - Faucet (207-49)	2	Lead	ppb	0	0	0	0	0	0	0	0
Break Room South East Kitchen - Faucet (207-49)	2	Total Coliform	--	Absent	Absent	Absent	Absent				
E201 Restroom - Lavatory Faucet	2	Legionella Culture	CFU/mL								
E201 Restroom - Lavatory Faucet	2	Copper	ppb								
E201 Restroom - Lavatory Faucet	2	E.Coli	--								
E201 Restroom - Lavatory Faucet	2	Lead	ppb								
E201 Restroom - Lavatory Faucet	2	Total Coliform	--								
C207 Janitor's Closet-Mop/Slop Sink	2	Legionella Culture	CFU/mL								
C207 Janitor's Closet-Mop/Slop Sink	2	Copper	ppb								
C207 Janitor's Closet-Mop/Slop Sink	2	E.Coli	--								
C207 Janitor's Closet-Mop/Slop Sink	2	Lead	ppb								
C207 Janitor's Closet-Mop/Slop Sink	2	Total Coliform	--								
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Legionella Culture	CFU/mL								
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Copper	ppb								
3W-2 Women's Restroom West - Lavatory Faucet-L	3	E.Coli	--								
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Lead	ppb								
3W-2 Women's Restroom West - Lavatory Faucet-L	3	Total Coliform	--								
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Legionella Culture	CFU/mL	ND	1.6	ND	ND	ND	1.2	ND	ND
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Copper	ppb	480	98	290	190	250	300	180	270
3W-2 Women's Restroom West - Lavatory Faucet-C	3	E.Coli	--	Absent	Absent	Absent	Absent				
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Lead	ppb	0	0	1.1	6	0	0	0	0
3W-2 Women's Restroom West - Lavatory Faucet-C	3	Total Coliform	--	Absent	Absent	Absent	Absent				
3W-2 Women's Restroom West - Lavatory Faucet-F	3	Legionella Culture	CFU/mL								
3W-2 Women's Restroom West - Lavatory Faucet-F	3	Copper	ppb								
3W-2 Women's Restroom West - Lavatory Faucet-F	3	E.Coli	--								
3W-2 Women's Restroom West - Lavatory Faucet-F	3	Lead	ppb								
3W-2 Women's Restroom West - Lavatory Faucet-F	3	Total Coliform	--								
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.8	ND	ND	ND
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	Copper	ppb	440	270	170	270	190	340	370	43
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	E.Coli	--	Absent	Absent	Absent	Absent				
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	Lead	ppb	0	0	0	0	0	0	2.1	1.7
3M-2 Men's Restroom West - Lavatory Faucet-Righ	3	Total Coliform	--	Absent	Absent						

3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Legionella Culture	CFU/mL								
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Copper	ppb								
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	E.Coli	--								
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Lead	ppb								
3M-1 Men's Restroom East - Lavatory Faucet-Left	3	Total Coliform	--								
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	Legionella Culture	CFU/mL	ND	1.6	2.8	ND	ND	0.4	ND	ND
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	Copper	ppb	3300	170	330	79	310	360	250	69
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	E.Coli	--	Absent	Absent	Absent	Absent				
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	Lead	ppb	43	0	4.4	5.2	0	0	3.6	1.9
3M-1 Men's Restroom East - Lavatory Faucet-Righ	3	Total Coliform	--	Absent	Absent	Absent	Absent				
3W-1 Women's Restroom East - Lavatory Faucet-L	3	Legionella Culture	CFU/mL								
3W-1 Women's Restroom East - Lavatory Faucet-L	3	Copper	ppb								
3W-1 Women's Restroom East - Lavatory Faucet-L	3	E.Coli	--								
3W-1 Women's Restroom East - Lavatory Faucet-L	3	Lead	ppb								
3W-1 Women's Restroom East - Lavatory Faucet-L	3	Total Coliform	--								
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Legionella Culture	CFU/mL	ND	0.4	0.4	ND	ND	ND	ND	ND
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Copper	ppb	1200	270	500	670	230	320	210	250
3W-1 Women's Restroom East - Lavatory Faucet-C	3	E.Coli	--	Absent	Absent	Absent	Absent				
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Lead	ppb	16	0	6.3	2.3	2.5	2.4	0	2.4
3W-1 Women's Restroom East - Lavatory Faucet-C	3	Total Coliform	--	Absent	Absent	Absent	Absent				
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Legionella Culture	CFU/mL								
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Copper	ppb								
3W-1 Women's Restroom East - Lavatory Faucet-R	3	E.Coli	--								
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Lead	ppb								
3W-1 Women's Restroom East - Lavatory Faucet-R	3	Total Coliform	--								
3 Corridor East - Drinking Fountain-Left	3	Legionella Culture	CFU/mL								
3 Corridor East - Drinking Fountain-Left	3	Copper	ppb								
3 Corridor East - Drinking Fountain-Left	3	E.Coli	--								
3 Corridor East - Drinking Fountain-Left	3	Lead	ppb								
3 Corridor East - Drinking Fountain-Left	3	Total Coliform	--								
C307 Janitor's Closet-Mop/Slop Sink	3	Legionella Culture	CFU/mL								
C307 Janitor's Closet-Mop/Slop Sink	3	Copper	ppb								

C307 Janitor's Closet-Mop/Slop Sink	3	E.Coli	--								
C307 Janitor's Closet-Mop/Slop Sink	3	Lead	ppb								
C307 Janitor's Closet-Mop/Slop Sink	3	Total Coliform	--								
4W-1 Women's Restroom East - Lavatory Faucet-L	4	Legionella Culture	CFU/mL								
4W-1 Women's Restroom East - Lavatory Faucet-L	4	Copper	ppb								
4W-1 Women's Restroom East - Lavatory Faucet-L	4	E.Coli	--								
4W-1 Women's Restroom East - Lavatory Faucet-L	4	Lead	ppb								
4W-1 Women's Restroom East - Lavatory Faucet-L	4	Total Coliform	--								
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Legionella Culture	CFU/mL	7.2	4	1.6	ND	ND	ND	ND	ND
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Copper	ppb	1100	130	71	280	99	94	480	120
4W-1 Women's Restroom East - Lavatory Faucet-C	4	E.Coli	--	Absent	Absent	Absent	Absent				
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Lead	ppb	52	0	0	0	0	0	7.8	0
4W-1 Women's Restroom East - Lavatory Faucet-C	4	Total Coliform	--	Absent	Absent	Absent	Absent				
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Legionella Culture	CFU/mL								
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Copper	ppb								
4W-1 Women's Restroom East - Lavatory Faucet-R	4	E.Coli	--								
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Lead	ppb								
4W-1 Women's Restroom East - Lavatory Faucet-R	4	Total Coliform	--								
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL								
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Copper	ppb								
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	E.Coli	--								
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Lead	ppb								
4M-1 Men's Restroom East - Lavatory Faucet-Left	4	Total Coliform	--								
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	Legionella Culture	CFU/mL	2.4	ND	ND	ND	ND	ND	ND	ND
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	Copper	ppb	500	300	110	420	49	350	660	360
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	E.Coli	--	Absent	Absent	Absent	Absent				
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	Lead	ppb	0	0	7.3	0	0	0	0	0
4M-1 Men's Restroom East - Lavatory Faucet-Righ	4	Total Coliform	--	Absent	Absent	Absent	Absent				
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Legionella Culture	CFU/mL								
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Copper	ppb								
4W-2 Women's Restroom West - Lavatory Faucet-L	4	E.Coli	--								
4W-2 Women's Restroom West - Lavatory Faucet-L	4	Lead	ppb								



4W-2 Women's Restroom West - Lavatory Faucet-Left	4	Total Coliform	--								
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	Copper	ppb	4700	170	2000	230	210	310	520	320
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	E.Coli	--	Absent	Absent	Absent	Absent				
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	Lead	ppb	59	0	34	0	1.1	0	3.8	0
4W-2 Women's Restroom West - Lavatory Faucet-Center	4	Total Coliform	--	Absent	Absent	Absent	Absent				
4W-2 Women West-Lavatory Faucet-Right	4	Legionella Culture	CFU/mL								
4W-2 Women West-Lavatory Faucet-Right	4	Copper	ppb								
4W-2 Women West-Lavatory Faucet-Right	4	E.Coli	--								
4W-2 Women West-Lavatory Faucet-Right	4	Lead	ppb								
4W-2 Women West-Lavatory Faucet-Right	4	Total Coliform	--								
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Legionella Culture	CFU/mL								
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Copper	ppb								
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	E.Coli	--								
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Lead	ppb								
4M-2 Men's Restroom West - Lavatory Faucet-Left	4	Total Coliform	--								
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	Copper	ppb	1800	150	180	340	110	270	370	520
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	E.Coli	--	Absent	Absent	Absent	Absent				
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	Lead	ppb	0	0	1.1	0	0	0	0	1.7
4M-2 Men's Restroom West - Lavatory Faucet-Right	4	Total Coliform	--	Absent	Absent	Absent	Absent				
4 Corridor West - Drinking Fountain-Left	4	Legionella Culture	CFU/mL								
4 Corridor West - Drinking Fountain-Left	4	Copper	ppb								
4 Corridor West - Drinking Fountain-Left	4	E.Coli	--								
4 Corridor West - Drinking Fountain-Left	4	Lead	ppb								
4 Corridor West - Drinking Fountain-Left	4	Total Coliform	--								
Suite 410 Kitchenette Faucet (NW)	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND		
Suite 410 Kitchenette Faucet (NW)	4	Copper	ppb	1800	890	530	520	1300	1100		
Suite 410 Kitchenette Faucet (NW)	4	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 410 Kitchenette Faucet (NW)	4	Lead	ppb	0	0	0	0	0	0		
Suite 410 Kitchenette Faucet (NW)	4	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 415 Kitchenette - Faucet (N)	4	Legionella Culture	CFU/mL	ND	ND						

Suite 415 Kitchenette - Faucet (N)	4	Copper	ppb	82	250						
Suite 415 Kitchenette - Faucet (N)	4	E.Coli	--	Absent	Absent						
Suite 415 Kitchenette - Faucet (N)	4	Lead	ppb	0	0						
Suite 415 Kitchenette - Faucet (N)	4	Total Coliform	--	Absent	Absent						
Suite 416 Kitchenette - Faucet (NE) - North	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 416 Kitchenette - Faucet (NE) - North	4	Copper	ppb	760	990	230	1500	610	800	730	590
Suite 416 Kitchenette - Faucet (NE) - North	4	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 416 Kitchenette - Faucet (NE) - North	4	Lead	ppb	0	0	0	0	0	0	0	0
Suite 416 Kitchenette - Faucet (NE) - North	4	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 420 Kitchenette - Faucet (NE) - South	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 420 Kitchenette - Faucet (NE) - South	4	Copper	ppb	750	540	140	140	530	660	760	290
Suite 420 Kitchenette - Faucet (NE) - South	4	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 420 Kitchenette - Faucet (NE) - South	4	Lead	ppb	0	0	0	0	0	0	0	0
Suite 420 Kitchenette - Faucet (NE) - South	4	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 435 Kitchenette Faucet (SE)	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 435 Kitchenette Faucet (SE)	4	Copper	ppb	610	490	83	100	810	660	710	460
Suite 435 Kitchenette Faucet (SE)	4	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 435 Kitchenette Faucet (SE)	4	Lead	ppb	0	0	0	0	0	0	0	0
Suite 435 Kitchenette Faucet (SE)	4	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 435 Kitchenette Faucet (SE) A (Second fixtur	4	Copper	ppb	170	200	80	300	760	300	700	300
Suite 435 Kitchenette Faucet (SE) A (Second fixtur	4	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 435 Kitchenette Faucet (SE) A (Second fixtur	4	Lead	ppb	0	0	0	0	0	0	0	0
Suite 435 Kitchenette Faucet (SE) A (Second fixtur	4	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 435 Kitchenette Faucet (SE) A (Second fixtur	4	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
C407 Janitor's Closet-Mop/Slop Sink	4	Legionella Culture	CFU/mL								
C407 Janitor's Closet-Mop/Slop Sink	4	Copper	ppb								
C407 Janitor's Closet-Mop/Slop Sink	4	E.Coli	--								
C407 Janitor's Closet-Mop/Slop Sink	4	Lead	ppb								
C407 Janitor's Closet-Mop/Slop Sink	4	Total Coliform	--								
Suite 540 Kitchenette - Faucet (507-25)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 540 Kitchenette - Faucet (507-25)	5	Copper	ppb	300	600	910	870	920	880	750	610
Suite 540 Kitchenette - Faucet (507-25)	5	E.Coli	--	Absent	Absent	Absent	Absent				

Suite 540 Kitchenette - Faucet (507-25)	5	Lead	ppb	0	0	0	0	0	0	0	0
Suite 540 Kitchenette - Faucet (507-25)	5	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Copper	ppb	1600	830	1000	1200	1200	940	730	430
Suite 535 Break Room-Kitchen Faucet (507-36)	5	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Lead	ppb	0	0	0	0	0	0	0	0
Suite 535 Break Room-Kitchen Faucet (507-36)	5	Total Coliform	--	Absent	Absent	Absent	Absent				
540 Faucet (507-26)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
540 Faucet (507-26)	5	Copper	ppb	770	550	480	680	860	650	710	500
540 Faucet (507-26)	5	E.Coli	--	Absent	Absent	Absent	Absent				
540 Faucet (507-26)	5	Lead	ppb	0	0	0	0	0	0	0	0
540 Faucet (507-26)	5	Total Coliform	--	Absent	Absent	Absent	Absent				
540 Faucet (507-26) A (Second fixture)	5	E.Coli	--								
540 Faucet (507-26) A (Second fixture)	5	Total Coliform	--								
540 Faucet (507-26) A (Second fixture)	5	Lead	ppb								
540 Faucet (507-26) A (Second fixture)	5	Copper	ppb								
540 Faucet (507-26) A (Second fixture)	5	Legionella Culture	CFU/mL								
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Legionella Culture	CFU/mL								
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Copper	ppb								
5W-2 Women's Restroom West - Lavatory Faucet-L	5	E.Coli	--								
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Lead	ppb								
5W-2 Women's Restroom West - Lavatory Faucet-L	5	Total Coliform	--								
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Copper	ppb	920	230	210	210	120	110	830	350
5W-2 Women's Restroom West - Lavatory Faucet-C	5	E.Coli	--	Absent	Absent	Absent	Absent				
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Lead	ppb	25	0	1.6	0	1.3	0	7.2	0
5W-2 Women's Restroom West - Lavatory Faucet-C	5	Total Coliform	--	Absent	Absent	Absent	Absent				
5W-2 Women's Restroom West - Lavatory Faucet-F	5	Legionella Culture	CFU/mL								
5W-2 Women's Restroom West - Lavatory Faucet-F	5	Copper	ppb								
5W-2 Women's Restroom West - Lavatory Faucet-F	5	E.Coli	--								
5W-2 Women's Restroom West - Lavatory Faucet-F	5	Lead	ppb								
5W-2 Women's Restroom West - Lavatory Faucet-F	5	Total Coliform	--								

5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL								
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Copper	ppb								
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	E.Coli	--								
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Lead	ppb								
5M-2 Men's Restroom West - Lavatory Faucet-Left	5	Total Coliform	--								
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	Legionella Culture	CFU/mL	ND	4	ND	0.8	ND	ND	ND	ND
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	Copper	ppb	1300	410	2200	270	86	68	370	250
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	E.Coli	--	Absent	Absent	Absent	Absent				
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	Lead	ppb	0	0	15	0	0	0	0	0
5M-2 Men's Restroom West - Lavatory Faucet-Righ	5	Total Coliform	--	Absent	Absent	Absent	Absent				
5 Corridor West - Drinking Fountain-Right	5	Legionella Culture	CFU/mL								
5 Corridor West - Drinking Fountain-Right	5	Copper	ppb								
5 Corridor West - Drinking Fountain-Right	5	E.Coli	--								
5 Corridor West - Drinking Fountain-Right	5	Lead	ppb								
5 Corridor West - Drinking Fountain-Right	5	Total Coliform	--								
Suite 540 Kitchenette - Faucet (507-15)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 540 Kitchenette - Faucet (507-15)	5	Copper	ppb	970	940	830	380	860	660	640	400
Suite 540 Kitchenette - Faucet (507-15)	5	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 540 Kitchenette - Faucet (507-15)	5	Lead	ppb	0	0	0	0	0	0	0	0
Suite 540 Kitchenette - Faucet (507-15)	5	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 540 Training Lobby - Faucet (507-12)	5	Legionella Culture	CFU/mL								
Suite 540 Training Lobby - Faucet (507-12)	5	Copper	ppb								
Suite 540 Training Lobby - Faucet (507-12)	5	E.Coli	--								
Suite 540 Training Lobby - Faucet (507-12)	5	Lead	ppb								
Suite 540 Training Lobby - Faucet (507-12)	5	Total Coliform	--								
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Legionella Culture	CFU/mL								
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Copper	ppb			570	470				
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	E.Coli	--			Absent	Absent				
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Lead	ppb			7	0				
5M-1 Men's Restroom East - Lavatory Faucet-Left	5	Total Coliform	--			Absent	Absent				
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	Legionella Culture	CFU/mL	ND	ND	ND	0.4	ND	ND		
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	Copper	ppb	860	75			220	230		

5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	E.Coli	--	Absent	Absent						
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	Lead	ppb	22	0			4.1	0		
5M-1 Men's Restroom East - Lavatory Faucet-Righ	5	Total Coliform	--	Absent	Absent						
5W-1 Women's Restroom East - Lavatory Faucet-L	5	Legionella Culture	CFU/mL								
5W-1 Women's Restroom East - Lavatory Faucet-L	5	Copper	ppb								
5W-1 Women's Restroom East - Lavatory Faucet-L	5	E.Coli	--								
5W-1 Women's Restroom East - Lavatory Faucet-L	5	Lead	ppb								
5W-1 Women's Restroom East - Lavatory Faucet-L	5	Total Coliform	--								
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Legionella Culture	CFU/mL	0.8	ND	ND	ND	ND	0.4	ND	ND
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Copper	ppb	2000	1300	360	400	200	230	300	360
5W-1 Women's Restroom East - Lavatory Faucet-C	5	E.Coli	--	Absent	Absent	Absent	Absent				
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Lead	ppb	51	0	4.6	1.1	2.6	0	0	0
5W-1 Women's Restroom East - Lavatory Faucet-C	5	Total Coliform	--	Absent	Absent	Absent	Absent				
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Legionella Culture	CFU/mL								
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Copper	ppb								
5W-1 Women's Restroom East - Lavatory Faucet-R	5	E.Coli	--								
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Lead	ppb								
5W-1 Women's Restroom East - Lavatory Faucet-R	5	Total Coliform	--								
Suite 530 Kitchenette - Faucet (509-10)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 530 Kitchenette - Faucet (509-10)	5	Copper	ppb	92	160	390	520	770	440	450	260
Suite 530 Kitchenette - Faucet (509-10)	5	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 530 Kitchenette - Faucet (509-10)	5	Lead	ppb	0	0	0	0	0	0	0	0
Suite 530 Kitchenette - Faucet (509-10)	5	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 520 Kitchenette Faucet (508-13)	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 520 Kitchenette Faucet (508-13)	5	Copper	ppb	1700	1000	900	1600	1400	980	900	570
Suite 520 Kitchenette Faucet (508-13)	5	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 520 Kitchenette Faucet (508-13)	5	Lead	ppb	0	0	0	0	0	0	0	0
Suite 520 Kitchenette Faucet (508-13)	5	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 532 Lactation Room - Faucet	5	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 532 Lactation Room - Faucet	5	Copper	ppb	810	780	1600	790	1000	65	900	230
Suite 532 Lactation Room - Faucet	5	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 532 Lactation Room - Faucet	5	Lead	ppb	0	0	0	0	0	0	0	1.7

Suite 532 Lactation Room - Faucet	5	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite. 540 Kitchenette - Faucet	5	Legionella Culture	CFU/mL								
Suite. 540 Kitchenette - Faucet	5	Copper	ppb								
Suite. 540 Kitchenette - Faucet	5	E.Coli	--								
Suite. 540 Kitchenette - Faucet	5	Lead	ppb								
Suite. 540 Kitchenette - Faucet	5	Total Coliform	--								
C507 Janitor's Closet - Mop/Slop Sink	5	Legionella Culture	CFU/mL								
C507 Janitor's Closet - Mop/Slop Sink	5	Copper	ppb								
C507 Janitor's Closet - Mop/Slop Sink	5	E.Coli	--								
C507 Janitor's Closet - Mop/Slop Sink	5	Lead	ppb								
C507 Janitor's Closet - Mop/Slop Sink	5	Total Coliform	--								
Suite 614 Room-Kitchen Faucet (610-03)	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 614 Room-Kitchen Faucet (610-03)	6	Copper	ppb	310	340	300	250	960	810	200	110
Suite 614 Room-Kitchen Faucet (610-03)	6	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 614 Room-Kitchen Faucet (610-03)	6	Lead	ppb	0	0	0	0	1.7	0	0	0
Suite 614 Room-Kitchen Faucet (610-03)	6	Total Coliform	--	Absent	Absent	Absent	Absent				
C607-Janitor's Closet - Mop/Slop Sink	6	Legionella Culture	CFU/mL								
C607-Janitor's Closet - Mop/Slop Sink	6	Copper	ppb								
C607-Janitor's Closet - Mop/Slop Sink	6	E.Coli	--								
C607-Janitor's Closet - Mop/Slop Sink	6	Lead	ppb								
C607-Janitor's Closet - Mop/Slop Sink	6	Total Coliform	--								
6 Corridor West - Drinking Fountain-Left	6	Legionella Culture	CFU/mL								
6 Corridor West - Drinking Fountain-Left	6	Copper	ppb								
6 Corridor West - Drinking Fountain-Left	6	E.Coli	--								
6 Corridor West - Drinking Fountain-Left	6	Lead	ppb								
6 Corridor West - Drinking Fountain-Left	6	Total Coliform	--								
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Legionella Culture	CFU/mL								
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Copper	ppb								
6W-2 Women's Restroom West - Lavatory Faucet-L	6	E.Coli	--								
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Lead	ppb								
6W-2 Women's Restroom West - Lavatory Faucet-L	6	Total Coliform	--								
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.4	ND	ND	ND

6W-2 Women's Restroom West - Lavatory Faucet-C	6	Copper	ppb	560	300	1100	360	450	280	380	220
6W-2 Women's Restroom West - Lavatory Faucet-C	6	E.Coli	--	Absent	Absent	Absent	Absent				
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Lead	ppb	0	0	48	0	3.2	0	12	0
6W-2 Women's Restroom West - Lavatory Faucet-C	6	Total Coliform	--	Absent	Absent	Absent	Absent				
6W-2 Women's Restroom West - Lavatory Faucet-F	6	Legionella Culture	CFU/mL								
6W-2 Women's Restroom West - Lavatory Faucet-F	6	Copper	ppb								
6W-2 Women's Restroom West - Lavatory Faucet-F	6	E.Coli	--								
6W-2 Women's Restroom West - Lavatory Faucet-F	6	Lead	ppb								
6W-2 Women's Restroom West - Lavatory Faucet-F	6	Total Coliform	--								
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL								
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Copper	ppb								
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	E.Coli	--								
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Lead	ppb								
6M-2 Men's Restroom West - Lavatory Faucet-Left	6	Total Coliform	--								
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	0.4	ND	ND	ND
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	Copper	ppb	1200	340	1200	310	320	270	1000	360
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	E.Coli	--	Absent	Absent	Absent	Absent				
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	Lead	ppb	25	0	61	0	4.8	0	15	0
6M-2 Men's Restroom West - Lavatory Faucet-Righ	6	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Legionella Culture	CFU/mL	ND	ND			ND	ND		
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Copper	ppb	970	490			1100	920		
Suite 615 Break Room-Kitchen Faucet (607-06)	6	E.Coli	--	Absent	Absent						
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Lead	ppb	0	0			0	0		
Suite 615 Break Room-Kitchen Faucet (607-06)	6	Total Coliform	--	Absent	Absent						
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	Copper	ppb	750	760			1200	120		
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	E.Coli	--	Absent	Absent						
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	Lead	ppb	0	0			0	0		
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	Total Coliform	--	Absent	Absent						
Suite 615 Break Room-Kitchen Faucet (607-06A) A	6	Legionella Culture	CFU/mL	ND	ND			ND	0.4		
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Legionella Culture	CFU/mL								
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Copper	ppb								
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	E.Coli	--								

6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Lead	ppb								
6M-1 Men's Restroom East - Lavatory Faucet-Left	6	Total Coliform	--								
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	Copper	ppb	1100	350	850	680	400	180	400	640
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	E.Coli	--	Absent	Absent	Absent	Absent				
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	Lead	ppb	18	0	27	0	1.3	0	2.7	0
6M-1 Men's Restroom East - Lavatory Faucet-Righ	6	Total Coliform	--	Absent	Absent	Absent	Absent				
6W-1 Women's Restroom East - Lavatory Faucet-L	6	Legionella Culture	CFU/mL								
6W-1 Women's Restroom East - Lavatory Faucet-L	6	Copper	ppb								
6W-1 Women's Restroom East - Lavatory Faucet-L	6	E.Coli	--								
6W-1 Women's Restroom East - Lavatory Faucet-L	6	Lead	ppb								
6W-1 Women's Restroom East - Lavatory Faucet-L	6	Total Coliform	--								
6W-1 Women's Restroom East - Lavatory Faucet-C	6	Legionella Culture	CFU/mL	ND	ND	6.4	ND	ND	ND	ND	ND
6W-1 Women's Restroom East - Lavatory Faucet-C	6	Copper	ppb	1200	300	1900	340	360	260	280	240
6W-1 Women's Restroom East - Lavatory Faucet-C	6	E.Coli	--	Absent	Absent	Absent	Absent				
6W-1 Women's Restroom East - Lavatory Faucet-C	6	Lead	ppb	17	0	67	0	2.2	0	2.4	0
6W-1 Women's Restroom East - Lavatory Faucet-C	6	Total Coliform	--	Absent	Absent	Absent	Absent				
6W-1 Women's Restroom East - Lavatory Faucet-R	6	Legionella Culture	CFU/mL								
6W-1 Women's Restroom East - Lavatory Faucet-R	6	Copper	ppb								
6W-1 Women's Restroom East - Lavatory Faucet-R	6	E.Coli	--								
6W-1 Women's Restroom East - Lavatory Faucet-R	6	Lead	ppb								
6W-1 Women's Restroom East - Lavatory Faucet-R	6	Total Coliform	--								
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Copper	ppb			460	510	1300	680	370	170
Suite 620 Break Room-Kitchen Faucet (608-12)	6	E.Coli	--			Absent	Absent				
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Lead	ppb			0	0	0	0	0	0
Suite 620 Break Room-Kitchen Faucet (608-12)	6	Total Coliform	--			Absent	Absent				
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Copper	ppb			460	240	980	530	390	220
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	E.Coli	--			Absent	Absent				
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Lead	ppb			0	0	0	0	0	0
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Total Coliform	--			Absent	Absent				
Suite 620 Break Room Kitchen - Faucet (608-12A)	6	Legionella Culture	CFU/mL			ND	ND	ND	ND	ND	ND



Suite 608 Kitchen - Faucet	6	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 608 Kitchen - Faucet	6	Copper	ppb	400	240	110	380	970	890	310	100
Suite 608 Kitchen - Faucet	6	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 608 Kitchen - Faucet	6	Lead	ppb	0	0	0	0	0	0	0	0
Suite 608 Kitchen - Faucet	6	Total Coliform	--	Absent	Absent	Absent	Absent				
C707-Janitor's Closet-Mop/Slop Sink	7	Legionella Culture	CFU/mL								
C707-Janitor's Closet-Mop/Slop Sink	7	Copper	ppb								
C707-Janitor's Closet-Mop/Slop Sink	7	E.Coli	--								
C707-Janitor's Closet-Mop/Slop Sink	7	Lead	ppb								
C707-Janitor's Closet-Mop/Slop Sink	7	Total Coliform	--								
7 Corridor East - Drinking Fountain-Left	7	Legionella Culture	CFU/mL								
7 Corridor East - Drinking Fountain-Left	7	Copper	ppb								
7 Corridor East - Drinking Fountain-Left	7	E.Coli	--								
7 Corridor East - Drinking Fountain-Left	7	Lead	ppb								
7 Corridor East - Drinking Fountain-Left	7	Total Coliform	--								
Suite 707-01 Break Room - Faucet (707-2)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	4.8	ND
Suite 707-01 Break Room - Faucet (707-2)	7	Copper	ppb	74	56	1100	66	780	610	84	83
Suite 707-01 Break Room - Faucet (707-2)	7	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 707-01 Break Room - Faucet (707-2)	7	Lead	ppb	0	0	0	0	0	0	0	0
Suite 707-01 Break Room - Faucet (707-2)	7	Total Coliform	--	Absent	Absent	Absent	Absent				
7W-2 Women's Restroom West - Lavatory Faucet-L	7	Legionella Culture	CFU/mL								
7W-2 Women's Restroom West - Lavatory Faucet-L	7	Copper	ppb								
7W-2 Women's Restroom West - Lavatory Faucet-L	7	E.Coli	--								
7W-2 Women's Restroom West - Lavatory Faucet-L	7	Lead	ppb								
7W-2 Women's Restroom West - Lavatory Faucet-L	7	Total Coliform	--								
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Legionella Culture	CFU/mL	ND	ND	2.0	0.4	ND	ND	ND	ND
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Copper	ppb	660	270	1600	410	460	280	570	360
7W-2 Women's Restroom West - Lavatory Faucet-C	7	E.Coli	--	Absent	Absent	Absent	Absent				
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Lead	ppb	0	0	42	0	0	0	2.9	0
7W-2 Women's Restroom West - Lavatory Faucet-C	7	Total Coliform	--	Absent	Absent	Absent	Absent				
7W-2 Women's Restroom West - Lavatory Faucet-F	7	Legionella Culture	CFU/mL								
7W-2 Women's Restroom West - Lavatory Faucet-F	7	Copper	ppb								

7W-2 Women's Restroom West - Lavatory Faucet-F	7	E.Coli	--								
7W-2 Women's Restroom West - Lavatory Faucet-F	7	Lead	ppb								
7W-2 Women's Restroom West - Lavatory Faucet-F	7	Total Coliform	--								
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL								
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Copper	ppb								
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	E.Coli	--								
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Lead	ppb								
7M-2 Men's Restroom West - Lavatory Faucet-Left	7	Total Coliform	--								
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Copper	ppb	780	340	880	350	320	400	280	240
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	E.Coli	--	Absent	Absent	Absent	Absent				
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Lead	ppb	0	0	77	0	0	1.7	0	0
7M-2 Men's Restroom West - Lavatory Faucet-Righ	7	Total Coliform	--	Absent	Absent	Absent	Absent				
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Legionella Culture	CFU/mL								
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Copper	ppb								
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	E.Coli	--								
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Lead	ppb								
7M-1 Men's Restroom East - Lavatory Faucet-Left	7	Total Coliform	--								
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	Copper	ppb	490	280	940	260	420	220	390	200
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	E.Coli	--	Absent	Absent	Absent	Absent				
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	Lead	ppb	0	0	12	0	1.1	0	1.3	0
7M-1 Men's Restroom East - Lavatory Faucet-Righ	7	Total Coliform	--	Absent	Absent	Absent	Absent				
7W-1 Women's Restroom East - Lavatory Faucet-L	7	Legionella Culture	CFU/mL								
7W-1 Women's Restroom East - Lavatory Faucet-L	7	Copper	ppb								
7W-1 Women's Restroom East - Lavatory Faucet-L	7	E.Coli	--								
7W-1 Women's Restroom East - Lavatory Faucet-L	7	Lead	ppb								
7W-1 Women's Restroom East - Lavatory Faucet-L	7	Total Coliform	--								
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Legionella Culture	CFU/mL							ND	ND
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Copper	ppb							510	250
7W-1 Women's Restroom East - Lavatory Faucet-C	7	E.Coli	--								
7W-1 Women's Restroom East - Lavatory Faucet-C	7	Lead	ppb							2.3	0

7W-1 Women's Restroom East - Lavatory Faucet-C	7	Total Coliform	--								
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND		
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Copper	ppb	650	110	1100	100	290	340		
7W-1 Women's Restroom East - Lavatory Faucet-R	7	E.Coli	--	Absent	Absent	Absent	Absent				
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Lead	ppb	0	0	19	0	1.7	0		
7W-1 Women's Restroom East - Lavatory Faucet-R	7	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 710 Faucet (710-03)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 710 Faucet (710-03)	7	Copper	ppb	110	100	130	160	500	460	650	410
Suite 710 Faucet (710-03)	7	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 710 Faucet (710-03)	7	Lead	ppb	0	0	0	0	0	0	0	0
Suite 710 Faucet (710-03)	7	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 707-10 Faucet (707-07)	7	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 707-10 Faucet (707-07)	7	Copper	ppb	230	170	970	700	870	670	640	310
Suite 707-10 Faucet (707-07)	7	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 707-10 Faucet (707-07)	7	Lead	ppb	0	0	0	0	0	0	0	0
Suite 707-10 Faucet (707-07)	7	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 810 Kitchen Faucet	8	Legionella Culture	CFU/mL	ND	ND	ND	0.4	ND	ND	ND	ND
Suite 810 Kitchen Faucet	8	Copper	ppb	270	430	420	350	660	320	280	210
Suite 810 Kitchen Faucet	8	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 810 Kitchen Faucet	8	Lead	ppb	0	0	0	0	0	0	0	0
Suite 810 Kitchen Faucet	8	Total Coliform	--	Absent	Absent	Absent	Absent				
C807-Janitor's Closet-Mop/Slop Sink	8	Legionella Culture	CFU/mL								
C807-Janitor's Closet-Mop/Slop Sink	8	Copper	ppb								
C807-Janitor's Closet-Mop/Slop Sink	8	E.Coli	--								
C807-Janitor's Closet-Mop/Slop Sink	8	Lead	ppb								
C807-Janitor's Closet-Mop/Slop Sink	8	Total Coliform	--								
8 Corridor West - Drinking Fountain-Left	8	Legionella Culture	CFU/mL								
8 Corridor West - Drinking Fountain-Left	8	Copper	ppb								
8 Corridor West - Drinking Fountain-Left	8	E.Coli	--								
8 Corridor West - Drinking Fountain-Left	8	Lead	ppb								
8 Corridor West - Drinking Fountain-Left	8	Total Coliform	--								
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Legionella Culture	CFU/mL								

8W-2 Women's Restroom West - Lavatory Faucet-L	8	Copper	ppb								
8W-2 Women's Restroom West - Lavatory Faucet-L	8	E.Coli	--								
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Lead	ppb								
8W-2 Women's Restroom West - Lavatory Faucet-L	8	Total Coliform	--								
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Copper	ppb	410	290	960	370	330	290	670	310
8W-2 Women's Restroom West - Lavatory Faucet-C	8	E.Coli	--	Absent	Absent	Absent	Absent				
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Lead	ppb	0	0	88	0	0	0	1.6	0
8W-2 Women's Restroom West - Lavatory Faucet-C	8	Total Coliform	--	Absent	Absent	Absent	Absent				
8W-2 Women's Restroom West - Lavatory Faucet-F	8	Legionella Culture	CFU/mL								
8W-2 Women's Restroom West - Lavatory Faucet-F	8	Copper	ppb								
8W-2 Women's Restroom West - Lavatory Faucet-F	8	E.Coli	--								
8W-2 Women's Restroom West - Lavatory Faucet-F	8	Lead	ppb								
8W-2 Women's Restroom West - Lavatory Faucet-F	8	Total Coliform	--								
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL								
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Copper	ppb								
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	E.Coli	--								
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Lead	ppb								
8M-2 Men's Restroom West - Lavatory Faucet-Left	8	Total Coliform	--								
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Copper	ppb	540	300	420	640	420	270	280	290
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	E.Coli	--	Absent	Absent	Absent	Absent				
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Lead	ppb	0	0	0	8.6	0	0	1.4	0
8M-2 Men's Restroom West - Lavatory Faucet-Righ	8	Total Coliform	--	Absent	Absent	Absent	Absent				
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Legionella Culture	CFU/mL								
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Copper	ppb								
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	E.Coli	--								
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Lead	ppb								
8M-1 Men's Restroom East - Lavatory Faucet-Left	8	Total Coliform	--								
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	Copper	ppb	700	350	740	340	450	330	370	370
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	E.Coli	--	Absent	Absent	Absent	Absent				

8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	Lead	ppb	0	0	12	0	1	0	0	0
8M-1 Men's Restroom East - Lavatory Faucet-Righ	8	Total Coliform	--	Absent	Absent	Absent	Absent				
8W-1 Women's Restroom East - Lavatory Faucet-L	8	Legionella Culture	CFU/mL								
8W-1 Women's Restroom East - Lavatory Faucet-L	8	Copper	ppb								
8W-1 Women's Restroom East - Lavatory Faucet-L	8	E.Coli	--								
8W-1 Women's Restroom East - Lavatory Faucet-L	8	Lead	ppb								
8W-1 Women's Restroom East - Lavatory Faucet-L	8	Total Coliform	--								
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Legionella Culture	CFU/mL	0.4	ND	ND	12.0	ND	ND	ND	ND
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Copper	ppb	740	380	600	440	680	340	270	340
8W-1 Women's Restroom East - Lavatory Faucet-C	8	E.Coli	--	Absent	Absent	Absent	Absent				
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Lead	ppb	0	0	12	0	4.3	0	2.5	0
8W-1 Women's Restroom East - Lavatory Faucet-C	8	Total Coliform	--	Absent	Absent	Absent	Absent				
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Legionella Culture	CFU/mL								
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Copper	ppb								
8W-1 Women's Restroom East - Lavatory Faucet-R	8	E.Coli	--								
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Lead	ppb								
8W-1 Women's Restroom East - Lavatory Faucet-R	8	Total Coliform	--								
Suite 808A Break Room Faucet (809-02)	8	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 808A Break Room Faucet (809-02)	8	Copper	ppb	350	300	290	290	670	240	480	200
Suite 808A Break Room Faucet (809-02)	8	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 808A Break Room Faucet (809-02)	8	Lead	ppb	0	0	0	0	0	0	0	0
Suite 808A Break Room Faucet (809-02)	8	Total Coliform	--	Absent	Absent	Absent	Absent				
C907-Janitor's Closet-Mop/Slop Sink	9	Legionella Culture	CFU/mL								
C907-Janitor's Closet-Mop/Slop Sink	9	Copper	ppb								
C907-Janitor's Closet-Mop/Slop Sink	9	E.Coli	--								
C907-Janitor's Closet-Mop/Slop Sink	9	Lead	ppb								
C907-Janitor's Closet-Mop/Slop Sink	9	Total Coliform	--								
9 Corridor East - Drinking Fountain-Left	9	Legionella Culture	CFU/mL								
9 Corridor East - Drinking Fountain-Left	9	Copper	ppb								
9 Corridor East - Drinking Fountain-Left	9	E.Coli	--								
9 Corridor East - Drinking Fountain-Left	9	Lead	ppb								
9 Corridor East - Drinking Fountain-Left	9	Total Coliform	--								

Suite 907A Break Room Faucet (907-22)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 907A Break Room Faucet (907-22)	9	Copper	ppb	510	810	370	700	900	470	690	370
Suite 907A Break Room Faucet (907-22)	9	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 907A Break Room Faucet (907-22)	9	Lead	ppb	0	0	0	0	0	0	0	0
Suite 907A Break Room Faucet (907-22)	9	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 910A Faucet (910-05)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 910A Faucet (910-05)	9	Copper	ppb	650	700	710	700	680	520	600	450
Suite 910A Faucet (910-05)	9	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 910A Faucet (910-05)	9	Lead	ppb	0	0	0	0	0	0	0	0
Suite 910A Faucet (910-05)	9	Total Coliform	--	Absent	Absent	Absent	Absent				
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Legionella Culture	CFU/mL								
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Copper	ppb								
9W-2 Women's Restroom West - Lavatory Faucet-L	9	E.Coli	--								
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Lead	ppb								
9W-2 Women's Restroom West - Lavatory Faucet-L	9	Total Coliform	--								
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Legionella Culture	CFU/mL	ND	0.4	ND	0.8	ND	1.2	49.6	0.4
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Copper	ppb	510	270	710	440	630	420	360	230
9W-2 Women's Restroom West - Lavatory Faucet-C	9	E.Coli	--	Absent	Absent	Absent	Absent				
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Lead	ppb	0	0	26	0	2	0	2.1	0
9W-2 Women's Restroom West - Lavatory Faucet-C	9	Total Coliform	--	Absent	Absent	Absent	Absent				
9W-2 Women's Restroom West - Lavatory Faucet-F	9	Legionella Culture	CFU/mL								
9W-2 Women's Restroom West - Lavatory Faucet-F	9	Copper	ppb								
9W-2 Women's Restroom West - Lavatory Faucet-F	9	E.Coli	--								
9W-2 Women's Restroom West - Lavatory Faucet-F	9	Lead	ppb								
9W-2 Women's Restroom West - Lavatory Faucet-F	9	Total Coliform	--								
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL								
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Copper	ppb								
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	E.Coli	--								
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Lead	ppb								
9M-2 Men's Restroom West - Lavatory Faucet-Left	9	Total Coliform	--								
9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	5.6	ND
9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	Copper	ppb	1500	330	520	410	650	230	700	290

9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	E.Coli	--	Absent	Absent	Absent	Absent				
9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	Lead	ppb	0	0	0	0	1.7	0	3.6	0
9M-2 Men's Restroom West - Lavatory Faucet-Righ	9	Total Coliform	--	Absent	Absent	Absent	Absent				
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Legionella Culture	CFU/mL								
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Copper	ppb								
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	E.Coli	--								
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Lead	ppb								
9M-1 Men's Restroom East - Lavatory Faucet-Left	9	Total Coliform	--								
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	Legionella Culture	CFU/mL	ND	ND	1.6	0.4	ND	ND	ND	ND
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	Copper	ppb	4000	310	470	330	270	240	520	250
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	E.Coli	--	Absent	Absent	Absent	Absent				
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	Lead	ppb	0	0	0	0	0	0	3.5	0
9M-1 Men's Restroom East - Lavatory Faucet-Righ	9	Total Coliform	--	Absent	Absent	Absent	Absent				
9W-1 Women's Restroom East - Lavatory Faucet-L	9	Legionella Culture	CFU/mL								
9W-1 Women's Restroom East - Lavatory Faucet-L	9	Copper	ppb								
9W-1 Women's Restroom East - Lavatory Faucet-L	9	E.Coli	--								
9W-1 Women's Restroom East - Lavatory Faucet-L	9	Lead	ppb								
9W-1 Women's Restroom East - Lavatory Faucet-L	9	Total Coliform	--								
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Legionella Culture	CFU/mL	4	ND	115.2	ND	ND	ND	ND	ND
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Copper	ppb	430	220	850	610	550	300	640	740
9W-1 Women's Restroom East - Lavatory Faucet-C	9	E.Coli	--	Absent	Absent	Absent	Absent				
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Lead	ppb	0	0	6.6	0	1.7	0	2.7	2.1
9W-1 Women's Restroom East - Lavatory Faucet-C	9	Total Coliform	--	Absent	Absent	Absent	Absent				
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Legionella Culture	CFU/mL								
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Copper	ppb								
9W-1 Women's Restroom East - Lavatory Faucet-R	9	E.Coli	--								
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Lead	ppb								
9W-1 Women's Restroom East - Lavatory Faucet-R	9	Total Coliform	--								
Suite 908 Break Room Faucet (908-15)	9	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 908 Break Room Faucet (908-15)	9	Copper	ppb	840	680	740	830	900	780	740	400
Suite 908 Break Room Faucet (908-15)	9	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 908 Break Room Faucet (908-15)	9	Lead	ppb	0	0	0	0	0	0	0	0

Suite 908 Break Room Faucet (908-15)	9	Total Coliform	--	Absent	Absent	Absent	Absent				
C1007-Janitor's Closet-Mop/Slop Sink	10	Legionella Culture	CFU/mL								
C1007-Janitor's Closet-Mop/Slop Sink	10	Copper	ppb								
C1007-Janitor's Closet-Mop/Slop Sink	10	E.Coli	--								
C1007-Janitor's Closet-Mop/Slop Sink	10	Lead	ppb								
C1007-Janitor's Closet-Mop/Slop Sink	10	Total Coliform	--								
10 Corridor West - Drinking Fountain-Left	10	Legionella Culture	CFU/mL								
10 Corridor West - Drinking Fountain-Left	10	Copper	ppb								
10 Corridor West - Drinking Fountain-Left	10	E.Coli	--								
10 Corridor West - Drinking Fountain-Left	10	Lead	ppb								
10 Corridor West - Drinking Fountain-Left	10	Total Coliform	--								
Suite 1010 Lavatory Faucet	10	Legionella Culture	CFU/mL								
Suite 1010 Lavatory Faucet	10	Copper	ppb								
Suite 1010 Lavatory Faucet	10	E.Coli	--								
Suite 1010 Lavatory Faucet	10	Lead	ppb								
Suite 1010 Lavatory Faucet	10	Total Coliform	--								
Suite 1010 Kitchenette Faucet	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 1010 Kitchenette Faucet	10	Copper	ppb	1000	1100	110	78	800	670	380	210
Suite 1010 Kitchenette Faucet	10	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 1010 Kitchenette Faucet	10	Lead	ppb	0	0	0	0	0	0	0	0
Suite 1010 Kitchenette Faucet	10	Total Coliform	--	Absent	Absent	Absent	Absent				
10W-2 Women's Restroom West - Lavatory Faucet	10	Legionella Culture	CFU/mL								
10W-2 Women's Restroom West - Lavatory Faucet	10	Copper	ppb								
10W-2 Women's Restroom West - Lavatory Faucet	10	E.Coli	--								
10W-2 Women's Restroom West - Lavatory Faucet	10	Lead	ppb								
10W-2 Women's Restroom West - Lavatory Faucet	10	Total Coliform	--								
10W-2 Women's Restroom West - Lavatory Faucet	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
10W-2 Women's Restroom West - Lavatory Faucet	10	Copper	ppb	360	230	410	340	450	280	390	350
10W-2 Women's Restroom West - Lavatory Faucet	10	E.Coli	--	Absent	Absent	Absent	Absent				
10W-2 Women's Restroom West - Lavatory Faucet	10	Lead	ppb	0	0	3.5	0	1.4	0	0	0
10W-2 Women's Restroom West - Lavatory Faucet	10	Total Coliform	--	Absent	Absent	Absent	Absent				
10W-2 Women's Restroom West - Lavatory Faucet	10	Legionella Culture	CFU/mL								



10W-2 Women's Restroom West - Lavatory Faucet	10	Copper	ppb								
10W-2 Women's Restroom West - Lavatory Faucet	10	E.Coli	--								
10W-2 Women's Restroom West - Lavatory Faucet	10	Lead	ppb								
10W-2 Women's Restroom West - Lavatory Faucet	10	Total Coliform	--								
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL								
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Copper	ppb								
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	E.Coli	--								
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Lead	ppb								
10M-2 Men's Restroom West - Lavatory Faucet-Left	10	Total Coliform	--								
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	0.8	ND	ND
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Copper	ppb	400	310	380	370	370	370	370	300
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	E.Coli	--	Absent	Absent	Absent	Absent				
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Lead	ppb	0	0	1.2	0	0	0	0	0
10M-2 Men's Restroom West - Lavatory Faucet-Right	10	Total Coliform	--	Absent	Absent	Absent	Absent				
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Legionella Culture	CFU/mL								
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Copper	ppb								
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	E.Coli	--								
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Lead	ppb								
10M-1 Men's Restroom East - Lavatory Faucet-Left	10	Total Coliform	--								
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Copper	ppb	500	350	480	350	390	330	330	430
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	E.Coli	--	Absent	Absent	Absent	Absent				
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Lead	ppb	0	0	20	0	2.2	0	0	0
10M-1 Men's Restroom East - Lavatory Faucet-Right	10	Total Coliform	--	Absent	Absent	Absent	Absent				
10W-1 Women's Restroom East - Lavatory Faucet-	10	Legionella Culture	CFU/mL								
10W-1 Women's Restroom East - Lavatory Faucet-	10	Copper	ppb								
10W-1 Women's Restroom East - Lavatory Faucet-	10	E.Coli	--								
10W-1 Women's Restroom East - Lavatory Faucet-	10	Lead	ppb								
10W-1 Women's Restroom East - Lavatory Faucet-	10	Total Coliform	--								
10W-1 Women's Restroom East - Lavatory Faucet-	10	Legionella Culture	CFU/mL					8.4	ND	ND	0.4
10W-1 Women's Restroom East - Lavatory Faucet-	10	Copper	ppb					870	89	220	40
10W-1 Women's Restroom East - Lavatory Faucet-	10	E.Coli	--								

10W-1 Women's Restroom East - Lavatory Faucet-	10	Lead	ppb					12	0	13	0
10W-1 Women's Restroom East - Lavatory Faucet-	10	Total Coliform	--								
10W-1 Women's Restroom East - Lavatory Faucet-	10	Legionella Culture	CFU/mL	ND	ND	ND	ND				
10W-1 Women's Restroom East - Lavatory Faucet-	10	Copper	ppb	420	280	820	330				
10W-1 Women's Restroom East - Lavatory Faucet-	10	E.Coli	--	Absent	Absent	Absent	Absent				
10W-1 Women's Restroom East - Lavatory Faucet-	10	Lead	ppb	0	0	12	0				
10W-1 Women's Restroom East - Lavatory Faucet-	10	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	Copper	ppb	760	640	640	610	730	530	360	250
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	Lead	ppb	0	0	0	0	3	0	0	0
Suite 1009C Break Room-Kitchen Faucet (1009-19	10	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Copper	ppb	530	710	210	200	900	580	950	480
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Lead	ppb	0	0	0	0	0	0	0	0
Suite 1015 GSA Kitchenette Faucet (1000-03)	10	Total Coliform	--	Absent	Absent	Absent	Absent				
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Legionella Culture	CFU/mL	ND	ND	ND	ND	ND	ND	ND	ND
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Copper	ppb	560	450	770	900	680	530	0	460
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	E.Coli	--	Absent	Absent	Absent	Absent				
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Lead	ppb	1	0	0	0	0	0	0	0
Suite 1008 Break Room-Kitchen Faucet (1009-07)	10	Total Coliform	--	Absent	Absent	Absent	Absent				
EC Roof -Cooling Tower	EC Roof	Legionella Culture	CFU/mL								
EC Roof -Cooling Tower	EC Roof	E.Coli	--								
EC Roof -Cooling Tower	EC Roof	Total Coliform	--								
EC Roof -Cooling Tower	EC Roof	Copper	ppb								
EC Roof -Cooling Tower	EC Roof	Lead	ppb								
Water Cooler 108 Left	1	Legionella Culture	CFU/mL		ND		ND		ND		ND
Water Cooler 108 Left	1	Copper	ppb		0		0		0		0
Water Cooler 108 Left	1	E.Coli	--		Absent		Absent				
Water Cooler 108 Left	1	Lead	ppb		0		0		0		0
Water Cooler 108 Left	1	Total Coliform	--		Absent		Absent				

Water Cooler 108 Right	1	Legionella Culture	CFU/mL		ND		ND		ND		ND
Water Cooler 108 Right	1	Copper	ppb		0		0		0		0
Water Cooler 108 Right	1	E.Coli	--		Absent		Absent				
Water Cooler 108 Right	1	Lead	ppb		0		0		0		0
Water Cooler 108 Right	1	Total Coliform	--		Absent		Absent				
Water Cooler #3	1	Legionella Culture	CFU/mL				ND		ND		ND
Water Cooler #3	1	Copper	ppb		0		0		0		0
Water Cooler #3	1	E.Coli	--		Absent		Absent				
Water Cooler #3	1	Lead	ppb		0		0		0		0
Water Cooler #3	1	Total Coliform	--		Absent		Absent				
Water Cooler Loading Dock	1	Legionella Culture	CFU/mL		ND		ND		ND		ND
Water Cooler Loading Dock	1	Copper	ppb		0				0		0
Water Cooler Loading Dock	1	E.Coli	--		Absent						
Water Cooler Loading Dock	1	Lead	ppb		0				0		0
Water Cooler Loading Dock	1	Total Coliform	--		Absent						