

Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Report
From 09/01/2024 to 09/30/2024

Definitions

Filter(s) Inspected: When the box is checked, the filter was inspected for active leaks, evidence of leaks, and any defects cracks in filter casing
Filter(s) Replaced: When the box is checked, a filter was replaced at this location on the date in the first column.

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
9/2/2024	1:03 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	1:04 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	1:06 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	1:07 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	1:08 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	1:18 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	1:19 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	1:22 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	1:23 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	1:24 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	1:34 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6		
9/2/2024	1:39 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE		0.5			0.48
9/2/2024	1:44 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE			1.5		
9/2/2024	1:53 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.7		
9/2/2024	2:01 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	2:02 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	2:03 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	2:10 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	2:11 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	2:12 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	2:28 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE		1.5	1.4	1.4	
9/2/2024	2:29 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE		1.5	1.4	1.4	
9/2/2024	2:50 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	2:51 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	2:57 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	2:59 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	3:17 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE	TRUE		1.7		
9/2/2024	3:25 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	3:26 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	3:32 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	3:33 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	3:38 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	3:38 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	3:46 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	3:46 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	3:48 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	3:59 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	3:59 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	3:59 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	4:01 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	4:01 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	4:08 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6		
9/2/2024	4:09 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	4:09 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	4:09 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	4:11 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	4:11 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	4:16 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	4:18 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	4:20 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	4:20 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	4:20 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	4:32 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.5		
9/2/2024	11:10 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE		1.5	1.11	1.07	
9/2/2024	8:12 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	8:12 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	8:12 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	8:14 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	8:14 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	8:20 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	8:21 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/2/2024	8:24 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/2/2024	8:24 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/2/2024	8:24 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48

9/2/2024	8:32 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
9/2/2024	8:32 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	8:32 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	8:32 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	8:34 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	8:38 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	8:42 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	8:42 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	8:46 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	8:46 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	8:46 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	8:47 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
9/2/2024	8:51 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	8:51 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	8:51 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	8:54 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	8:54 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	8:56 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	8:57 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	9:00 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	9:00 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	9:00 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	9:03 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8		
9/2/2024	9:08 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	9:08 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	9:08 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	9:10 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	9:10 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	9:15 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	9:16 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	9:18 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	9:18 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	9:18 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	9:25 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
9/2/2024	10:22 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	10:23 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	10:26 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	10:27 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	10:39 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	10:40 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	10:42 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5	1.1	
9/2/2024	10:43 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5	1.1	
9/2/2024	10:44 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5	1.1	
9/2/2024	10:50 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
9/2/2024	10:55 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	10:56 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	10:57 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	11:06 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	11:07 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	11:12 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	11:13 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/2/2024	11:14 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
9/2/2024	11:15 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
9/2/2024	11:57 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5		0.48	
9/2/2024	10:25 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5		0.48	
9/3/2024	8:16 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.07	1.07	
9/3/2024	8:16 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5		0.75	
9/3/2024	8:37 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.25	1.36	
9/3/2024	8:53 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	1.42	1.3	
9/3/2024	9:05 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.30	1.20	
9/3/2024	9:19 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.30	1.30	
9/3/2024	9:31 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.20	1.20	
9/3/2024	9:51 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.15	1.11	
9/3/2024	10:01 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.11	1.11	
9/3/2024	10:20 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.20	1.15	
9/3/2024	10:33 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.30	1.15	
9/3/2024	10:50 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.25	1.25	
9/3/2024	11:34 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	TRUE	1.5	1.25	1.25
9/3/2024	2:23 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.2	1.2	
9/3/2024	2:45 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.15	1.2	
9/3/2024	2:58 PM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
9/3/2024	3:12 PM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.2	1.25	
9/3/2024	3:25 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.30	1.20	
9/3/2024	3:36 PM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.11	1.11	

9/3/2024	3:47 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.30	1.20	
9/3/2024	3:57 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.15	1.11	
9/3/2024	4:09 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.2	1.11	
9/3/2024	4:18 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.2	1.15	
9/3/2024	4:28 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.2	1.2	
9/3/2024	4:40 PM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1.07	1.11	
9/4/2024	8:30 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.5	1.5	
9/4/2024	8:40 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.2	1.2	
9/4/2024	8:50 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	TRUE	1.5	1.3	1.2
9/4/2024	9:00 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	TRUE	1.5	1.3	1.3
9/4/2024	9:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	TRUE	1.5	1.2	1.2
9/4/2024	9:25 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE				0.74
9/4/2024	9:35 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	TRUE	1.5	1.25	1.2
9/4/2024	9:45 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	TRUE	1.5	1.3	1.3
9/4/2024	9:55 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	TRUE	1.5	1.2	1.2
9/4/2024	10:05 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE				1.2
9/4/2024	10:10 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE				0.48
9/4/2024	10:20 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE				0.48
9/4/2024	10:35 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	TRUE	1.5	1.2	1.3
9/4/2024	10:45 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE		1.5	1.2	1.2
9/4/2024	10:50 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE		1.5	1.3	1.2
9/4/2024	11:00 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE		1.5	1.2	1
9/4/2024	11:10 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE		1.5	1.3	1.2
9/4/2024	11:15 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE		0.5		0.48
9/4/2024	11:20 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE		1.5	1.2	1.2
9/4/2024	11:30 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE		0.5		0.48
9/4/2024	11:30 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE			1.5	1.5
9/4/2024	2:00 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE		1.5	1.4	1.2
9/4/2024	7:20 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/4/2024	7:20 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/4/2024	7:25 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/4/2024	7:35 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE		2		0.44
9/4/2024	7:38 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE		2		2.08
9/4/2024	7:43 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE		2		2.00
9/4/2024	7:46 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE		2		1.40
9/4/2024	7:53 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE		0.5		0.48
9/4/2024	7:56 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE		0.5		0.48
9/4/2024	7:56 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE		0.5		0.48
9/4/2024	7:59 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE		2		2.3
9/4/2024	8:01 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE		2		4.7
9/4/2024	8:04 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE		2		4.8
9/4/2024	8:09 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE		2		4.1
9/4/2024	8:12 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE		2		2.1
9/4/2024	8:16 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE		2		4.2
9/4/2024	8:24 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE			0.08	1.2
9/4/2024	8:30 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE		1.6	1.2	0.96
9/4/2024	8:36 PM	Floor 01	119-16A Shower	2	TRUE				4
9/4/2024	8:40 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE			0.76	1.00
9/4/2024	8:50 PM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE		1.6		
9/4/2024	8:56 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE		1.6		
9/4/2024	8:59 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE		1.6		
9/4/2024	9:04 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE		1.6		
9/4/2024	9:08 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE		1.6		
9/4/2024	9:14 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE		1.6		
9/9/2024	12:14 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/9/2024	12:15 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/9/2024	12:18 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/9/2024	12:19 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/9/2024	12:20 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/9/2024	12:30 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/9/2024	12:31 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/9/2024	12:34 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/9/2024	12:35 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/9/2024	12:36 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/9/2024	12:42 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6	
9/9/2024	12:49 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/9/2024	12:50 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/9/2024	12:51 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/9/2024	12:59 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/9/2024	1:00 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/9/2024	1:09 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		1.88
9/9/2024	1:10 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		1.7
9/9/2024	1:12 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/9/2024	1:13 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48

9/9/2024	1:14 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	1:23 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
9/9/2024	1:29 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	1:30 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	1:31 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	1:39 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	1:40 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	1:45 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	1:46 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	1:49 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	1:50 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	1:51 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	2:00 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
9/9/2024	2:07 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	2:08 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	2:09 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	2:17 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	2:18 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	2:22 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		4.28		
9/9/2024	2:27 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	2:28 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	2:32 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	2:33 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	2:34 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	3:57 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	3:57 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	4:05 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
9/9/2024	4:15 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.4		
9/9/2024	4:18 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.5		
9/9/2024	4:55 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	4:55 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	4:59 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	5:02 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	5:02 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	5:04 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	5:04 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	5:04 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	5:08 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	70	1.8	
9/9/2024	5:08 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	70	1.7	
9/9/2024	8:09 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:09 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:09 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	11:10 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.11	1.07	
9/9/2024	8:04 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:08 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:17 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:18 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:21 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
9/9/2024	8:23 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			
9/9/2024	8:23 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			
9/9/2024	8:23 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			
9/9/2024	8:28 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:28 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	8:28 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:30 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:30 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:35 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:35 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:35 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	8:35 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:47 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:47 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	8:47 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:48 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:48 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:58 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:58 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	8:58 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	8:58 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	8:59 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	9:09 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	9:12 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	9:12 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	9:12 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48

9/9/2024	9:29 PM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6	
9/9/2024	10:17 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	10:18 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	10:22 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
9/9/2024	10:24 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	10:25 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.438
9/9/2024	10:32 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6	
9/9/2024	10:33 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	10:34 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	10:38 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	10:39 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	10:40 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	10:49 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	10:50 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	10:51 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	10:59 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	11:00 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	11:05 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	11:06 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	11:08 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/9/2024	11:09 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/9/2024	11:10 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/9/2024	11:18 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.7	
9/9/2024	10:23 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/10/2024	8:30 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	TRUE	1.5	1.2	1.2
9/10/2024	8:30 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE		1.5		24
9/10/2024	8:40 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	TRUE	1.5	1.2	1.2
9/10/2024	8:40 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	TRUE	1.5	1.2	1.2
9/10/2024	8:40 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	TRUE	1.5		0.23
9/10/2024	9:15 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	TRUE	1.5	1.2	1.3
9/10/2024	9:25 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	TRUE	1.5	1.3	1.3
9/10/2024	9:35 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	TRUE	1.5	1.2	1.2
9/10/2024	9:45 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE		1.5	1.3	1.3
9/10/2024	10:00 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE		1.5	1.2	1.2
9/10/2024	10:20 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE		1.5	1.2	1.2
9/10/2024	10:30 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE		1.5	1.3	1.2
9/10/2024	10:40 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE		1.5	1.2	1.2
9/10/2024	10:50 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE		1.5	1.3	1.3
9/10/2024	11:00 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE		1.5	1.2	1.2
9/10/2024	11:00 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE		1.5		0.46
9/10/2024	11:10 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE		1.5	1.2	1.2
9/10/2024	11:30 AM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE		1.5	1.3	1.3
9/10/2024	11:40 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE		1.5	1.3	1.3
9/10/2024	12:00 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE		1.5	1.2	1.2
9/10/2024	1:00 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	TRUE	1.5	1.4	1.4
9/10/2024	1:10 PM	Floor 05	540 Faucet (507-26)	2	TRUE	TRUE	1.5	1.2	1.2
9/10/2024	1:30 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	TRUE	1.5	1.2	1.2
9/10/2024	1:40 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	TRUE	1.5	1.2	1.2
9/10/2024	1:40 PM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE		1.5	1.2	1.2
9/10/2024	1:50 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE		1.5	1.2	1.2
9/10/2024	9:00 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	TRUE	1.5	1.2	1.3
9/11/2024	1:28 AM	Floor 01	119-02 Mailroom - Faucet	2	TRUE			0.75	1.0
9/11/2024	1:28 AM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE		1.6		
9/11/2024	1:28 AM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE		1.6		
9/11/2024	1:28 AM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE		1.6		
9/11/2024	1:28 AM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE		1.6		
9/11/2024	1:28 AM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE		1.6		
9/11/2024	1:28 AM	Floor 01	119-16A Shower	2	TRUE				0.13
9/11/2024	1:28 AM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE		1.6		
9/11/2024	1:28 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE		1.6	1.2	1.2
9/11/2024	1:28 AM	Floor 01	119-21 Faucet/Eyewash	2	TRUE			1.23	1.22
9/11/2024	8:30 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE		1.5	1.07	1.2
9/11/2024	8:58 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE		1.5	1.11	1.07
9/11/2024	9:10 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE		1.5	1.85	1.85
9/11/2024	9:37 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE		1.5	1.03	1.03
9/11/2024	9:37 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE		1.5		0.58
9/11/2024	10:21 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE		1.5	1.25	1.25
9/11/2024	10:33 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE		1.5	1.3	1.2
9/11/2024	10:52 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE		1.5	1.25	1.3
9/11/2024	11:02 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE		1.5	1.11	1.07
9/11/2024	11:45 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE			2.00	1.66
9/11/2024	1:14 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE		1.5	1.00	0.96
9/11/2024	1:30 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE		0.5		0.48
9/11/2024	1:45 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE		0.5		0.48

9/11/2024	2:00 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE		0.5			1.2
9/11/2024	2:10 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE		0.5			0.48
9/11/2024	2:20 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE		0.5			0.48
9/11/2024	2:43 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/11/2024	2:43 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE		0.5			0.48
9/11/2024	3:05 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE		1.5	1.11	1.11	
9/11/2024	3:40 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE		1.5	1.11	1.11	
9/11/2024	3:57 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE		1.5	1.15	1.11	
9/11/2024	4:05 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE		1.5	1.03	1.03	
9/11/2024	4:45 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE		1.5	1.2	1.25	
9/11/2024	4:57 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE		1.5	1.5	1.3	
9/11/2024	9:21v AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE		1.5	1.25	1.25	
9/16/2024	12:29 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	12:30 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	12:33 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	12:34 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5			0.48
9/16/2024	12:35 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	12:46 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	12:47 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	12:50 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	12:52 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	1:00 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			3.33
9/16/2024	1:00 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			2.00
9/16/2024	1:15 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	1:15 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5			0.48
9/16/2024	1:15 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	1:15 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE	TRUE		2.30		
9/16/2024	1:30 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	1:30 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5			0.48
9/16/2024	1:30 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	1:45 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	1:45 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:00 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:00 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:12 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:13 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:15 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:15 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:15 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:15 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE	TRUE		4.28		
9/16/2024	2:15 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:22 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:23 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:24 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:28 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE		1.5	1.0	1.0	
9/16/2024	2:29 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE		1.5	1.0	1.0	
9/16/2024	2:30 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:30 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:30 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:31 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE	TRUE		1.7		
9/16/2024	2:45 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:45 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:52 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:53 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:57 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	2:58 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	3:00 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE	TRUE		2.50		
9/16/2024	3:00 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	3:00 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	3:01 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	TRUE	0.5			0.48
9/16/2024	3:04 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE	TRUE		1.6		
9/16/2024	3:30 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	3:30 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5			0.48
9/16/2024	3:30 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	3:54 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE	TRUE		1.6		
9/16/2024	4:03 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	4:04 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	4:06 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	TRUE	0.5			0.48
9/16/2024	4:06 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
9/16/2024	11:00 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	TRUE	TRUE		1.7		
9/16/2024	5:50 PM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE		1.5	1.15	1.20	
9/16/2024	8:00 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
9/16/2024	8:00 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
9/16/2024	8:15 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48

9/16/2024	8:15 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/16/2024	8:15 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/16/2024	8:30 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/16/2024	8:30 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/16/2024	8:30 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE	TRUE		1.85	
9/16/2024	8:45 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/16/2024	8:45 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/16/2024	8:45 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/16/2024	9:00 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:00 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:00 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:15 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:15 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:30 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:30 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:30 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE	TRUE		2.30	
9/16/2024	9:44 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE	TRUE		1.6	
9/16/2024	9:45 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:45 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:45 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:48 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:49 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:50 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:51 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/16/2024	9:52 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:00 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:00 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:03 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/16/2024	10:04 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:06 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		1.00
9/16/2024	10:08 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		1.00
9/16/2024	10:09 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		1.00
9/16/2024	10:15 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:15 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:15 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:20 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:21 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:22 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:30 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:30 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:32 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:33 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:39 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:40 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/16/2024	10:42 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/16/2024	10:43 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/16/2024	10:45 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:45 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:45 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	10:45 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE	TRUE		2.30	
9/16/2024	11:00 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/16/2024	11:00 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/16/2024	11:00 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	11:04 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	TRUE	0.5		0.48
9/16/2024	11:15 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		1.20
9/16/2024	11:15 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/16/2024	12:51 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/17/2024	8:30 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	TRUE	1.5	1.25	1.3
9/17/2024	8:52 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	TRUE	1.5	1.42	1.36
9/17/2024	9:07 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE		1.5	1.20	1.15
9/17/2024	9:21 AM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE		1.5	1.03	1.03
9/17/2024	9:38 AM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	TRUE	1.5	1.2	1.25
9/17/2024	9:57 AM	Floor 05	540 Faucet (507-26)	2	TRUE	TRUE	1.5	1.03	1.03
9/17/2024	10:14 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	TRUE	1.5	1.11	1.2
9/17/2024	10:35 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE		1.5	1.15	1.11
9/17/2024	10:49 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	TRUE	1.5	1.20	1.20
9/17/2024	11:19 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	TRUE	1.5	1.20	1.20
9/17/2024	11:37 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	TRUE	1.5	1.15	1.20
9/17/2024	2:41 PM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE		1.5	1.20	1.20
9/17/2024	2:55 PM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE		1.5	1.36	1.30
9/17/2024	3:15 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	TRUE	1.5	1.30	1.30
9/17/2024	3:31 PM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	TRUE	1.5		0.48
9/17/2024	4:01 PM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE		1.5	1.30	1.25
9/17/2024	4:12 PM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE		1.5	1.36	1.36

9/17/2024	4:27 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE		1.5	1.15	1.20
9/17/2024	4:39 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	TRUE	1.5	1.30	1.11
9/17/2024	5:00 PM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE		1.5	1.11	1.11
9/17/2024	5:10 PM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	TRUE	1.5	1.11	1.11
9/17/2024	5:27 PM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE		1.5	1.20	1.25
9/17/2024	5:40 PM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE		1.5	1.25	1.2
9/18/2024	8:30 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	TRUE	1.5	1.4	1.4
9/18/2024	8:40 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	TRUE	1.5	1.3	1.3
9/18/2024	8:50 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	TRUE	1.5	1.3	1.3
9/18/2024	8:50 AM	Floor 01	119-02 Mailroom - Faucet	2	TRUE	TRUE		0.64	0.88
9/18/2024	9:00 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	TRUE	1.5	1.2	1.2
9/18/2024	9:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	TRUE	1.5	1.3	1.3
9/18/2024	9:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	TRUE	1.5		0.24
9/18/2024	9:20 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	TRUE	1.5	1.2	1.2
9/18/2024	9:30 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	TRUE	1.5	1.3	1.3
9/18/2024	9:30 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	TRUE	1.5	1.2	1.2
9/18/2024	9:40 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	TRUE	1.5	1.2	1.2
9/18/2024	11:00 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	TRUE	1.5	1.2	1.2
9/18/2024	11:10 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	TRUE	1.5	1.3	1.3
9/18/2024	11:20 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	TRUE	1.5	1.2	1.6
9/18/2024	11:30 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	TRUE	1.5	1.3	1.4
9/18/2024	12:15 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	TRUE	1.5	1.3	1.3
9/18/2024	3:00 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	TRUE	0.5		0.48
9/18/2024	3:30 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	TRUE	1.5	1.2	1.2
9/18/2024	3:40 PM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE	TRUE		1.2	1.2
9/18/2024	4:30 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	TRUE	1.5		
9/18/2024	7:30 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
9/18/2024	7:36 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
9/18/2024	7:38 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
9/18/2024	7:46 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE		2		1.00
9/18/2024	7:54 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE		2		4.08
9/18/2024	7:56 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE		2		1.80
9/18/2024	7:59 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	TRUE	2		2.20
9/18/2024	8:18 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	TRUE	0.5		0.48
9/18/2024	8:20 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	TRUE	0.5		0.48
9/18/2024	8:20 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	TRUE	0.5		0.48
9/18/2024	8:24 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE		2		4.4
9/18/2024	8:28 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE		2		2
9/18/2024	8:30 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE		2		4.1
9/18/2024	8:32 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE		2		4.2
9/18/2024	8:34 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE		2		4.9
9/18/2024	8:36 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE		2		4.3
9/18/2024	9:00 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	TRUE	1.6	0.72	0.76
9/18/2024	9:08 PM	Floor 01	119-16A Shower	2	TRUE				4.4
9/18/2024	9:22 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE	TRUE		0.68	0.72
9/18/2024	9:50 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	TRUE	0.5		1.3
9/18/2024	9:55 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	TRUE	0.5		0.48
9/18/2024	10:11 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	TRUE	0.5		0.48
9/18/2024	3:15 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	TRUE	0.5		0.48
9/23/2024	12:21 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	12:22 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	12:23 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	12:31 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		1.1
9/23/2024	12:32 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	12:38 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		2.0
9/23/2024	12:39 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		2.1
9/23/2024	12:41 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	12:43 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	12:44 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	12:52 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6	
9/23/2024	12:58 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	12:59 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	1:00 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		4.8
9/23/2024	1:10 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	1:16 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	1:17 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	1:19 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	1:20 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	1:21 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	1:30 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE			1.5	
9/23/2024	1:36 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	1:37 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	1:38 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	1:47 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48

9/23/2024	1:48 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	2:00 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	2:01 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	2:02 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	2:03 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	2:04 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
9/23/2024	2:04 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	3:14 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	3:14 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	3:15 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	3:29 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
9/23/2024	3:39 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	3:39 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	3:39 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	3:39 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	3:39 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	3:44 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	3:44 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	3:52 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	0.7	1.18	
9/23/2024	3:52 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	0.68	1.19	
9/23/2024	4:03 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.9		
9/23/2024	4:05 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
9/23/2024	4:07 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.7		
9/23/2024	11:05 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.3	1.3	
9/23/2024	7:35 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	7:35 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	7:59 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	7:59 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	7:59 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	8:17 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	8:18 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	8:20 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	8:20 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	8:20 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	8:32 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
9/23/2024	8:56 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	8:56 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	8:56 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	8:56 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	8:56 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:02 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:15 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:15 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	9:15 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:18 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:18 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:28 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:28 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:29 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:30 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:30 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:30 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	9:30 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:33 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	9:33 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:34 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:35 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:40 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:42 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:43 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:50 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:51 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	9:55 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	9:56 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	9:57 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	10:03 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
9/23/2024	10:08 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	10:09 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/23/2024	10:10 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	10:19 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	10:22 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
9/23/2024	10:26 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/23/2024	10:27 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/23/2024	10:29 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48

9/23/2024	10:30 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	10:31 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	10:48 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	10:49 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	10:52 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	10:53 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	10:54 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	11:04 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	11:05 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	11:09 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	11:10 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	11:11 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	11:17 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6	
9/23/2024	1:11 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/23/2024	10:18 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	10:41 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6	
9/23/2024	9:06 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/23/2024	9:06 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/23/2024	9:06 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/24/2024	8:30 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	TRUE	1.5	1.3	1.3
9/24/2024	8:35 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	TRUE	1.5	0.32	0.32
9/24/2024	8:40 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	TRUE	1.5	1.3	1.3
9/24/2024	8:45 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	TRUE	1.5		0.24
9/24/2024	9:00 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE		1.5	1.2	1.2
9/24/2024	9:10 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE		1.5	1.3	1.3
9/24/2024	9:20 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE		1.5	1.3	1.3
9/24/2024	9:30 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE		1.5	1.3	1.3
9/24/2024	9:40 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE		1.5	1.3	1.3
9/24/2024	9:50 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE		1.5	1.2	1.2
9/24/2024	10:05 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE		1.5	1.3	1.3
9/24/2024	10:15 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE		1.5	1.3	1.3
9/24/2024	10:25 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE		1.5	1.2	1.2
9/24/2024	10:25 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE		1.5	1.2	1.2
9/24/2024	10:35 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE		1.5	1.2	1.2
9/24/2024	10:45 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE		1.5	1.2	1.2
9/24/2024	10:55 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE		1.5	1.2	1.2
9/24/2024	11:15 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE		1.5	1.2	1.2
9/24/2024	11:25 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE		1.5		0.48
9/24/2024	1:00 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE		1.5	1.3	1.3
9/24/2024	1:10 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE		1.5	1.3	1.3
9/24/2024	1:20 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE		1.5	1.4	1.4
9/24/2024	1:30 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE		1.5	1.2	1.2
9/24/2024	1:40 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE		1.5	1.3	1.3
9/24/2024	1:50 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE		1.5	1.2	1.2
9/24/2024	2:00 PM	Floor 05	540 Faucet (507-26)	2	TRUE		1.5	1.2	1.2
9/25/2024	12:43 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE		0.5		0.48
9/25/2024	12:44 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE		0.5		0.48
9/25/2024	12:45 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE		0.5		0.48
9/25/2024	12:49 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE		2		1.4
9/25/2024	12:50 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE		2		1.4
9/25/2024	12:51 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE		2		1.4
9/25/2024	12:52 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE		2		1.4
9/25/2024	1:02 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE		0.5		0.48
9/25/2024	1:03 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE		0.5		0.48
9/25/2024	1:04 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE		0.5		0.48
9/25/2024	1:08 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE		2		1.47
9/25/2024	1:09 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE		2		1.4
9/25/2024	1:10 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE		2		1.4
9/25/2024	1:11 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE		2		1.4
9/25/2024	1:13 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE		2		1.4
9/25/2024	2:09 AM	Floor 01	119-02 Mailroom - Faucet	2	TRUE			2.1	2.1
9/25/2024	2:09 AM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	TRUE	1.6		
9/25/2024	2:13 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE		1.6	2.1	2.1
9/25/2024	2:21 AM	Floor 01	119-16A Shower	2	TRUE				0.9
9/25/2024	2:31 AM	Floor 01	119-21 Faucet/Eyewash	2	TRUE			2	2
9/25/2024	2:34 AM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	TRUE	1.6		
9/25/2024	2:35 AM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	TRUE	1.6		
9/25/2024	8:26 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE		1.5	1.66	1.76
9/25/2024	8:38 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE		1.5	1.25	1.2
9/25/2024	8:50 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE		1.5	1.07	1.07
9/25/2024	9:04 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE		1.5	1.2	1.2
9/25/2024	9:16 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE		1.5	1.07	1.03
9/25/2024	9:16 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE		1.5		0.63
9/25/2024	9:30 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE		1.5	1.25	1.25

9/25/2024	9:45 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.3	1.25	
9/25/2024	10:00 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.3	1.3	
9/25/2024	10:13 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.07	1.11	
9/25/2024	11:00 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2.3	1.62	
9/25/2024	11:15 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.11	1.03	
9/25/2024	11:30 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
9/25/2024	11:43 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.2
9/25/2024	11:55 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
9/25/2024	12:10 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
9/25/2024	3:21 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.2	1.15	
9/25/2024	3:32 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.15	1.11	
9/25/2024	3:43 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.11	1.11	
9/25/2024	3:55 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.11	1.07	
9/25/2024	4:09 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.25	1.2	
9/25/2024	4:21 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	2.3	1.85	
9/25/2024	5:15 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
9/25/2024	1:12 M	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			1.4
9/30/2024	12:29 AM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
9/30/2024	12:58 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	12:59 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	1:01 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	1:02 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	1:03 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	1:14 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	1:15 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	1:17 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	1:18 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	1:19 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	1:27 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	TRUE				
9/30/2024	1:35 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.8		
9/30/2024	1:44 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	1:45 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	1:46 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	1:54 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	1:55 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	1:56 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	2:00 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.0	1.0	
9/30/2024	2:01 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	1.0	1.0	
9/30/2024	2:08 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE	TRUE	1.9		
9/30/2024	2:11 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
9/30/2024	2:21 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	2:22 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	2:29 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	2:36 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
9/30/2024	2:42 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	2:43 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	2:47 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	2:49 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	4:14 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	4:14 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	4:28 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	4:28 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	4:28 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	4:37 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	4:37 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	4:43 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	4:44 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	4:44 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	4:51 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		2.1		
9/30/2024	7:48 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	7:48 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	7:48 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	7:54 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	7:54 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	7:54 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	7:58 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	8:01 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	8:01 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	8:02 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	8:07 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		2.0		
9/30/2024	8:14 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
9/30/2024	8:14 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
9/30/2024	8:14 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
9/30/2024	8:18 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48

9/30/2024	8:18 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	8:25 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	8:29 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	8:29 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	8:29 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
9/30/2024	8:29 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	8:31 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8	
9/30/2024	8:33 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	8:33 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	8:34 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
9/30/2024	8:36 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	8:36 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	8:39 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	8:39 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	8:42 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
9/30/2024	8:42 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	8:42 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	8:49 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8	
9/30/2024	9:18 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	9:18 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	9:25 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	9:25 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
9/30/2024	9:25 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	9:38 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	9:40 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	9:43 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	9:43 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
9/30/2024	9:43 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
9/30/2024	9:46 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8	
9/30/2024	9:49 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
9/30/2024	9:49 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
9/30/2024	9:49 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48

Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 09/01/2024 to 09/30/2024

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
---------------------	---------------------	--------------------------------

All filters were inspected

Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Report
From 10/01/2024 to 10/31/2024

Definitions

Filter(s) Inspected: When the box is checked, the filter was inspected for active leaks, evidence of leaks, and any defects cracks in filter casing
Filter(s) Replaced: When the box is checked, a filter was replaced at this location on the date in the first column.

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
10/1/2024	8:11 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE		1.5	1.25	1.2	
10/1/2024	8:33 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE		1.5	1.3	1.3	
10/1/2024	8:33 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE		1.5		0.78	
10/1/2024	9:09 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	TRUE	1.5	1.36	1.36	
10/1/2024	9:30 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE		1.5	1.2	1.15	
10/1/2024	9:44 AM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE		1.5	1.25	1.2	
10/1/2024	9:55 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE		1.5	1.2	1.15	
10/1/2024	10:12 AM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE		1.5	1.2	1.2	
10/1/2024	10:25 AM	Floor 05	540 Faucet (507-26)	2	TRUE		1.5	1.15	1.11	
10/1/2024	10:31 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE		1.5	1.2	1.2	
10/1/2024	10:45 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE		1.5	1.07	1.15	
10/1/2024	10:56 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE		1.5	1.15	1.2	
10/1/2024	11:08 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE		1.5	1.15	1.15	
10/1/2024	2:34 PM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	TRUE	1.5	1.2	1.2	
10/1/2024	3:00 PM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE		1.5	1.07	1.11	
10/1/2024	3:15 PM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE		1.5	1.2	1.2	
10/1/2024	3:30 PM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE		1.5	1.25	1.25	
10/1/2024	3:45 PM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE		1.5	1.25	1.25	
10/1/2024	4:00 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE		1.5	1.25	1.2	
10/1/2024	4:15 PM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE		1.5			0.48
10/1/2024	4:30 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE		1.5	1.15	1.15	
10/1/2024	4:45 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE		1.5	1.3	1.25	
10/1/2024	5:00 PM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE		1.5	1.3	1.3	
10/1/2024	5:15 PM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE		1.5	1.15	1.2	
10/1/2024	5:30 PM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE		1.5	1.2	1.2	
10/2/2024	8:10 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE		1.5	1.15	1.2	
10/2/2024	8:46 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE		1.5	1.07	1.03	
10/2/2024	9:01 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE		1.5	1.03	1.03	
10/2/2024	9:01 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE		1.5		0.61	
10/2/2024	9:27 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE		1.5	1.25	1.15	
10/2/2024	9:38 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE		1.5	1.87	1.66	
10/2/2024	10:40 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE		1.5	1.25	1.25	
10/2/2024	11:00 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE		1.5	1.3	1.36	
10/2/2024	11:25 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE		1.5	1.3	1.2	
10/2/2024	11:48 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE		1.5	1.2	1.1	
10/2/2024	2:10 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE		0.5			0.48
10/2/2024	2:30 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE		0.5			1.1
10/2/2024	2:51 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE		0.5			0.48
10/2/2024	3:12 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE		1.5	1.11	1.11	
10/2/2024	3:25 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE		1.5	1.11	1.15	
10/2/2024	3:36 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE		1.5	1.11	1.07	
10/2/2024	3:48 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE		1.5	1.15	1.07	
10/2/2024	3:59 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE		1.5	1.2	1.3	
10/2/2024	4:11 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	TRUE	1.5	2.00	0.90	
10/2/2024	4:45 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE		0.5			0.48
10/2/2024	4:45 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE		0.5			0.48
10/2/2024	5:00 PM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE			2.30	1.76	
10/2/2024	5:15 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE		1.5	1.03	1.00	
10/2/2024	8:08 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE		0.5			0.48
10/2/2024	8:10 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE		0.5			0.48
10/2/2024	8:10 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE		0.5			0.48
10/2/2024	8:18 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE		2			1.6
10/2/2024	8:27 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE		2			2.3
10/2/2024	8:30 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE		2			2.1
10/2/2024	8:34 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE		0.5			0.48
10/2/2024	8:34 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE		0.5			0.48
10/2/2024	8:39 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE		2			4.4
10/2/2024	8:42 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE		2			1
10/2/2024	8:44 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE		2			2.1
10/2/2024	8:46 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE		2			1.6
10/2/2024	8:48 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE		2			4.3
10/2/2024	8:50 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE		2			4.6
10/2/2024	8:59 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE			0.72	0.81	
10/2/2024	9:02 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE			0.68	0.68	

10/2/2024	9:05 PM	Floor 01	119-16A Shower	2	TRUE				0.48
10/2/2024	9:12 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	0.08	0.76	
10/2/2024	9:18 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
10/2/2024	9:22 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
10/2/2024	9:27 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
10/2/2024	11:44 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			2.2
10/2/2024	11:33 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
10/7/2024	12:11 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	12:12 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	12:24 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1.4
10/7/2024	12:25 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	12:31 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	12:32 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	12:34 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	12:35 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	12:36 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	12:49 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.9		
10/7/2024	12:56 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	12:57 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	12:58 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	1:06 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	1:07 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	1:15 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	1:16 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	1:18 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	1:19 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	1:20 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	1:27 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.9		
10/7/2024	1:36 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	1:37 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	1:38 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	1:46 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	1:47 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	1:55 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.8		
10/7/2024	1:58 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	1:59 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	2:01 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	2:02 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	2:03 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	2:35 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	2:35 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	2:36 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	2:36 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	2:44 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.8		
10/7/2024	2:51 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
10/7/2024	2:56 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	2:58 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	2:58 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	3:14 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	3:16 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	3:16 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	3:19 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.9		
10/7/2024	3:27 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	0.71	1.14	
10/7/2024	3:28 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	0.73	1.13	
10/7/2024	11:15 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.1	1.1	
10/7/2024	12:10 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	7:20 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/7/2024	7:36 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	7:36 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	7:36 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	7:36 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	7:46 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	7:48 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	7:48 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	7:51 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8		
10/7/2024	7:58 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	7:58 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	7:58 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:03 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:03 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	8:03 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:07 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:14 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:18 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48

10/7/2024	8:18 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	8:19 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:23 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:24 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:24 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	8:26 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:26 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:30 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:31 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:34 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:34 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	8:34 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:40 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:40 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:41 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:41 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:45 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	8:45 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:46 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:46 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:47 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:54 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	8:55 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:55 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	8:56 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	8:56 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	9:04 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		2.3		
10/7/2024	9:14 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	9:15 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	9:16 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	9:25 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	9:26 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	9:31 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	9:32 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	9:37 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	9:38 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	9:39 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	9:49 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		2.1		
10/7/2024	9:50 PM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		10		
10/7/2024	9:53 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	9:54 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	9:58 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	9:59 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	10:00 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	10:10 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	10:11 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	10:15 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/7/2024	10:16 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/7/2024	10:17 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/7/2024	10:25 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		2.0		
10/7/2024	8:0/8 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/8/2024	8:13 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.1	1.1	
10/8/2024	8:15 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5	1.1	1.5	
10/8/2024	8:30 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.3	1.3	
10/8/2024	8:30 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5		0.81	
10/8/2024	8:31 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	1.3	1.3	
10/8/2024	9:00 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.3	1.3	
10/8/2024	9:15 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.3	1.3	
10/8/2024	9:31 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.5	1.5	
10/8/2024	9:50 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.3	1.3	
10/8/2024	10:05 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.1	1.1	
10/8/2024	10:18 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.1	1.1	
10/8/2024	10:33 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.2	1.2	
10/8/2024	10:44 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.3	1.3	
10/8/2024	10:54 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.3	1.3	
10/8/2024	11:30 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.3	1.3	
10/8/2024	11:40 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	TRUE	1.5		0.48
10/8/2024	11:51 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.1	1.1	
10/8/2024	12:06 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.4	1.4	
10/8/2024	1:00 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.1	1.1	
10/8/2024	1:10 PM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.3	1.3	
10/8/2024	1:10 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.2	1.2	
10/8/2024	1:13 PM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1	1	
10/8/2024	1:24 PM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1.1	1.1	

10/8/2024	1:25 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.2	1.2	
10/8/2024	1:35 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.2	1.2	
10/8/2024	1:35 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.3	1.3	
10/8/2024	1:55 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.2	1.2	
10/9/2024	12:00 AM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE	1.6			
10/9/2024	12:05 AM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6			
10/9/2024	12:06 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	1.6	1.6	
10/9/2024	12:06 AM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1.6	1.6	
10/9/2024	12:07 AM	Floor 01	119-16A Shower	2	TRUE				0.96
10/9/2024	1:58 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/9/2024	1:59 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/9/2024	2:00 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/9/2024	2:07 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			2.7
10/9/2024	2:08 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			2.6
10/9/2024	2:09 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			2.7
10/9/2024	2:10 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			2.7
10/9/2024	2:14 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
10/9/2024	2:15 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
10/9/2024	2:16 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
10/9/2024	2:27 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			2.6
10/9/2024	2:28 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			2.6
10/9/2024	2:29 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			2.7
10/9/2024	2:30 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			2.6
10/9/2024	2:31 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			2.7
10/9/2024	2:32 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			2.6
10/9/2024	8:10 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1.1	1.1	
10/9/2024	8:25 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.2	1.2	
10/9/2024	8:43 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.0	1.0	
10/9/2024	8:58 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.0	1.0	
10/9/2024	9:02 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5			0.6
10/9/2024	9:32 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	TRUE	1.5	1.25	1.25
10/9/2024	9:48 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.2	1.2	
10/9/2024	10:12 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.3	1.3	
10/9/2024	10:46 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.1	1.1	
10/9/2024	11:11 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/9/2024	11:20 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/9/2024	11:30 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/9/2024	11:40 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/9/2024	11:52 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/9/2024	1:18 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			0.48
10/9/2024	1:31 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
10/9/2024	1:40 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
10/9/2024	1:45 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.5	1.5	
10/9/2024	2:06 PM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.3	1.3	
10/9/2024	5:00 PM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2.30	1.66	
10/9/2024	5:15 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.03	1.00	
10/9/2024	5:30 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/9/2024	5:45 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/9/2024	11:51 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		1.6	1.6	
10/9/2024	11:52 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6			
10/9/2024	11:53 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
10/9/2024	11:54 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
10/9/2024	11:58 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
10/9/2024	11:59 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
10/14/2024	12:26 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	12:27 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	12:29 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	12:30 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	12:31 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	12:41 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	12:42 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	12:45 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	12:46 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	12:47 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	2:23 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	2:24 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	2:25 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	2:30 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	2:31 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	2:32 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	2:39 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
10/14/2024	2:42 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.4	1.4	
10/14/2024	2:44 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	1.4	1.4	
10/14/2024	3:02 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48

10/14/2024	3:03 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	3:12 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	3:13 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	3:20 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
10/14/2024	3:22 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.6		
10/14/2024	4:00 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	4:01 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	4:01 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
10/14/2024	4:08 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	4:08 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	4:11 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	4:11 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	4:12 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	4:16 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	4:17 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	4:30 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	4:32 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	4:32 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	4:38 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	4:40 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	4:54 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
10/14/2024	11:40 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.1	1.1	
10/14/2024	7:12 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	7:14 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	7:14 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	7:21 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	7:22 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	7:34 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	7:35 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	7:37 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	7:37 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	7:38 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	7:39 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8		
10/14/2024	7:43 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	7:44 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	7:44 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	7:48 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	7:48 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	7:54 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	7:55 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	7:57 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	7:57 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	7:57 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:00 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		0.48		
10/14/2024	8:05 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:06 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	8:06 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:10 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:10 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:14 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:16 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:19 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	8:19 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:19 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:20 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
10/14/2024	8:24 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:25 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:25 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	8:31 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:31 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:39 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:39 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:42 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:42 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	8:42 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:48 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8		
10/14/2024	8:51 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:51 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	8:51 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	8:54 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	8:54 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	9:00 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	9:02 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	9:06 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48

10/14/2024	9:06 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	9:06 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	9:12 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.8		
10/14/2024	10:22 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	10:23 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	10:26 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	10:27 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	10:28 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	10:41 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	10:42 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	10:44 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.9
10/14/2024	10:45 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		3.3
10/14/2024	10:46 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.6
10/14/2024	10:54 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
10/14/2024	10:59 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	11:00 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	11:01 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	11:10 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	11:11 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	11:21 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	11:23 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/14/2024	11:24 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/14/2024	11:25 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/14/2024	11:54 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/15/2024	8:30 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.2	1.2	
10/15/2024	8:40 AM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.3	1.3	
10/15/2024	8:45 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.25	1.25	
10/15/2024	8:50 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.2	1.2	
10/15/2024	9:00 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.3	1.3	
10/15/2024	9:09 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.3	1.3	
10/15/2024	9:10 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.3	1.3	
10/15/2024	9:25 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.2	1.2	
10/15/2024	9:35 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.2	1.2	
10/15/2024	9:40 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.4	1.4	
10/15/2024	10:30 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.2	1.2	
10/15/2024	10:30 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5		0.83	
10/15/2024	10:48 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.1	1.1	
10/15/2024	11:00 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.1	1.1	
10/15/2024	11:05 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.2	1.2	
10/15/2024	11:10 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.0	1.0	
10/15/2024	11:22 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.3	1.3	
10/15/2024	11:36 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
10/15/2024	1:35 PM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.2	1.2	
10/15/2024	1:48 PM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	1.5	1.42	
10/15/2024	2:12 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.25	1.3	
10/15/2024	2:23 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.15	1.15	
10/15/2024	4:15 PM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.25	1.25	
10/15/2024	4:31 PM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	TRUE	1.5	1.20	1.20
10/16/2024	12:00 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/16/2024	12:00 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/16/2024	12:00 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/16/2024	12:00 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.1	1.1	
10/16/2024	2:15 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.2	1.2	
10/16/2024	2:50 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/16/2024	3:00 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		1.6	1.6	
10/16/2024	8:28 AM	Floor 01	119-16A Shower	2	TRUE				5.2
10/16/2024	9:45 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.4	1.4	
10/16/2024	9:55 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1.3	1.3	
10/16/2024	10:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.2	1.2	
10/16/2024	10:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5		0.5	
10/16/2024	10:20 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.3	1.3	
10/16/2024	10:30 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.3	1.3	
10/16/2024	10:45 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.3	1.3	
10/16/2024	11:35 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.3	1.3	
10/16/2024	1:00 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	2.0	1.0	
10/16/2024	2:30 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/16/2024	3:20 PM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.2	1.2	
10/16/2024	7:11 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/16/2024	7:12 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/16/2024	7:12 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/16/2024	7:15 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			2.3
10/16/2024	7:17 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			2.3
10/16/2024	7:20 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			2.8
10/16/2024	7:23 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			2.0

10/16/2024	7:29 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
10/16/2024	7:30 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
10/16/2024	7:30 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
10/16/2024	7:38 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			4.4
10/16/2024	7:40 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			4.6
10/16/2024	7:42 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			4.2
10/16/2024	7:44 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			4.0
10/16/2024	7:50 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			4.1
10/16/2024	7:53 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			4.2
10/16/2024	8:07 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		0.72	0.68	
10/16/2024	8:16 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	0.84	0.92	
10/16/2024	8:16 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		0.15	0.15	
10/16/2024	8:35 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
10/16/2024	8:38 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
10/16/2024	11:00 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.3
10/16/2024	11:10 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
10/16/2024	11:20 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
10/21/2024	12:02 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	12:03 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	12:04 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	12:12 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	12:13 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	12:17 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	12:18 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	12:19 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	12:25 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
10/21/2024	12:28 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	12:29 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	12:30 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	12:38 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1.3
10/21/2024	12:39 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	12:44 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		3.5
10/21/2024	12:45 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			3.4
10/21/2024	12:47 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	12:48 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	12:49 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	12:58 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
10/21/2024	1:10 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	1:11 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	1:12 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	1:20 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	1:21 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	1:26 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	1:27 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	1:29 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	1:30 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	1:31 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	1:39 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
10/21/2024	1:45 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	1:46 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	1:47 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	1:55 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	1:56 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	2:01 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.5		
10/21/2024	2:07 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	2:08 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	2:10 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	2:11 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	2:12 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	2:28 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	2:28 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	2:34 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.8		
10/21/2024	2:44 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	2:48 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	2:50 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
10/21/2024	2:56 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
10/21/2024	3:10 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	3:12 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	3:12 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	3:17 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	3:18 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	3:18 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	3:28 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	68	116	
10/21/2024	3:28 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	69	114	

10/21/2024	11:22 AM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/21/2024	11:30 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.1	1.1	
10/21/2024	8:00 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	8:02 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	8:02 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	8:11 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	8:11 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	8:22 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	8:26 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	8:29 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	8:29 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	8:29 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	8:43 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
10/21/2024	9:05 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:05 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:06 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:06 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	9:06 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:10 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:14 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:14 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	9:14 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:22 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:24 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:24 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	9:26 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:26 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:30 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:31 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:33 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:33 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	9:33 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:50 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:52 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	9:53 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:53 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	9:56 PM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.9		
10/21/2024	10:18 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	10:19 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	10:21 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	10:23 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	10:25 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	10:31 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	10:32 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	10:36 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	10:37 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	10:38 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	10:45 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
10/21/2024	10:49 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	10:50 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	10:51 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	11:00 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	11:01 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	11:05 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	11:06 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	11:08 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/21/2024	11:09 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/21/2024	11:10 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	11:17 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
10/21/2024	11:57 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/21/2024	11:58 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/22/2024	7:15 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.0	1.0	
10/22/2024	7:25 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.25	1.25	
10/22/2024	7:35 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.2	1.2	
10/22/2024	7:45 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.2	1.2	
10/22/2024	8:30 AM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.2	1.2	
10/22/2024	9:00 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.3	1.3	
10/22/2024	9:00 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5			0.7
10/22/2024	9:00 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.2	1.2	
10/22/2024	9:10 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.2	1.2	
10/22/2024	9:21 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.5	1.5	
10/22/2024	9:21 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	TRUE	1.5		0.7
10/22/2024	9:25 AM	Floor 05	Suite. 540 Kitchenette - Faucet	2	TRUE	1.5	1.2	1.2	
10/22/2024	9:30 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.2	1.2	

10/22/2024	9:45 AM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1.2	1.2	
10/22/2024	9:50 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	1.4	1.4	
10/22/2024	10:05 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.2	1.25	
10/22/2024	10:30 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.5	1.5	
10/22/2024	10:50 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.2	1.2	
10/22/2024	11:08 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.5	1.5	
10/22/2024	11:45 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.2	1.2	
10/22/2024	12:00 PM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
10/22/2024	1:00 PM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.25	1.25	
10/22/2024	1:10 PM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.1	1.1	
10/22/2024	1:22 PM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.25	1.25	
10/22/2024	1:39 PM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.0	1.0	
10/22/2024	1:50 PM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.0	1.0	
10/22/2024	2:05 PM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.00	1.00	
10/22/2024	2:20 PM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.0	1.0	
10/23/2024	12:40 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/23/2024	12:41 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/23/2024	12:42 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/23/2024	12:50 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			1.0
10/23/2024	12:51 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			1.0
10/23/2024	12:52 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			1.1
10/23/2024	12:53 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			1.0
10/23/2024	12:59 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
10/23/2024	1:00 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
10/23/2024	1:09 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			1.0
10/23/2024	1:10 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
10/23/2024	1:10 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			1.0
10/23/2024	1:11 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			1.0
10/23/2024	1:12 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			1.0
10/23/2024	1:13 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			1.1
10/23/2024	1:14 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			1.0
10/23/2024	10:27 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.0	1.0	
10/23/2024	10:40 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.0	1.0	
10/23/2024	11:07 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.8	1.6	
10/23/2024	11:16 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1.25	1.11	
10/23/2024	1:30 PM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2.8	1.6	
10/23/2024	1:43 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.0	1.0	
10/23/2024	1:50 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/23/2024	2:00 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.25
10/23/2024	2:00 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
10/23/2024	2:10 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
10/23/2024	2:10 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
10/23/2024	3:49 PM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	0.93	1.0	
10/23/2024	3:49 PM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5			0.61
10/23/2024	4:23 PM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.15	1.2	
10/23/2024	4:43 PM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.03	1.07	
10/23/2024	5:00 PM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.07	1.07	
10/23/2024	5:13 PM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.3	1.3	
10/23/2024	5:29 PM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.3	1.25	
10/23/2024	5:43 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.25	1.25	
10/23/2024	5:58 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	2.3	1.2	
10/23/2024	6:22 PM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	1.5	1.25	1.25	
10/23/2024	6:30 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.11	1.15	
10/23/2024	6:40 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.11	1.11	
10/23/2024	10:06 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		2.1	2.1	
10/23/2024	10:06 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6			
10/23/2024	10:06 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
10/23/2024	10:06 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
10/23/2024	10:06 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
10/23/2024	10:06 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
10/23/2024	10:06 PM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE	1.6			
10/23/2024	10:06 PM	Floor 01	119-16A Shower	2	TRUE				1
10/23/2024	10:06 PM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6	2.0	2.0	
10/23/2024	10:06 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	2.1	2.1	
10/23/2024	10:06 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		2.1	2.1	
10/28/2024	12:59 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	1:00 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	1:02 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	1:03 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	1:04 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	1:14 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	1:15 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	1:18 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	1:19 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48

10/28/2024	1:20 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	1:48 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	1:49 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	1:50 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	1:59 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	2:00 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	2:01 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	2:04 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.9	1.9	
10/28/2024	2:05 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	TRUE	1.5	2.0	2.0
10/28/2024	2:22 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
10/28/2024	2:24 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	2:24 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	2:31 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	2:32 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	2:38 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	2:38 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	2:39 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	2:43 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	2:47 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	2:47 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
10/28/2024	2:50 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.7		
10/28/2024	2:54 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	2:54 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	2:54 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	3:00 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
10/28/2024	3:29 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.1		
10/28/2024	3:44 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	3:45 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	3:46 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	3:47 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	3:37 PM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	TRUE	1.5	1.15	1.15
10/28/2024	7:00 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	7:01 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	7:01 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	7:05 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	7:09 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	7:20 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	7:23 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	7:28 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	7:28 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	7:29 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	7:32 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8		
10/28/2024	7:38 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	7:38 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	7:38 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	7:42 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	7:42 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	7:54 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	7:56 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	7:58 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	7:58 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	7:58 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	8:02 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.9		
10/28/2024	8:10 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	8:10 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	8:10 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	8:12 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	8:13 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	8:21 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	8:21 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	8:25 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	8:25 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	8:25 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	8:28 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.9		
10/28/2024	8:35 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	8:35 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	8:35 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	8:38 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	8:38 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	8:48 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/28/2024	8:49 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	8:52 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/28/2024	8:52 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/28/2024	8:52 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48

10/28/2024	8:58 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		0.17	
10/28/2024	9:04 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	9:05 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	9:05 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
10/28/2024	9:08 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	9:08 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	9:20 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	9:20 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	9:24 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	9:24 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
10/28/2024	9:24 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	9:32 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7	
10/28/2024	9:34 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	10:06 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.5	
10/28/2024	10:10 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	10:11 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	10:12 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	10:13 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
10/28/2024	10:14 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	10:28 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	10:29 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	10:33 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.85
10/28/2024	10:34 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5	2.2
10/28/2024	10:35 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5	2.0
10/28/2024	10:46 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	10:47 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
10/28/2024	10:48 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	10:56 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	10:57 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	11:08 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	11:09 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
10/28/2024	11:10 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
10/28/2024	11:11 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
10/28/2024	11:27 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5		0.48
10/28/2024	:34 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
10/29/2024	1:37 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.2	1.5
10/29/2024	7:51 AM	Floor 05	Suite. 540 Kitchenette - Faucet	2	TRUE	1.5	1.0	1.0
10/29/2024	7:51 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.0	1.0
10/29/2024	8:12 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.25	1.25
10/29/2024	8:24 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.25	1.25
10/29/2024	8:40 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.0	1.0
10/29/2024	9:10 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.2	1.2
10/29/2024	9:37 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.2	1.2
10/29/2024	9:37 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	0.75	0.78
10/29/2024	9:50 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.25	1.25
10/29/2024	9:50 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5	1.0	0.78
10/29/2024	10:00 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.3	1.3
10/29/2024	10:20 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.2	1.2
10/29/2024	10:28 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.3	1.3
10/29/2024	10:40 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.2	1.2
10/29/2024	10:55 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.0	1.0
10/29/2024	11:07 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.3	1.3
10/29/2024	11:30 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.2	1.2
10/29/2024	11:40 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.2	1.5
10/29/2024	11:55 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.2	1.5
10/29/2024	1:30 PM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1.1	1.1
10/29/2024	1:41 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	0.9	0.9
10/29/2024	2:00 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5		1.0
10/29/2024	2:30 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.3	1.3
10/29/2024	2:40 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.2	1.2
10/29/2024	3:21 PM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	1.3	1.36
10/29/2024	3:37 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.2	1.2
10/29/2024	3:40 PM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5		0.48
10/30/2024	8:05 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		1.5	1.5
10/30/2024	8:11 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.2	1.2
10/30/2024	8:30 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.2	1.22
10/30/2024	8:30 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.3	1.3
10/30/2024	8:30 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1	1
10/30/2024	8:30 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.0	1.0
10/30/2024	8:30 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5		0.48
10/30/2024	8:30 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5		0.48
10/30/2024	9:00 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5		0.48
10/30/2024	9:21 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5		0.48
10/30/2024	9:21 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5		0.48

10/30/2024	9:50 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.25	1.25	
10/30/2024	11:20 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.3	1.3	
10/30/2024	11:30 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.25	1.25	
10/30/2024	11:40 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	1.5	1.2	1.2	
10/30/2024	11:51 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.0	1.6	
10/30/2024	11:54 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5		1.6	
10/30/2024	1:00 PM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1.25	1.25	
10/30/2024	1:16 PM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.1	1.1	
10/30/2024	1:35 PM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.3	1.3	
10/30/2024	1:45 PM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.7	1.7	
10/30/2024	1:55 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.2	1.2	
10/30/2024	2:30 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.2	1.2	
10/30/2024	7:18 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
10/30/2024	7:18 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
10/30/2024	7:18 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
10/30/2024	7:30 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			0.64
10/30/2024	7:38 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			1.92
10/30/2024	7:42 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			1.8
10/30/2024	7:48 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			2.2
10/30/2024	7:51 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
10/30/2024	7:55 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
10/30/2024	7:57 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
10/30/2024	8:00 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			2.4
10/30/2024	8:08 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			4.32
10/30/2024	8:12 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			5.6
10/30/2024	8:16 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			4.8
10/30/2024	8:19 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			4
10/30/2024	8:22 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			4.8
10/30/2024	8:25 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		0.88	0.88	
10/30/2024	8:25 PM	Floor 01	119-16A Shower	2	TRUE				4.9
10/30/2024	8:25 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	0.36	0.72	
10/30/2024	8:47 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		0.72	0.6	

**Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 10/01/2024 to 10/31/2024**

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
---------------------	---------------------	--------------------------------

All filters were inspected

Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Report
From 11/01/2024 to 11/30/2024

Definitions

Filter(s) Inspected: When the box is checked, the filter was inspected for active leaks, evidence of leaks, and any defects cracks in filter casing
Filter(s) Replaced: When the box is checked, a filter was replaced at this location on the date in the first column.

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
11/4/2024	3:14 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE			1.6		
11/4/2024	3:26 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE		0.5			0.48
11/4/2024	3:39 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE		1.5	0.68	1.18	
11/4/2024	3:39 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE		1.5	0.67	1.2	
11/4/2024	3:43 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	3:45 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	3:46 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	3:48 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	3:48 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	3:49 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	3:49 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	4:03 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	4:06 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	4:08 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	4:15 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.8		
11/4/2024	4:34 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6		
11/4/2024	8:22 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	8:24 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	8:40 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	8:42 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	8:50 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	9:05 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	9:07 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	9:18 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	9:20 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	9:22 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	9:40 AM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.0		
11/4/2024	9:42 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	9:44 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	9:50 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	9:57 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	9:58 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	10:01 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	10:10 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	10:11 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	10:12 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	10:13 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	10:22 AM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE			1		
11/4/2024	10:27 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	10:28 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	10:31 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	10:40 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	10:41 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	10:50 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	10:51 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	10:54 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	10:55 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	10:56 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	11:01 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE			0.48		
11/4/2024	11:02 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	11:03 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	11:13 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	11:15 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	TRUE	1.5	1.25	1.25	
11/4/2024	11:20 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	11:21 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	11:24 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	11:34 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.62
11/4/2024	11:35 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	11:36 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	11:37 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
11/4/2024	11:46 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE			0.48		
11/4/2024	11:47 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
11/4/2024	11:48 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
11/4/2024	11:58 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48

11/4/2024	12:05 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	12:06 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	12:09 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	12:15 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	12:16 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	12:17 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	12:18 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	12:28 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		0.48	
11/4/2024	12:29 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	12:40 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	12:41 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	12:44 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	12:45 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	12:50 PM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		0.48	
11/4/2024	12:53 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	1:00 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	1:01 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	1:02 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	1:03 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	1:10 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		0.48	
11/4/2024	1:13 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	1:25 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	1:26 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	1:27 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	1:28 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	1:35 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	1:36 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	1:37 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	1:38 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	1:45 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	1:52 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	1:53 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	2:30 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	2:37 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	2:38 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	2:50 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	3:28 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	3:29 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	3:30 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	3:40 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5		0.48
11/4/2024	7:04 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	7:06 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	7:06 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	7:10 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	7:11 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	7:29 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	7:30 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	7:30 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/4/2024	7:33 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	7:33 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	7:34 PM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	TRUE			
11/4/2024	7:40 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/4/2024	7:43 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	7:53 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/4/2024	7:56 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/5/2024	1:30 AM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.4	1.4
11/5/2024	8:00 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.0	1.0
11/5/2024	8:10 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1	1
11/5/2024	8:23 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.4	
11/5/2024	8:23 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	1.4	1.07
11/5/2024	8:34 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.3	1.3
11/5/2024	8:41 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5		
11/5/2024	8:50 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.30	1.30
11/5/2024	9:00 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.30	1.30
11/5/2024	9:19 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.15	1.15
11/5/2024	9:34 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.20	1.20
11/5/2024	10:00 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.25	1.25
11/5/2024	10:10 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.30	1.30
11/5/2024	10:10 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.3	1.3
11/5/2024	10:35 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5		0.48
11/5/2024	10:45 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.30	1.30
11/5/2024	10:50 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.25	1.25
11/5/2024	1:00 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.2	1.3
11/5/2024	1:00 PM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.3	1.3

11/5/2024	1:15 PM	Floor LL	Suite. 540 Kitchenette - Faucet	2	TRUE	1.5	1.0	1.0	
11/5/2024	1:39 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.3	1.3	
11/5/2024	2:00 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.2	1.2	
11/5/2024	5:30 PM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1.00	1.08	
11/5/2024	8:15 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.2	1.3	
11/5/2024	8:43:00 AM; 12:30 PM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5			
11/5/2024	8:43:00 AM; 12:30 PM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5			
11/6/2024	1:06 AM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
11/6/2024	1:07 AM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
11/6/2024	1:09 AM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6			
11/6/2024	1:10 AM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
11/6/2024	1:14 AM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
11/6/2024	1:29 AM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE	1.6			
11/6/2024	1:48 AM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6			
11/6/2024	8:30 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.10	1.10	
11/6/2024	8:45 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.20	1.10	
11/6/2024	8:45 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.20	1.10	
11/6/2024	8:55 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.20	1.20	
11/6/2024	9:10 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2.30	2.30	
11/6/2024	9:20 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.30	1.00	
11/6/2024	9:30 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/6/2024	9:40 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/6/2024	9:50 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	0.75	0.6	
11/6/2024	10:00 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.10	1.30	
11/6/2024	10:10 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.15	1.50	
11/6/2024	10:20 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.1	1.1	
11/6/2024	10:20 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	1.10	1.10	
11/6/2024	10:32 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1.2	1.2	
11/6/2024	10:46 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.2	1.1	
11/6/2024	11:00 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.2	1.2	
11/6/2024	11:30 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.0	1.0	
11/6/2024	11:30 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.20	1.20	
11/6/2024	1:00 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.20	1.50	
11/6/2024	8:00 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.10
11/6/2024	8:00 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
11/6/2024	8:00 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
11/6/2024	9:44 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
11/6/2024	9:45 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
11/6/2024	9:46 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
11/6/2024	9:54 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2.0			1.70
11/6/2024	9:55 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2.0			1.90
11/6/2024	9:56 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2.0			1.80
11/6/2024	9:57 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2.0			1.70
11/6/2024	9:58 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2.0			1.70
11/6/2024	9:59 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2.0			1.80
11/6/2024	10:07 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/6/2024	10:08 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/6/2024	10:09 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/6/2024	10:16 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2.0			1.70
11/6/2024	10:17 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2.0			1.60
11/6/2024	10:18 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2.0			1.70
11/6/2024	10:19 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2.0			1.70
11/6/2024	10:36 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		2.00	2.00	
11/6/2024	10:49 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	2.0	2.0	
11/6/2024	11:11 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		2.0	2.0	
11/6/2024	10:59 PM	Floor 01	119-16A Shower	2	TRUE				1.3
11/11/2024	12:00 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	12:10 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	12:11 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	12:19 AM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	12:23 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	12:24 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	12:25 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	12:43 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	12:44 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	12:45 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	12:48 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	12:49 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	1:01 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	1:02 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	1:05 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	1:06 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	1:07 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48

11/11/2024	1:21 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
11/11/2024	1:27 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.4		
11/11/2024	1:33 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
11/11/2024	1:44 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	1:45 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	1:46 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	2:04 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	2:05 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	2:06 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	2:12 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.2	1.2	
11/11/2024	2:13 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	1.2	1.2	
11/11/2024	2:32 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	2:33 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	2:39 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			48
11/11/2024	2:40 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	3:42 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE	TRUE		1.6	
11/11/2024	3:52 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	3:53 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	4:02 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	4:03 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	4:04 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	4:04 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	4:04 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	4:09 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	4:09 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	4:28 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	4:30 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	4:30 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	4:30 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	4:38 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	4:54 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.8	
11/11/2024	7:22 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	7:26 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	7:28 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	7:28 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	7:29 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	7:32 AM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.07	
11/11/2024	7:39 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	7:39 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	7:39 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	7:43 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	7:43 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	7:45 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	7:45 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	7:48 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	7:49 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	7:52 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	7:53 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	7:53 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	7:53 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	7:54 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	7:54 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	7:59 AM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.8	
11/11/2024	8:04 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	8:05 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	8:05 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	8:07 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	8:07 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	8:18 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	8:20 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	8:24 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	8:26 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	8:26 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	8:26 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.8	
11/11/2024	8:34 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	8:35 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	8:35 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	8:38 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	8:38 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	8:50 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/11/2024	8:51 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	8:54 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/11/2024	8:54 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/11/2024	8:54 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48

11/11/2024	8:59 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8		
11/11/2024	9:03 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
11/11/2024	9:04 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
11/11/2024	9:10 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
11/11/2024	9:10 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
11/11/2024	9:18 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
11/11/2024	9:18 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
11/11/2024	9:24 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
11/11/2024	9:24 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
11/11/2024	9:24 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
11/11/2024	9:32 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.8		
11/11/2024	10:40 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.25	1.25	
11/11/2024	10:54 AM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/11/2024	10:06 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE	TRUE	1.6		
11/11/2024	10:11 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
11/11/2024	10:12 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
11/11/2024	10:14 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5		0.48	
11/11/2024	10:15 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48	
11/11/2024	10:16 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
11/11/2024	10:30 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
11/11/2024	10:31 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48	
11/11/2024	10:34 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5	1.40	
11/11/2024	10:35 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5	0.48	
11/11/2024	10:36 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5	0.448	
11/11/2024	11:58 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48	
11/11/2024	11:59 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5	0.48	
11/12/2024	7:50 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.2	1.2	
11/12/2024	8:00 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.2	1.2	
11/12/2024	8:10 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.25	1.25	
11/12/2024	8:20 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
11/12/2024	9:00 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.3	1.3	
11/12/2024	9:10 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.15	1.15	
11/12/2024	9:20 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	0.75	0.75	
11/12/2024	9:30 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.0	1.0	
11/12/2024	9:40 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.3	1.5	
11/12/2024	9:50 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.25	1.33	
11/12/2024	10:00 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.07	1.07	
11/12/2024	10:05 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.15	1.15	
11/12/2024	10:05 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5	1.0	1.0	
11/12/2024	10:25 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.36	1.35	
11/12/2024	10:25 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	0.75	0.75	
11/12/2024	10:40 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.4	1.4	
11/12/2024	10:50 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.15	1.15	
11/12/2024	11:00 AM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.3	1.3	
11/12/2024	11:10 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1	1	
11/12/2024	11:20 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.15	1.15	
11/12/2024	11:30 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.25	1.25	
11/12/2024	12:00 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.3	1.3	
11/12/2024	12:20 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.25	1.25	
11/12/2024	12:30 PM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.25	1.25	
11/12/2024	12:40 PM	Floor 05	Suite. 540 Kitchenette - Faucet	2	TRUE	1.5	1.1	1.1	
11/12/2024	10:30 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.15	1.15	
11/13/2024	8:16 AM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		1.20	0.76	
11/13/2024	8:18 AM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6	1.25	1.25	
11/13/2024	8:20 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	1.10	1.00	
11/13/2024	8:26 AM	Floor 01	119-16A Shower	2	TRUE				1.30
11/13/2024	8:38 AM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE	1.6			
11/13/2024	8:47 AM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
11/13/2024	8:50 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1.0	1.0	
11/13/2024	8:54 AM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
11/13/2024	9:00 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.25	1.25	
11/13/2024	9:00 AM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
11/13/2024	9:04 AM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
11/13/2024	9:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.25	1.25	
11/13/2024	9:20 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	2.0	2.0	
11/13/2024	9:20 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	1.25	1.25	
11/13/2024	9:30 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.3	1.3	
11/13/2024	9:50 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.3	1.3	
11/13/2024	10:00 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.4	1.4	
11/13/2024	10:10 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.0	1.0	
11/13/2024	10:30 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.25
11/13/2024	10:30 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
11/13/2024	11:10 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	1.5	1.25	1.25	
11/13/2024	11:11 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.3	1.3	

11/13/2024	11:11 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.50	1.20	
11/13/2024	6:50 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			2.2
11/13/2024	6:58 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			2
11/13/2024	7:00 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			2.3
11/13/2024	7:02 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			2.2
11/13/2024	7:03 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
11/13/2024	7:04 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/13/2024	7:05 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/13/2024	7:05 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/13/2024	7:09 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
11/13/2024	7:09 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
11/13/2024	7:17 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			2.3
11/13/2024	7:20 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			1.6
11/13/2024	7:20 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			1.4
11/13/2024	7:24 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			4.2
11/13/2024	7:26 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			4.1
11/13/2024	7:29 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			1.7
11/13/2024	8:20 PM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2.14	2.14	
11/13/2024	8:30 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	0.96	0.96	
11/13/2024	10:30 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1.20	1.20	
11/13/2024	10:31 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
11/13/2024	11:20 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.2	1.4	
11/13/2024	11:20 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.3	1.4	
11/13/2024	11:20 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1	1	
11/13/2024	11:20 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.2	1.2	
11/13/2024	11:21 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/13/2024	11:22 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/18/2024	12:02 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	12:03 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	12:04 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	12:09 AM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
11/18/2024	12:15 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	12:16 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	12:20 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	12:21 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	12:22 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	12:29 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	12:30 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	12:35 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	12:36 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	12:37 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	12:45 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
11/18/2024	1:50 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	1:51 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	1:52 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	2:00 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	2:01 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1.2
11/18/2024	2:02 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	2:10 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			1.9
11/18/2024	2:11 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			3.4
11/18/2024	2:12 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	2:13 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	2:14 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	2:14 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	2:15 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	2:22 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
11/18/2024	2:22 AM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	2:30 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	2:30 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	2:31 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	2:32 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	2:32 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	2:34 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	2:36 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	2:38 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	2:42 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	2:43 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	2:56 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	2:57 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	3:00 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	3:01 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	3:02 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	3:07 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
11/18/2024	3:11 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48

11/18/2024	3:12 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	3:13 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	3:21 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	3:22 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	3:26 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
11/18/2024	3:30 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	3:31 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	3:34 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	3:35 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	3:36 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	4:08 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.6		
11/18/2024	4:14 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
11/18/2024	4:21 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	4:21 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	4:27 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	4:27 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	4:34 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	4:35 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	4:35 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	4:47 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	4:48 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	4:49 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	4:54 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	119	72	
11/18/2024	4:54 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	120	70	
11/18/2024	5:01 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
11/18/2024	5:24 AM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/18/2024	8:30 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	TRUE	1.5	1.1	1.15
11/18/2024	10:16 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
11/18/2024	7:01 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	7:03 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	7:03 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	7:14 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	7:14 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	7:18 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	7:20 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	7:20 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	7:21 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	7:25 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	7:29 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
11/18/2024	7:35 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	7:37 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	7:37 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	7:40 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	7:40 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	7:44 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	7:45 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	7:48 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	7:48 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	7:48 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	7:55 PM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
11/18/2024	10:04 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	10:06 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	10:13 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	10:14 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	10:28 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	10:29 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	10:33 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	10:34 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	10:35 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	10:42 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	10:43 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	10:49 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	10:50 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	10:51 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	10:57 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
11/18/2024	11:03 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	11:04 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/18/2024	11:05 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	11:13 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	11:58 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/18/2024	11:58 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/18/2024	11:59 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/19/2024	8:00 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.50	1.50	
11/19/2024	8:10 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.25	1.20	

11/19/2024	8:20 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.50	1.50	
11/19/2024	8:25 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
11/19/2024	8:40 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.1	1.2	
11/19/2024	8:50 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.25	1.3	
11/19/2024	9:00 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.25	1.1	
11/19/2024	9:10 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1	1	
11/19/2024	9:20 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.3	1.3	
11/19/2024	9:30 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.3	1.2	
11/19/2024	9:40 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.3	1.3	
11/19/2024	9:50 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.25	1.25	
11/19/2024	10:00 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.5	1.25	
11/19/2024	10:00 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	0.75	0.75	
11/19/2024	10:10 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.2	1.2	
11/19/2024	10:10 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5	1.0	1.0	
11/19/2024	10:31 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.5	1.5	
11/19/2024	10:40 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	1.5	1.5	
11/19/2024	10:50 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.00	1.00	
11/19/2024	11:00 AM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1.07	1.10	
11/19/2024	11:20 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1	1	
11/19/2024	11:30 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.2	1.3	
11/19/2024	11:40 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.15	1.15	
11/19/2024	11:50 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.25	1.25	
11/19/2024	12:00 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.5	1.5	
11/19/2024	12:20 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.25	1.3	
11/20/2024	12:52 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/20/2024	12:53 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/20/2024	12:57 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			2.5
11/20/2024	12:58 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			2.3
11/20/2024	12:59 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			2.4
11/20/2024	1:00 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			2.5
11/20/2024	1:08 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
11/20/2024	1:09 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
11/20/2024	1:10 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
11/20/2024	1:19 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			1.6
11/20/2024	1:20 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			1.7
11/20/2024	1:21 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			1.7
11/20/2024	1:22 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			1.6
11/20/2024	1:23 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			1.7
11/20/2024	1:24 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			1.7
11/20/2024	8:20 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
11/20/2024	8:20 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
11/20/2024	8:40 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.0	1.0	
11/20/2024	8:40 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.5	0.5	
11/20/2024	8:40 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	TRUE	1.5	1.5	1
11/20/2024	8:40 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.25	1.25	
11/20/2024	10:00 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	2	1.5	
11/20/2024	10:10 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1	1	
11/20/2024	10:20 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	2	1.5	
11/20/2024	10:37 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	0.5	0.5	
11/20/2024	10:37 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	0.75	0.75	
11/20/2024	10:50 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1	1	
11/20/2024	11:10 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1	0.5	
11/20/2024	11:20 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1	0.5	
11/20/2024	11:30 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1	0.75	
11/20/2024	1:30 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
11/20/2024	1:40 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.5	2	
11/20/2024	8:20 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.2
11/20/2024	8:20 PM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2	1.5	
11/20/2024	8:30 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1	1.5	
11/20/2024	8:40 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/20/2024	8:40 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/20/2024	10:04 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6			
11/20/2024	10:05 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
11/20/2024	10:07 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
11/20/2024	10:11 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
11/20/2024	10:15 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
11/20/2024	10:21 PM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE	1.6			
11/20/2024	10:30 PM	Floor 01	119-16A Shower	2	TRUE				1
11/20/2024	10:41 PM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6			
11/20/2024	10:52 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	1.7	1.7	
11/20/2024	10:59 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		1.7	1.6	
11/20/2024	11:08 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/20/2024	11:16 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1.6	1.6	
11/25/2024	12:49 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48

11/25/2024	12:51 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	12:53 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	1:03 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	1:04 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	1:06 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	1:07 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	1:08 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	1:15 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	TRUE				
11/25/2024	1:28 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
11/25/2024	1:34 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.6		
11/25/2024	1:42 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	1:43 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	1:50 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	1:51 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	2:00 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	2:01 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	2:02 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	2:12 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	2:12 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	2:14 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	2:18 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.3	1.3	
11/25/2024	2:19 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	1.3	1.3	
11/25/2024	2:21 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
11/25/2024	2:31 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
11/25/2024	2:42 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	2:43 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	2:49 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	2:50 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	4:14 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	4:14 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	4:40 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	4:44 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	4:44 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	4:44 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	4:44 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	9:12 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	12:48 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	2:10 PM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1	1	
11/25/2024	4:17 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	4:17 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	4:22 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:03 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:03 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:04 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	7:04 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	7:08 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	7:23 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	7:24 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:24 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:26 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	7:27 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	7:30 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
11/25/2024	7:34 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:35 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	7:35 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	7:41 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	7:41 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:49 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	7:51 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:53 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	7:53 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	7:54 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	7:55 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
11/25/2024	8:06 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	8:07 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	8:09 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	8:12 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	8:12 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	8:18 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	8:19 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	8:23 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/25/2024	8:24 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/25/2024	8:24 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/25/2024	8:27 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		16		

11/25/2024	8:35 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	8:36 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	8:36 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/25/2024	8:42 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	8:42 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	8:50 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	8:52 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	8:56 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	8:56 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/25/2024	8:56 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	9:00 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.5	
11/25/2024	9:08 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	9:08 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/25/2024	9:09 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	9:12 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	9:13 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	9:25 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	9:26 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	9:30 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	9:30 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/25/2024	9:30 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	9:34 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6	
11/25/2024	10:08 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6	
11/25/2024	10:14 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	10:16 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	10:17 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/25/2024	10:18 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	10:28 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	10:30 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	10:30 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		1.5
11/25/2024	10:31 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		2
11/25/2024	10:32 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		1
11/25/2024	10:45 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	10:46 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/25/2024	10:47 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	10:55 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	10:56 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	11:03 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	11:06 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/25/2024	11:07 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5		0.48
11/25/2024	11:08 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5		0.48
11/25/2024	11:24 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5		0.48
11/25/2024	10:13 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5		0.48
11/26/2024	9:10 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5		0.48
11/26/2024	9:15 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1	1
11/26/2024	9:30 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1	1
11/26/2024	9:40 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.5	1
11/26/2024	10:00 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1	1.5
11/26/2024	10:10 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.5	1
11/26/2024	10:20 AM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1	0.5
11/26/2024	10:30 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1	1
11/26/2024	10:40 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1	0.5
11/26/2024	10:52 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1	1.5
11/26/2024	11:10 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	2	1.5
11/26/2024	11:20 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.5	1.5
11/26/2024	11:30 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.5	1.5
11/26/2024	11:40 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	2	1.5
11/26/2024	11:50 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.5	1.5
11/26/2024	12:00 PM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1	1
11/26/2024	1:00 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1	1
11/26/2024	1:10 PM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.5	1.5
11/26/2024	1:20 PM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.5	1
11/26/2024	1:30 PM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	2	1.5
11/26/2024	1:50 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.5	1.5
11/26/2024	2:00 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1	1
11/27/2024	8:00 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5		0.48
11/27/2024	8:00 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5		0.48
11/27/2024	8:00 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5		0.48
11/27/2024	9:30 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.5	1.5
11/27/2024	9:40 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1	1.5
11/27/2024	9:50 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1	1.5
11/27/2024	10:10 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.5	1.5
11/27/2024	10:20 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1	0.5
11/27/2024	10:20 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	0.75	0.75

11/27/2024	10:30 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.5	1.5	
11/27/2024	10:40 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.5	1.5	
11/27/2024	10:50 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.0	0.5	
11/27/2024	11:30 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.0	1.0	
11/27/2024	7:03 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
11/27/2024	7:04 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
11/27/2024	7:04 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
11/27/2024	7:10 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			1
11/27/2024	7:12 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			1/2
11/27/2024	7:14 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			1/2
11/27/2024	7:16 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			1
11/27/2024	7:25 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
11/27/2024	7:27 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
11/27/2024	7:27 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
11/27/2024	7:29 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			1/2
11/27/2024	7:32 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			1/2
11/27/2024	7:33 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			1/2
11/27/2024	7:35 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			1
11/27/2024	7:37 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			1/2
11/27/2024	7:39 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			1/2
11/27/2024	8:08 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		2.0	2.0	
11/27/2024	8:17 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	1	1/2	
11/27/2024	8:23 PM	Floor 01	119-16A Shower	2	TRUE				0.48
11/27/2024	8:25 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1	1	
11/27/2024	8:32 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
11/27/2024	8:35 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
11/27/2024	8:36 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6			
11/27/2024	8:42 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6	1/2	1/2	
11/27/2024	8:50 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
11/27/2024	8:50 PM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2	1	
11/27/2024	8:55 PM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6			
11/27/2024	9:00 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1	1	
11/27/2024	9:20 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/27/2024	9:20 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
11/27/2024	11:00 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1	1	
11/27/2024	11:00 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1	1	
11/27/2024	11:00 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	0.5	0.5	
11/27/2024	11:00 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1	1	

**Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 11/01/2024 to 11/30/2024**

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
---------------------	---------------------	--------------------------------

All filters were inspected

Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Report
From 12/01/2024 to 12/31/2024

Definitions

Filter(s) Inspected: When the box is checked, the filter was inspected for active leaks, evidence of leaks, and any defects cracks in filter casing
Filter(s) Replaced: When the box is checked, a filter was replaced at this location on the date in the first column.

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
12/2/2024	12:28 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	12:29 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	12:34 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	12:35 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	12:36 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	12:45 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	12:46 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	12:51 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	12:52 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	12:53 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	1:00 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6		
12/2/2024	1:10 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	1:11 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	1:12 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	1:21 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			1.5
12/2/2024	1:22 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	1:30 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			2.8
12/2/2024	1:31 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			3.4
12/2/2024	1:33 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	1:34 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	1:35 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	1:43 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6		
12/2/2024	1:52 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	1:53 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	1:54 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	2:02 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	2:03 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	2:10 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	2:11 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	2:13 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	2:14 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	2:15 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	2:22 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6		
12/2/2024	2:28 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	2:29 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	2:30 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	2:39 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	2:40 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	2:47 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	2:48 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	2:52 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6		
12/2/2024	2:58 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	2:59 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	3:00 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	3:29 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE			1.7		
12/2/2024	3:40 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE		0.5			0.48
12/2/2024	3:55 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	3:55 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	3:59 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	3:59 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	4:00 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		10	1.8		
12/2/2024	4:06 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	4:07 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	4:07 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	4:12 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5			0.48
12/2/2024	4:15 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	4:15 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5			0.48
12/2/2024	4:16 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE		1.5	0.21	66	
12/2/2024	4:16 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE		1.5	0.23	68	
12/2/2024	4:38 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6		
12/2/2024	1:40 PM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE		1.5	1	0.5	
12/2/2024	7:06 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5			0.48
12/2/2024	7:08 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
12/2/2024	7:08 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5			0.48

12/2/2024	7:12 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	7:12 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	7:23 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	7:24 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	7:26 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	7:26 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	7:26 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	7:29 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/2/2024	7:38 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	7:39 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	7:39 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	7:42 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	7:42 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	7:49 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	7:54 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	7:54 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	7:54 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	8:00 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	8:01 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	8:01 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	8:06 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	8:07 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	8:12 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	8:14 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	8:17 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	8:17 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	8:17 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	8:24 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	8:25 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	8:39 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	8:41 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	10:10 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	10:11 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	10:15 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	10:16 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	10:17 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	10:28 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	10:29 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	10:33 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	10:34 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	10:35 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	10:42 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/2/2024	10:49 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	10:50 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	10:51 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	10:59 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	11:00 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	11:01 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
12/2/2024	11:09 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	11:10 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	11:13 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/2/2024	11:14 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/2/2024	11:15 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/2/2024	11:21 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.5		
12/3/2024	8:40 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1	1	
12/3/2024	8:50 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1	1	
12/3/2024	9:20 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1	1	
12/3/2024	9:30 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.5	1.5	
12/3/2024	10:00 AM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.5	0.5	
12/3/2024	10:10 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.5	0.5	
12/3/2024	10:20 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.5	1.5	
12/3/2024	10:40 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.5	1	
12/3/2024	10:40 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	1	0.5	
12/3/2024	10:40 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1	1	
12/3/2024	10:50 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1	1.5	
12/3/2024	11:10 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.5	1	
12/3/2024	11:20 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1	1	
12/3/2024	11:30 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1	1	
12/3/2024	11:30 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.5	1	
12/3/2024	11:40 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1	1	
12/3/2024	1:00 PM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1	1.5	
12/3/2024	1:10 PM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.5	1	
12/3/2024	1:20 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.5	1.5	
12/3/2024	1:25 PM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48

12/3/2024	1:30 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.5	1.5	
12/3/2024	1:50 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1	0.5	
12/4/2024	2:35 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/4/2024	2:36 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/4/2024	2:37 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/4/2024	2:43 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			1.7
12/4/2024	2:44 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			1.7
12/4/2024	2:45 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			1.7
12/4/2024	2:46 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			1.7
12/4/2024	2:50 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
12/4/2024	2:51 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
12/4/2024	2:52 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
12/4/2024	2:58 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			1.7
12/4/2024	2:59 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			1.6
12/4/2024	3:00 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			1.7
12/4/2024	3:01 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			1.7
12/4/2024	3:02 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			1.7
12/4/2024	3:30 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			1.7
12/4/2024	8:00 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.5
12/4/2024	8:00 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
12/4/2024	8:00 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
12/4/2024	9:00 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2	1.5	
12/4/2024	9:02 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1	0.5	
12/4/2024	9:03 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
12/4/2024	9:20 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
12/4/2024	9:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	0.5	0.5	
12/4/2024	9:35 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	0.5	0.5	
12/4/2024	9:40 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1	1	
12/4/2024	9:50 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1	1	
12/4/2024	10:00 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1	1	
12/4/2024	10:20 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1	1	
12/4/2024	10:30 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	2	2	
12/4/2024	10:38 AM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1.8	1.8	
12/4/2024	10:40 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1	1	
12/4/2024	10:50 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	1.5	1	1	
12/4/2024	11:00 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	2	2	
12/4/2024	11:11 AM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
12/4/2024	11:12 AM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
12/4/2024	11:28 AM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
12/4/2024	12:00 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	TRUE	1.5	1.5	1.5
12/4/2024	12:00 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	TRUE	1.5	1	1.5
12/4/2024	12:00 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	TRUE	1.5	1.5	1
12/4/2024	12:00 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	TRUE	1.5	1	1
12/4/2024	9:56 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		2.5	2.5	
12/4/2024	10:12 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	2.5	2.5	
12/4/2024	10:28 PM	Floor 01	119-16A Shower	2	TRUE				1
12/4/2024	10:49 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.5			
12/4/2024	10:50 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
12/4/2024	11:41 PM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6			
12/9/2024	12:38 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	12:39 AM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/9/2024	12:41 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1
12/9/2024	12:42 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			1.5
12/9/2024	12:43 AM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			1
12/9/2024	12:55 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	12:56 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/9/2024	12:57 AM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/9/2024	1:06 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	1:07 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/9/2024	1:18 AM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	1:21 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	1:22 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/9/2024	1:23 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/9/2024	1:44 AM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
12/9/2024	2:13 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	2:14 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/9/2024	2:16 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	2:17 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/9/2024	2:18 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/9/2024	2:25 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	2:26 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/9/2024	2:29 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/9/2024	2:30 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/9/2024	2:31 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48

12/9/2024	2:36 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	TRUE				
12/9/2024	3:00 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/9/2024	3:18 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:26 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:26 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:28 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:30 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:30 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:30 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE			1.8	
12/9/2024	3:31 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE		0.5		0.48
12/9/2024	3:32 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE			16	
12/9/2024	3:32 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:34 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:36 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:37 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	3:38 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	3:42 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:44 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	3:45 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	3:48 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:50 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	3:52 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	3:53 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/9/2024	3:54 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	3:55 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	3:56 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/9/2024	3:56 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE		1.5	1.2	1.2
12/9/2024	3:57 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	3:57 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE		1.5	1.2	1.2
12/9/2024	4:05 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6	
12/9/2024	4:08 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	4:09 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	4:12 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
12/9/2024	4:15 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	4:16 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	4:18 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	4:20 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	4:22 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	4:23 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	4:30 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	4:32 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:00 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:04 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:20 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	11:00 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE		1.5	1.5	2
12/9/2024	8:00 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:03 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:20 PM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6	
12/9/2024	8:26 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:28 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:30 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:32 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:34 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:36 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:40 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:42 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	8:44 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6	
12/9/2024	9:56 PM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6	
12/9/2024	10:03 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	10:04 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	10:08 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:09 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/9/2024	10:10 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	10:10 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:11 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	10:19 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	10:20 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:24 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/9/2024	10:25 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	10:26 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	10:28 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:30 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:32 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:33 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6	

12/9/2024	10:34 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
12/9/2024	10:39 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	10:40 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/9/2024	10:41 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	10:49 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	10:50 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	10:59 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	11:00 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	11:03 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	11:04 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/9/2024	11:05 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	11:11 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE	TRUE		1.6	
12/9/2024	11:15 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6	
12/9/2024	11:18 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	11:19 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	11:21 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/9/2024	11:22 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/9/2024	11:23 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/9/2024	10:26 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/10/2024	8:20 AM	Floor 05	540 Faucet (507-26)	2	TRUE		1.5	1	0.5
12/10/2024	8:30 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE		1.5	1.5	1
12/10/2024	8:40 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE		1.5	1.5	1
12/10/2024	8:50 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE		1.5	1.5	1
12/10/2024	9:00 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE		1.5	1	1
12/10/2024	9:10 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	TRUE	1.5	1.5	1
12/10/2024	9:20 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE		1.5	1	1
12/10/2024	9:40 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE		1.5	1.5	1
12/10/2024	10:00 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE		1.5	1	
12/10/2024	10:00 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE		1.5	1	0.5
12/10/2024	10:10 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE		1.5	1.5	1.5
12/10/2024	10:30 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE		1.5	1	1
12/10/2024	10:50 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE		1.5	1	1
12/10/2024	11:00 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE		1.5	1	1
12/10/2024	11:10 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE		1.5	1	1
12/10/2024	11:20 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE		1.5	1	1
12/10/2024	11:30 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE		1.5	1.5	1
12/10/2024	12:33 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE		1.5	1.5	2
12/10/2024	12:40 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE		1.5	1.5	2
12/10/2024	12:50 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE		1.5	1.5	2
12/11/2024	10:39 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE			1.5	2
12/11/2024	10:40 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE		1.5	2	2
12/11/2024	10:46 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE		0.5		0.48
12/11/2024	10:50 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE		0.5		0.48
12/11/2024	11:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE		1.5	2	0
12/11/2024	11:10 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE		1.5	0	0.5
12/11/2024	11:20 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE		1.5	1.5	1
12/11/2024	11:30 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE		1.5	2	1.5
12/11/2024	11:40 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE		1.5	1.5	1.5
12/11/2024	11:50 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE		1.5	1.5	1
12/11/2024	12:00 PM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE		1.5	1.5	1.5
12/11/2024	12:10 PM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE		1.5	1	1
12/11/2024	12:20 PM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE		1.5	1	1
12/11/2024	12:30 PM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE		1.5	2	1.5
12/11/2024	12:30 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE		1.5	1.5	1.5
12/11/2024	12:40 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE		1.5	1.5	1.5
12/11/2024	12:50 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE		1.5	1.5	2
12/11/2024	1:00 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE		1.5	1.3	1
12/11/2024	1:00 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE		1.5	1.5	2
12/11/2024	7:01 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE		0.5		1/2
12/11/2024	7:02 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE		0.5		1/2
12/11/2024	7:02 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE		0.5		1/2
12/11/2024	7:12 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE				1/2
12/11/2024	7:14 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE				1/2
12/11/2024	7:16 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE				1/2
12/11/2024	7:18 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE				1/2
12/11/2024	7:24 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE				1/2
12/11/2024	7:25 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE				1/2
12/11/2024	7:25 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE				1/2
12/11/2024	7:28 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE		2		112 1/2
12/11/2024	7:31 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE				112 1/2
12/11/2024	7:32 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE		2		1/2
12/11/2024	7:32 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE				1/2
12/11/2024	7:33 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE				1/2
12/11/2024	7:36 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE		2		1/2

12/11/2024	8:07 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		3	2.5	
12/11/2024	8:20 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE		1	2	
12/11/2024	8:24 PM	Floor 01	119-16A Shower	2	TRUE				1/2
12/11/2024	8:28 PM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE				
12/11/2024	8:28 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1	1/2	
12/11/2024	8:34 PM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE		1/2		
12/11/2024	8:38 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE				
12/11/2024	8:40 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE				1
12/11/2024	8:40 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE				0.48
12/11/2024	8:40 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
12/11/2024	8:42 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE		1/2	1/2	
12/11/2024	8:44 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE				
12/11/2024	8:49 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE		1/2	1/2	
12/11/2024	8:49 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE		1/2	1/2	1/2
12/16/2024	12:00 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	12:05 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	12:06 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	12:07 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	12:15 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	12:16 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	12:21 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	12:22 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	12:23 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	12:30 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
12/16/2024	12:35 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	12:36 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	12:37 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	12:46 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	12:47 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	12:55 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			2.2
12/16/2024	12:56 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			3
12/16/2024	12:59 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	1:00 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	1:01 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	1:08 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/16/2024	1:14 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	1:15 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	1:16 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	1:18 AM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
12/16/2024	1:25 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	1:26 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	1:32 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	1:33 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	1:36 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	1:37 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	1:38 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	1:44 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
12/16/2024	2:48 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	2:49 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	2:50 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	2:59 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	3:00 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	3:08 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	3:09 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	3:12 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	3:13 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	3:14 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	3:18 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	3:18 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	3:22 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
12/16/2024	3:28 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	3:28 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	3:55 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.6		
12/16/2024	4:04 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
12/16/2024	4:27 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	4:28 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	4:30 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	4:32 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
12/16/2024	4:36 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	4:36 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	4:38 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	4:44 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	66	122	
12/16/2024	4:44 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	65	120	
12/16/2024	5:04 AM	Floor 02	C207 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		

12/16/2024	5:12 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
12/16/2024	7:08 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	7:08 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	7:08 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	7:12 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	7:12 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	7:17 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/16/2024	7:18 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	7:20 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	7:22 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	7:22 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	7:23 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	7:34 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	7:35 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	7:35 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	7:38 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	7:39 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	7:53 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	7:57 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	7:57 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	7:57 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	8:00 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	8:01 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	8:02 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	8:07 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	8:07 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	8:10 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	8:18 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	8:19 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	8:19 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	8:19 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	8:37 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	8:40 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	8:54 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	8:58 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	10:09 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	10:10 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	10:16 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	10:17 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	10:18 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	10:24 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/16/2024	10:26 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	10:27 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	10:31 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	10:32 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	10:33 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	10:48 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	10:49 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	10:50 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	10:58 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	10:59 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	11:07 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	11:08 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	11:11 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/16/2024	11:12 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/16/2024	11:13 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/16/2024	11:20 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/16/2024	11:59 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/17/2024	12:10 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.5	1.5	
12/17/2024	12:10 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.5	1	
12/17/2024	12:20 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	2	1.5	
12/17/2024	12:30 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1	1	
12/17/2024	12:40 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1	1	
12/17/2024	12:40 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
12/17/2024	12:50 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	2	1.5	
12/17/2024	8:20 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	0.5	0.5	
12/17/2024	8:50 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.5	1.5	
12/17/2024	9:00 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	TRUE	1.5	1.5	2
12/17/2024	9:10 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	TRUE	1.5	1	1.5
12/17/2024	12:00 PM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.5	1	
12/17/2024	8:30 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.5	1.5	1.5
12/17/2024	8:40 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1	1.5	
12/17/2024	9:20 PM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	TRUE	1.5	1	1
12/17/2024	9:30 PM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1	1	

12/17/2024	9:40 PM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	TRUE	1.5	2	2
12/17/2024	10:00 PM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE		1.5	1	1
12/17/2024	10:20 PM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	TRUE	1.5	1.5	1.5
12/17/2024	10:20 PM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	TRUE	1.5	1.5	0.5
12/17/2024	10:40 PM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	TRUE	1.5	1.5	1.5
12/17/2024	10:40 PM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	TRUE	1.5	1.5	0.5
12/17/2024	10:50 PM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE		1.5	1.5	1.5
12/17/2024	11:00 PM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE		1.5	1.5	1
12/17/2024	11:10 PM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE		1.5	1.5	1
12/17/2024	11:20 PM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE		1.5	1.5	1.5
12/18/2024	12:10 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE		0.5		1
12/18/2024	12:20 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE		0.5		0.48
12/18/2024	12:30 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE		0.5		0.48
12/18/2024	12:42 AM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE		1.6		
12/18/2024	12:59 AM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE		1.6		
12/18/2024	1:16 AM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE		1.6		
12/18/2024	1:34 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/18/2024	1:35 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/18/2024	1:36 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/18/2024	1:42 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE		2		1.4
12/18/2024	1:43 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE		2		1.4
12/18/2024	1:44 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE		2		1.3
12/18/2024	1:45 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE		2		1.4
12/18/2024	1:51 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE		0.5		0.48
12/18/2024	1:52 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE		0.5		0.48
12/18/2024	1:53 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE		0.5		0.48
12/18/2024	2:00 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE		2		1.3
12/18/2024	2:01 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE		2		1.2
12/18/2024	2:02 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE		2		1.4
12/18/2024	2:03 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE		2		1.3
12/18/2024	2:04 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE		2		1.3
12/18/2024	2:05 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE		2		1.4
12/18/2024	8:30 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE	TRUE		2	2
12/18/2024	8:40 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	TRUE	1.5	1.5	1
12/18/2024	8:44 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	TRUE	0.5		0.48
12/18/2024	8:50 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE		0.5		0.48
12/18/2024	8:51 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE		1.5	1.5	1
12/18/2024	9:00 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE		1.5	1.5	1
12/18/2024	9:10 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE		1.5	1	1
12/18/2024	9:20 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE		1.5	1	1
12/18/2024	9:30 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE		1.5	1.5	1
12/18/2024	9:40 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE		1.5	1	1
12/18/2024	9:50 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE		1.5	1	1
12/18/2024	10:00 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE		1.5	1	1
12/18/2024	10:20 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE		1.5	1.5	0.5
12/18/2024	11:00 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE		1.5	1.5	1
12/18/2024	11:30 AM	Floor 01	119-02 Mailroom - Faucet	2	TRUE			1	1
12/18/2024	11:40 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE		1.5	1.5	1
12/18/2024	11:50 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE		1.5	1.5	1
12/18/2024	12:00 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE		1.5	1.5	1
12/18/2024	10:19 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE		1.6	1.8	2
12/18/2024	10:31 PM	Floor 01	119-16A Shower	2	TRUE				1
12/18/2024	10:42 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE	TRUE		1.8	1.7
12/18/2024	10:49 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE		1.6		
12/18/2024	10:55 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE		1.6		
12/18/2024	11:06 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE		1.6		
12/18/2024	11:19 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE		1.6		
12/18/2024	11:20 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE		1.5	1.5	1
12/18/2024	11:20 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE		1.5	1	1
12/18/2024	11:20 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE		1.5	1.5	1.5
12/23/2024	12:26 AM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE		0.5		0.48
12/23/2024	12:50 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/23/2024	12:51 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/23/2024	12:53 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/23/2024	12:54 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/23/2024	12:55 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/23/2024	1:07 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/23/2024	1:08 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/23/2024	1:11 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5		0.48
12/23/2024	1:12 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5		0.48
12/23/2024	1:13 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5		0.48
12/23/2024	1:30 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE		0.5		0.48
12/23/2024	1:33 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE			1.7	
12/23/2024	1:41 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5		0.48

12/23/2024	1:42 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	1:48 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	1:49 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	1:58 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	1:59 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	2:00 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	2:11 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	2:12 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	2:13 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	2:18 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.4	1.4	
12/23/2024	2:20 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	1.2	1.2	
12/23/2024	2:31 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
12/23/2024	2:40 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	2:41 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	2:47 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	2:48 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	6:59 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
12/23/2024	6:59 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	6:59 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	6:59 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:02 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:02 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:08 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:09 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:12 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:12 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	7:13 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:19 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	7:20 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:20 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:22 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:22 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:36 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:38 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:38 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	7:42 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:42 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:46 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8		
12/23/2024	7:52 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	7:53 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:53 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	7:56 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	7:56 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	8:06 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	8:07 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	8:08 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	8:08 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	8:08 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	8:09 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.8		
12/23/2024	8:16 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	8:17 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	8:17 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	8:23 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	8:23 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	8:36 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	8:38 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	8:42 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	8:42 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	8:42 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	8:45 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.9		
12/23/2024	8:54 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	8:55 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	8:55 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	8:58 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	8:58 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	9:09 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	9:12 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	9:15 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	9:15 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	9:16 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	9:22 PM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.8		
12/23/2024	10:01 PM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
12/23/2024	10:06 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/23/2024	10:12 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48

12/23/2024	10:13 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	10:13 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	10:17 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	10:18 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	10:32 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	10:33 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	10:36 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			1.4
12/23/2024	10:37 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			1.2
12/23/2024	10:39 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1
12/23/2024	10:48 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	10:49 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	10:50 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	10:59 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	11:00 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/23/2024	11:08 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	11:10 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/23/2024	11:11 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/23/2024	11:12 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/24/2024	12:50 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.5	1.5	
12/24/2024	12:50 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.5	1.5	
12/24/2024	1:00 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1	1	
12/24/2024	1:10 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.5	1	
12/24/2024	1:20 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	2	1.5	
12/24/2024	1:50 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.5	1	
12/24/2024	2:10 AM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	1.5	1	
12/24/2024	2:20 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	2	1.5	
12/24/2024	9:30 PM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.5	1.5	
12/24/2024	9:40 PM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1	1	
12/24/2024	9:50 PM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.5	1	
12/24/2024	10:00 PM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.5	1	
12/24/2024	10:10 PM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.5	1.5	
12/24/2024	10:30 PM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.5	2	
12/24/2024	10:50 PM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.5	1.5	
12/24/2024	11:00 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.5	1.5	
12/24/2024	11:10 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1	1	
12/24/2024	11:20 PM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
12/25/2024	9:50 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.5	1	
12/25/2024	9:50 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	2	1.5	
12/25/2024	9:50 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.5	1	
12/25/2024	9:50 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
12/25/2024	10:00 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
12/25/2024	10:08 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
12/25/2024	10:20 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.5	1	
12/25/2024	10:30 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		1.5	1.5	
12/25/2024	7:00 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/25/2024	7:01 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/25/2024	7:01 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/25/2024	7:13 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			1.5
12/25/2024	7:14 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			1.5
12/25/2024	7:20 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			1.5
12/25/2024	7:23 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			1.5
12/25/2024	7:30 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.48
12/25/2024	7:32 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.48
12/25/2024	7:32 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.48
12/25/2024	7:33 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			1.5
12/25/2024	7:35 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			1.5
12/25/2024	7:41 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			1.5
12/25/2024	7:43 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			1
12/25/2024	7:45 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			2
12/25/2024	7:48 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			1
12/25/2024	8:05 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		2.5	3	
12/25/2024	8:15 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	2	2.5	
12/25/2024	8:20 PM	Floor 01	119-16A Shower	2	TRUE				0.5
12/25/2024	8:27 PM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE	1.6	1	0.5	
12/25/2024	8:28 PM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6			
12/25/2024	8:29 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		3	25	
12/25/2024	8:30 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6	1		
12/25/2024	8:38 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6	1	0.5	
12/25/2024	8:42 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6	1	1.5	
12/25/2024	8:47 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6	1.5	1	
12/25/2024	8:52 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6	1	5	
12/25/2024	9:00 PM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.5	0.5	
12/25/2024	9:00 PM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	1.5	1.5	
12/25/2024	9:30 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.5

12/25/2024	9:32 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
12/25/2024	9:36 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
12/25/2024	9:40 PM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
12/25/2024	10:50 PM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.5	1	
12/30/2024	12:41 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	12:42 AM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	12:45 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	12:46 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	12:52 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	12:53 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	12:53 AM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	12:54 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	12:56 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	12:57 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	12:58 AM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:01 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
12/30/2024	1:07 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	1:08 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	1:09 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:17 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1.5
12/30/2024	1:18 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:18 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	1:19 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:23 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			2.8
12/30/2024	1:24 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			2
12/30/2024	1:24 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	1:25 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	1:26 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:27 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	1:28 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	1:29 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:39 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/30/2024	1:39 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	1:40 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:44 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	1:45 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	1:45 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	1:46 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	1:46 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:47 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:56 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	1:57 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	2:00 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	2:01 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	2:02 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
12/30/2024	2:06 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	2:07 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	2:09 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	2:10 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.7		
12/30/2024	2:16 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
12/30/2024	2:22 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
12/30/2024	2:31 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	2:32 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	2:38 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	2:39 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	2:50 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	2:51 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	2:52 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	3:03 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	3:04 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	3:04 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	3:05 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	3:05 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	3:06 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	3:11 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.3	1.3	
12/30/2024	3:12 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	TRUE	1.5	1.4	1.4
12/30/2024	3:17 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	3:18 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	3:20 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.5		
12/30/2024	3:23 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
12/30/2024	3:28 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	3:28 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	3:29 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	3:29 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48

12/30/2024	3:33 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	3:33 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	3:34 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	3:34 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	3:35 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	1:00 PM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.5	1	
12/30/2024	10:06 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	10:07 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	10:13 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	10:14 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	10:15 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	10:16 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
12/30/2024	10:22 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	10:22 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	10:23 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	10:23 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	10:26 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
12/30/2024	10:27 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	10:27 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	10:28 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	10:28 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	10:29 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	10:35 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/30/2024	10:40 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	10:41 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	10:42 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	10:42 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	10:43 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	10:47 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.1
12/30/2024	10:48 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		1.4
12/30/2024	10:49 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		1.4
12/30/2024	10:52 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	10:53 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	11:00 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	11:01 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	11:01 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	11:02 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	11:02 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	11:03 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	11:04 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	11:05 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	11:12 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
12/30/2024	11:16 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	11:17 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/30/2024	11:21 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
12/30/2024	11:22 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
12/30/2024	11:24 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
12/30/2024	11:25 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
12/31/2024	8:15 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.5	1.5	
12/31/2024	8:40 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.5	1	
12/31/2024	8:50 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.5	1	
12/31/2024	9:00 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.5	1	
12/31/2024	9:10 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1	1	
12/31/2024	9:30 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.5	1.5	
12/31/2024	9:40 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.5	1	
12/31/2024	10:00 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1	1	
12/31/2024	10:30 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	2	1	
12/31/2024	10:30 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5	2	0.05	
12/31/2024	10:40 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.5	1	
12/31/2024	10:50 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.5	1.5	
12/31/2024	11:10 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	1	1	
12/31/2024	11:20 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.5	1.5	
12/31/2024	11:30 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1.5	1.5	
12/31/2024	11:40 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.5	1	
12/31/2024	12:00 PM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.5	1	
12/31/2024	12:10 PM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1	1	
12/31/2024	12:20 PM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48

**Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 12/01/2024 to 12/31/2024**

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
---------------------	---------------------	--------------------------------

All filters were inspected

Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Report
From 01/01/2025 to 01/31/2025

Definitions

Filter(s) Inspected: When the box is checked, the filter was inspected for active leaks, evidence of leaks, and any defects cracks in filter casing
Filter(s) Replaced: When the box is checked, a filter was replaced at this location on the date in the first column.

Date	Time	Floor	Location / Plumbing Outlet (For Publication)	Number of Filters	Filter(s) Inspected	Filter(s) Replaced	Design Flow Rate (GPM)	Cold Flow Rate (GPM)	Hot Flow Rate (GPM)	Mixed Flow Rate (GPM)
1/1/2025	12:00 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE		0.5			1.5
1/1/2025	12:10 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE		0.5			0.48
1/1/2025	1:09 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE		0.5			0.48
1/1/2025	1:15 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE		0.5			0.48
1/1/2025	1:16 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE		0.5			0.48
1/1/2025	1:17 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE		0.5			0.48
1/1/2025	1:26 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE		2			1.8
1/1/2025	1:27 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE		2			1.8
1/1/2025	1:28 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE		2			1.8
1/1/2025	1:29 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE		2			1.8
1/1/2025	1:41 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE		0.5			0.48
1/1/2025	1:43 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE		0.5			0.48
1/1/2025	1:48 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE		2			1.6
1/1/2025	1:49 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	TRUE	2			1.7
1/1/2025	1:50 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	TRUE	2			1.7
1/1/2025	1:51 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE		2			1.7
1/1/2025	1:52 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE		2			1.6
1/1/2025	1:53 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	TRUE	2			1.8
1/1/2025	8:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE		1.5	1	1	
1/1/2025	8:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE		1.5	1	5	
1/1/2025	8:40 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE		1.5	1.5	1	
1/1/2025	9:00 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE		1.5	1.5	1.5	
1/1/2025	9:20 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE		1.5	2	1.5	
1/1/2025	9:30 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE		1.5	1	1	
1/1/2025	9:40 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE		1.5	1	1	
1/1/2025	9:50 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE		1.5	1.5	1.5	
1/1/2025	10:00 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE		1.5	1.5	1.5	
1/1/2025	10:10 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE		1.5	1.5	1.5	
1/1/2025	10:20 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE		1.5	1	1	
1/1/2025	10:30 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE		1.5	1.5	1	
1/1/2025	10:30 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE		1.5	1.5	1.5	
1/1/2025	10:40 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE		1.5	1.5	1.5	
1/1/2025	11:00 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE			1.5	1.5	
1/1/2025	11:10 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE		1.5	1.5	1.5	
1/1/2025	11:30 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE		0.5			0.48
1/1/2025	11:50 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE		0.5			0.48
1/1/2025	1:42 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE		0.5			0.48
1/1/2025	10:06 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE			1.2	1.6	
1/1/2025	10:18 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE		1.6	1.2	1.6	
1/1/2025	10:31 PM	Floor 01	119-16A Shower	2	TRUE					1.1
1/1/2025	10:45 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE			1.7	1.8	
1/1/2025	10:51 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE		1.6			
1/1/2025	10:52 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE		1.6			
1/1/2025	11:02 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE		1.6			
1/1/2025	11:03 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE		1.6			
1/1/2025	11:17 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE		1.6			
1/1/2025	11:22 PM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE		1.6			
1/1/2025	11:26 PM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE		1.6			
1/6/2025	12:45 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
1/6/2025	12:46 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
1/6/2025	12:49 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE		0.5			0.48
1/6/2025	12:51 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE		0.5			0.48
1/6/2025	1:04 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
1/6/2025	1:15 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE		0.5			0.48
1/6/2025	1:16 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE		0.5			0.48
1/6/2025	1:17 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE		0.5			0.48
1/6/2025	1:38 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE		0.5			0.48
1/6/2025	1:44 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE			1.7		
1/6/2025	1:54 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6		
1/6/2025	2:04 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5			0.48
1/6/2025	2:05 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5			0.48
1/6/2025	2:11 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE		0.5			0.48
1/6/2025	2:12 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE		0.5			0.48
1/6/2025	2:32 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5			0.48

1/6/2025	2:33 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	2:34 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	2:43 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	2:44 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	2:50 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.3	1.3	
1/6/2025	2:55 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	1.1	1.1	
1/6/2025	3:15 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
1/6/2025	3:27 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	3:28 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	3:38 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	3:39 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	8:40 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	9:00 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	9:00 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1	1	
1/6/2025	9:02 AM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	9:10 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	9:12 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	9:14 AM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	9:16 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	9:18 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	9:20 AM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	9:25 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	9:30 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	9:32 AM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	9:44 AM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1		
1/6/2025	9:50 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	9:52 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	9:54 AM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:08 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:10 AM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:16 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:18 AM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:20 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:22 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	10:24 AM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:34 AM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.5		
1/6/2025	10:38 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:40 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:46 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	10:46 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:50 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	11:00 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	11:02 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	11:08 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	11:10 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	11:11 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	11:20 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		2		
1/6/2025	11:22 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	11:24 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	11:26 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	11:40 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	11:42 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	11:48 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	11:50 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	12:00 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	12:02 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	12:04 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	12:14 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		2		
1/6/2025	12:16 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	12:18 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	12:20 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	12:34 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	12:36 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	12:42 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	12:44 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	12:46 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	12:48 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	12:50 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	1:08 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		2		
1/6/2025	1:10 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	1:10 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	1:12 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	1:15 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	1:30 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48

1/6/2025	1:32 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	1:34 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	1:36 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	1:38 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	1:40 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	1:42 PM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		2		
1/6/2025	1:50 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:03 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/6/2025	10:08 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:09 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:12 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:13 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	10:14 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:25 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:26 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:29 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1
1/6/2025	10:30 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			1.8
1/6/2025	10:31 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			1.8
1/6/2025	10:44 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:45 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	10:46 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	10:56 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	10:57 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	11:04 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	11:08 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/6/2025	11:09 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/6/2025	11:10 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/6/2025	11:28 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
1/7/2025	8:30 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.5	1	
1/7/2025	8:40 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.5	1.5	
1/7/2025	9:10 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.5	1.5	
1/7/2025	9:20 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
1/7/2025	9:40 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.5	1.5	
1/7/2025	9:50 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.5	1.5	
1/7/2025	10:00 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.5	1	
1/7/2025	10:10 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.5	1.5	
1/7/2025	10:20 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1	1	
1/7/2025	10:30 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.5	1.5	
1/7/2025	10:40 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.5	1	
1/7/2025	10:50 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.5	1	
1/7/2025	11:00 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	2	2	
1/7/2025	11:10 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.5	1	
1/7/2025	11:30 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.5	1	
1/7/2025	11:40 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5	1.5	0.5	
1/7/2025	11:50 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.5	1	
1/7/2025	12:00 PM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	1.5	5	
1/7/2025	12:40 PM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.5	1	
1/7/2025	12:50 PM	Floor 05	540 Faucet (507-26) A (Second fixture)	2	TRUE	1.5	2	2	
1/7/2025	1:00 PM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.5	1	
1/7/2025	1:10 PM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.5	1.5	
1/7/2025	1:20 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1.5	1	
1/7/2025	1:30 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.5	1.5	
1/7/2025	1:40 PM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.5	1.5	
1/7/2025	2:00 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1	1	
1/8/2025	8:30 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2	1.5	
1/8/2025	8:40 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.5	1.5	
1/8/2025	8:44 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
1/8/2025	8:50 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
1/8/2025	9:10 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.5	1	
1/8/2025	9:20 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1	1	
1/8/2025	9:30 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.5	1	
1/8/2025	9:40 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	2	1.5	
1/8/2025	9:50 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.5	1	
1/8/2025	9:50 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	1.5	0.5	
1/8/2025	10:00 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	2	1.5	
1/8/2025	10:10 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.5	1.5	
1/8/2025	10:20 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1	1	
1/8/2025	10:40 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
1/8/2025	10:50 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
1/8/2025	10:50 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	2	1.5	
1/8/2025	11:00 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
1/8/2025	11:10 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	2	1.5	
1/8/2025	11:20 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1	1	
1/8/2025	11:30 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	1.5	1.5	1.5	

1/8/2025	12:30 PM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			1.5
1/8/2025	12:32 PM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
1/8/2025	12:36 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
1/8/2025	7:05 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/8/2025	7:06 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/8/2025	7:06 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/8/2025	7:08 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			0.5
1/8/2025	7:09 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			0.5
1/8/2025	7:10 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			0.5
1/8/2025	7:11 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			0.5
1/8/2025	7:26 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.5
1/8/2025	7:28 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.5
1/8/2025	7:28 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.5
1/8/2025	7:34 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			1
1/8/2025	7:38 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			1
1/8/2025	7:39 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			0.5
1/8/2025	7:41 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			0.5
1/8/2025	7:42 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			1
1/8/2025	7:43 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			1
1/8/2025	8:07 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		2	3	
1/8/2025	8:15 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	1	2	
1/8/2025	8:20 PM	Floor 01	119-16A Shower	2	TRUE				0.5
1/8/2025	8:25 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1 1/2	2	
1/8/2025	8:30 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
1/8/2025	8:30 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
1/8/2025	8:36 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6			
1/8/2025	8:42 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6	1	1/2	
1/8/2025	8:45 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6	1	1	
1/13/2025	12:21 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	12:22 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	12:27 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	12:28 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	12:29 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	12:39 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	12:40 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	12:46 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	12:47 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	12:48 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	12:55 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.7		
1/13/2025	1:01 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	1:02 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	1:03 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	1:13 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1.5
1/13/2025	1:14 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	1:21 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			2
1/13/2025	1:22 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			2.5
1/13/2025	1:26 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	1:27 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	1:28 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	1:36 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/13/2025	1:44 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	1:45 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	1:46 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	1:55 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	1:56 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	2:06 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	2:08 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	2:11 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	2:12 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	2:13 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	2:20 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
1/13/2025	2:26 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	2:27 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	2:28 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	2:37 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	2:38 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	2:45 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	2:46 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	2:47 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	2:50 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	2:51 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	2:58 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
1/13/2025	4:26 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.5
1/13/2025	4:29 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.5

1/13/2025	4:29 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	4:32 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.5		
1/13/2025	4:32 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	4:32 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	4:33 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	4:45 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	4:45 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/13/2025	4:53 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	4:56 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	4:56 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/13/2025	5:04 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	65	122	
1/13/2025	5:04 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	68	123	
1/13/2025	5:23 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
1/13/2025	5:30 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
1/13/2025	8:50 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.5	1.5	
1/13/2025	8:56 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:02 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:02 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	7:03 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	7:06 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:06 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/13/2025	7:13 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/13/2025	7:25 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	7:26 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:28 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:28 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/13/2025	7:29 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	7:34 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	7:35 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:35 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/13/2025	7:38 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:38 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	7:45 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:48 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	7:48 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/13/2025	7:48 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	8:00 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	8:01 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	8:01 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/13/2025	8:08 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	8:08 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	8:15 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	8:16 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	8:19 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	8:19 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/13/2025	8:19 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	8:25 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/13/2025	8:28 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	8:56 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/13/2025	10:06 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	10:07 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	10:12 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	10:13 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	10:14 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	10:22 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	10:23 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	10:28 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	10:29 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	10:30 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	10:37 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/13/2025	10:42 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	10:43 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	10:44 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	10:52 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	10:53 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	10:59 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	11:00 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	11:03 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/13/2025	11:04 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/13/2025	11:05 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/13/2025	11:13 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/13/2025	11:15 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.5
1/14/2025	9:00 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	2	1.5	
1/14/2025	9:10 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48

1/14/2025	9:20 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1.5	1
1/14/2025	9:30 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	2	1.5
1/14/2025	9:40 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.5	1
1/14/2025	9:50 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.5	1
1/14/2025	10:00 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.5	1.5
1/14/2025	10:10 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.5	1.5
1/14/2025	10:20 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1	1
1/14/2025	10:30 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1	1
1/14/2025	10:40 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.5	1.5
1/14/2025	10:50 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1.5	1.5
1/14/2025	11:00 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	2	1.5
1/14/2025	11:10 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.5	1
1/14/2025	11:30 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.5	1.5
1/14/2025	11:30 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	1.5	1.5
1/14/2025	11:40 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1.5	1
1/14/2025	11:50 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1	1
1/14/2025	11:50 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.5	1
1/14/2025	12:00 PM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1	1
1/14/2025	12:10 PM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.5	1.5
1/14/2025	12:20 PM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.5	1.5
1/14/2025	12:30 PM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1	1
1/15/2025	12:02 AM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6		
1/15/2025	12:17 AM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE	1.6		
1/15/2025	12:29 AM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6		
1/15/2025	12:53 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5		0.48
1/15/2025	12:54 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5		0.48
1/15/2025	12:55 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5		0.48
1/15/2025	1:03 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2		1.8
1/15/2025	1:04 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2		1.8
1/15/2025	1:05 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2		1.8
1/15/2025	1:06 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2		1.8
1/15/2025	1:16 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5		0.48
1/15/2025	1:17 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5		0.48
1/15/2025	1:20 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5		0.48
1/15/2025	1:28 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2		1.8
1/15/2025	1:29 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2		1.8
1/15/2025	1:30 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2		1.6
1/15/2025	1:31 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2		1.8
1/15/2025	1:32 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	TRUE	2	1.8
1/15/2025	1:33 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2		1.8
1/15/2025	8:00 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5		0.48
1/15/2025	8:10 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5		0.48
1/15/2025	9:50 AM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1	1
1/15/2025	9:50 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		1.5	1.5
1/15/2025	10:00 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.5	1.5
1/15/2025	10:10 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.5	1
1/15/2025	10:20 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1	1
1/15/2025	10:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.5	1.5
1/15/2025	10:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	1	0.5
1/15/2025	10:40 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.5	1.5
1/15/2025	10:47 AM	Floor 01	119-16A Shower	2	TRUE			1
1/15/2025	10:50 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	2	1.5
1/15/2025	11:00 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.5	1.5
1/15/2025	11:10 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	1.5	2	1.5
1/15/2025	11:20 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.5	1.5
1/15/2025	11:30 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1	1
1/15/2025	11:40 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5		1
1/15/2025	11:50 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5		0.48
1/15/2025	12:00 PM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5		0.48
1/15/2025	12:10 PM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.5	1.5
1/15/2025	12:20 PM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.5	1.5
1/15/2025	12:30 PM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.5	1
1/15/2025	12:40 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	2	1.5
1/15/2025	8:20 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.5	1.5
1/15/2025	10:06 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE	TRUE	1.5	1.5
1/15/2025	10:19 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6		
1/15/2025	10:20 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6		
1/15/2025	10:31 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	TRUE	1.6	1.5
1/15/2025	11:02 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1.5	1.5
1/15/2025	11:15 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6		
1/15/2025	11:16 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6		
1/20/2025	12:57 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48
1/20/2025	12:58 AM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5		0.48
1/20/2025	1:00 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5		0.48

1/20/2025	1:01 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/20/2025	1:02 AM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	1:22 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	1:23 AM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	1:26 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	1:27 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/20/2025	1:28 AM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	1:55 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.48
1/20/2025	1:58 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE			1.6	
1/20/2025	2:03 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.7	
1/20/2025	2:13 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	2:14 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	2:22 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	2:23 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	2:48 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/20/2025	2:49 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
1/20/2025	2:50 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/20/2025	2:59 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE		0.5		0.48
1/20/2025	3:00 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE		0.5		0.48
1/20/2025	3:01 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE		0.5		0.48
1/20/2025	3:14 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	1.2	1.2	
1/20/2025	3:15 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	1.3	1.3	
1/20/2025	3:19 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE			1.6	
1/20/2025	3:27 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	3:28 AM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	3:35 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	3:36 AM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	9:00 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.5	1.5	
1/20/2025	6:55 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	6:56 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:00 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:00 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:03 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.6	
1/20/2025	7:13 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:14 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:16 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:16 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	7:18 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	7:18 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:25 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:26 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:26 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	7:31 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:31 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:36 PM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.8	
1/20/2025	7:40 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:41 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:44 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:44 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	7:44 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:45 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:46 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:46 PM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	7:48 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.5	
1/20/2025	7:50 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:50 PM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:52 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:53 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	7:53 PM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	7:55 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	7:55 PM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:03 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	8:04 PM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:04 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:06 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	8:06 PM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	8:09 PM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE			1.7	
1/20/2025	8:14 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	8:15 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:15 PM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	8:17 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:17 PM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	8:21 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:30 PM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5

1/20/2025	8:34 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:34 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	8:34 PM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	8:54 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	8:55 PM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:55 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	8:55 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	8:55 PM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	9:00 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	9:01 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	9:01 PM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	9:05 PM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.7		
1/20/2025	9:05 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	9:05 PM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	9:18 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	9:20 PM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	9:26 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/20/2025	9:26 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/20/2025	9:28 PM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/20/2025	9:32 PM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.5		
1/20/2025	10:11 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/20/2025	10:15 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	10:16 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	10:17 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	10:19 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/20/2025	10:20 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	10:33 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	10:34 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	10:36 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			1
1/20/2025	10:37 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			1.8
1/20/2025	10:38 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		2
1/20/2025	10:50 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	10:51 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/20/2025	10:52 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	11:01 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	11:02 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	11:11 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	11:13 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/20/2025	11:14 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/20/2025	11:15 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/20/2025	11:30 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
1/21/2025	8:20 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	1	1	
1/21/2025	8:30 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.5	1	
1/21/2025	8:40 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.5	1.5	
1/21/2025	8:50 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
1/21/2025	9:30 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.5	1.5	
1/21/2025	9:40 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	2	1.5	
1/21/2025	10:00 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	2	1.5	
1/21/2025	10:10 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06)	2	TRUE	1.5	1.5	1	
1/21/2025	10:20 AM	Floor 06	Suite 615 Break Room-Kitchen Faucet (607-06A) A (Second fixture)	2	TRUE	1.5	1.5	0.5	
1/21/2025	10:30 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.5	0.5	
1/21/2025	10:40 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	1.5	0.5	
1/21/2025	10:50 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1	1	
1/21/2025	11:00 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1	1	
1/21/2025	11:10 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.5	1.5	
1/21/2025	11:20 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1	1	
1/21/2025	11:30 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.5	1.5	
1/21/2025	12:00 PM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	2	1.5	
1/22/2025	8:20 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.5	1.5	
1/22/2025	8:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1.5	1	
1/22/2025	8:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	1.5	1.5	
1/22/2025	9:10 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1	1	
1/22/2025	9:20 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	1.5	1	
1/22/2025	9:30 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.5	1	
1/22/2025	9:40 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
1/22/2025	9:50 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.5	1	
1/22/2025	10:00 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.5	1	
1/22/2025	10:10 AM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
1/22/2025	10:10 AM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.5	1.5	
1/22/2025	10:20 AM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
1/22/2025	10:40 AM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
1/22/2025	11:10 AM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		1.5	1.5	
1/22/2025	11:20 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.5	1	
1/22/2025	11:30 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.5	1.5	

1/22/2025	12:10 PM	Floor 04	Suite 410 Kitchenette Faucet (NW)	2	TRUE	1.5	1.5	1	
1/22/2025	12:20 PM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1.5	1.5	
1/22/2025	1:50 PM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	1.5	2	1.5	
1/22/2025	7:00 PM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/22/2025	7:01 PM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/22/2025	7:01 PM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/22/2025	7:10 PM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	2			1
1/22/2025	7:13 PM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	2			0.5
1/22/2025	7:17 PM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	2			1
1/22/2025	7:18 PM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	2			0.5
1/22/2025	7:31 PM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	0.5			0.5
1/22/2025	7:32 PM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	0.5			0.5
1/22/2025	7:32 PM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	0.5			0.5
1/22/2025	7:35 PM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE	2			0.5
1/22/2025	7:37 PM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	2			0.5
1/22/2025	7:38 PM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE	2			1
1/22/2025	7:38 PM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE	2			1
1/22/2025	7:39 PM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	2			0.5
1/22/2025	7:40 PM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE	2			0.5
1/22/2025	8:05 PM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		3	2.5	
1/22/2025	8:15 PM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1	1.5	
1/22/2025	8:17 PM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	1 1/2	2.5	
1/22/2025	8:26 PM	Floor 01	119-16A Shower	2	TRUE				0.5
1/22/2025	8:34 PM	Floor 01	119-11 Toilet/Sink Combo	2	TRUE	1.6			
1/22/2025	8:40 PM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6			
1/22/2025	8:45 PM	Floor 01	119-10 Toilet/Sink Combo	2	TRUE	1.6			
1/22/2025	8:48 PM	Floor 01	119-07 Toilet/Sink Combo-Right	2	TRUE	1.6			
1/22/2025	8:52 PM	Floor 01	119-07 Toilet/Sink Combo-Left	2	TRUE	1.6			
1/22/2025	8:57 PM	Floor 01	119-08 Toilet/Sink Combo-Left	2	TRUE	1.6			
1/22/2025	8:59 PM	Floor 01	119-08 Toilet/Sink Combo-Right	2	TRUE	1.6			
1/27/2025	12:21 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	12:22 AM	Floor 08	8M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	12:26 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/27/2025	12:27 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	12:28 AM	Floor 08	8W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	12:36 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	12:37 AM	Floor 08	8M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	12:43 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/27/2025	12:44 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	12:44 AM	Floor 08	8W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	12:51 AM	Floor 08	C807-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/27/2025	12:55 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	12:56 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/27/2025	12:57 AM	Floor 07	7W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	1:07 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	1:08 AM	Floor 07	7M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	1:12 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	1:13 AM	Floor 07	7M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			2.6
1/27/2025	1:16 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	1:17 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/27/2025	1:18 AM	Floor 07	7W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	1:26 AM	Floor 07	C707-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/27/2025	1:31 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	1:32 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/27/2025	1:33 AM	Floor 06	6W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	1:43 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	1:44 AM	Floor 06	6M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	1:51 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	1:52 AM	Floor 06	6M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	1:56 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	1:57 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/27/2025	1:58 AM	Floor 06	6W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	2:08 AM	Floor 06	C607-Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
1/27/2025	2:13 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	2:14 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/27/2025	2:15 AM	Floor 05	5W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	2:30 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	2:31 AM	Floor 05	5M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	2:38 AM	Floor 05	C507 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
1/27/2025	2:44 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	2:45 AM	Floor 05	5M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48
1/27/2025	2:48 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.48
1/27/2025	2:49 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.48
1/27/2025	2:50 AM	Floor 05	5W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.48

1/27/2025	4:00 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	4:00 AM	Floor 01	1W-2 Women's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	4:08 AM	Floor 01	114-2 Loading Dock - Janitor's Closet - Mop/Slop Sink	2	TRUE		1.9		
1/27/2025	4:10 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	4:10 AM	Floor 01	1M-2 Men's Restroom South - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	4:20 AM	Floor 01	1U-1 Loading Dock - Lavatory Faucet	2	TRUE	0.5			0.5
1/27/2025	4:25 AM	Floor 01	C105-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		2		
1/27/2025	4:31 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	4:36 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	4:37 AM	Floor 01	1W-1 Women's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/27/2025	4:48 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	4:50 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	4:51 AM	Floor 01	1M-1 Men's Restroom North - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/27/2025	4:56 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Small	1	TRUE	1.5	70	122	
1/27/2025	4:56 AM	Floor 01	108-4 Cafe Prep. - Kitchen Faucet-Large	1	TRUE	1.5	68	124	
1/27/2025	5:00 AM	Floor LL	CLL09-1 Janitor's Closet - Mop/Slop Sink	1	TRUE		1.6		
1/27/2025	8:50 AM	Floor 10	Suite 1015 GSA Kitchenette Faucet (1000-03)	2	TRUE	1.5	1.5	1	
1/27/2025	5:25 PM	Floor 02EC	E201 Restroom - Lavatory Faucet	1	TRUE	0.5			0.5
1/27/2025	6:48 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	6:49 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	6:49 PM	Floor 04	4W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/27/2025	6:51 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	6:51 PM	Floor 04	4M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	7:05 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	7:06 PM	Floor 04	4M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	7:12 PM	Floor 04	4W-2 Women West-Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	7:12 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/27/2025	7:12 PM	Floor 04	4W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	7:16 PM	Floor 04	C407 Janitor's Closet-Mop/Slop Sink	1	TRUE		1.9		
1/27/2025	7:30 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	7:31 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	7:31 PM	Floor 03	3W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/27/2025	7:35 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	7:35 PM	Floor 03	3M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	7:50 PM	Floor 03	3M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	7:55 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	7:55 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/27/2025	7:55 PM	Floor 03	3W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	8:04 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	8:05 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	8:05 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	8:05 PM	Floor 02	2W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/27/2025	8:08 PM	Floor 02	2M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	8:30 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	8:31 PM	Floor 02	2M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	8:34 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	8:34 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	0.5			0.5
1/27/2025	8:34 PM	Floor 02	2W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	8:50 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	8:52 PM	Floor LL	LLM-1 Men-Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	8:55 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Right	1	TRUE	0.5			0.5
1/27/2025	8:56 PM	Floor LL	LLW-1 Women-Lavatory Faucet-Left	1	TRUE	0.5			0.5
1/27/2025	10:04 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:05 PM	Floor 10	10M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:09 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:10 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:11 PM	Floor 10	10W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:19 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:20 PM	Floor 10	10M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:25 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:26 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:27 PM	Floor 10	10W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:35 PM	Floor 10	C1007-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		
1/27/2025	10:44 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:45 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:46 PM	Floor 09	9W-1 Women's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:57 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	10:58 PM	Floor 09	9M-1 Men's Restroom East - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	11:10 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	11:11 PM	Floor 09	9M-2 Men's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	11:13 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/27/2025	11:14 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
1/27/2025	11:15 PM	Floor 09	9W-2 Women's Restroom West - Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/27/2025	11:23 PM	Floor 09	C907-Janitor's Closet-Mop/Slop Sink	1	TRUE		1.6		

1/28/2025	8:10 AM	Floor 10	Suite 1008 Break Room-Kitchen Faucet (1009-07)	2	TRUE	1.5	2	1.5	
1/28/2025	8:20 AM	Floor 10	Suite 1009C Break Room-Kitchen Faucet (1009-19)	2	TRUE	1.5	1.5	1.5	
1/28/2025	8:30 AM	Floor 10	Suite 1010 Kitchenette Faucet	2	TRUE	1.5	1.5	1	
1/28/2025	8:40 AM	Floor 10	Suite 1010 Lavatory Faucet	1	TRUE	1.5			0.48
1/28/2025	9:00 AM	Floor 09	Suite 907A Break Room Faucet (907-22)	2	TRUE	1.5	1.5	1	
1/28/2025	9:10 AM	Floor 09	Suite 908 Break Room Faucet (908-15)	2	TRUE	1.5	1.5	1	
1/28/2025	9:20 AM	Floor 09	Suite 910A Faucet (910-05)	2	TRUE	1.5	1.5	1.5	
1/28/2025	9:30 AM	Floor 08	Suite 808A Break Room Faucet (809-02)	1	TRUE	1.5	1.5	1.5	
1/28/2025	9:40 AM	Floor 08	Suite 810 Kitchen Faucet	1	TRUE	1.5	1	1	
1/28/2025	9:50 AM	Floor 07	Suite 707-01 Break Room - Faucet (707-2)	2	TRUE	1.5	1.5	1	
1/28/2025	10:00 AM	Floor 07	Suite 707-10 Faucet (707-07)	2	TRUE	1.5	1.5	1	
1/28/2025	10:10 AM	Floor 07	Suite 710 Faucet (710-03)	2	TRUE	1.5	1	1	
1/28/2025	10:20 AM	Floor 06	Suite 608 Kitchen - Faucet	2	TRUE	1.5	1.5	1.5	
1/28/2025	10:30 AM	Floor 06	Suite 614 Room-Kitchen Faucet (610-03)	2	TRUE	1.5	1.5	1.5	
1/28/2025	10:40 AM	Floor 06	Suite 620 Break Room-Kitchen Faucet (608-12)	2	TRUE	1.5	1.5	1	
1/28/2025	10:40 AM	Floor 06	Suite 620 Break Room Kitchen - Faucet (608-12A) A (Second fixture)	1	TRUE	1.5	1.5	0.5	
1/28/2025	10:50 AM	Floor 04	Suite 540 Kitchenette - Faucet (507-25)	2	TRUE	1.5	1	1	
1/28/2025	11:00 AM	Floor 05	540 Faucet (507-26)	2	TRUE	1.5	1.5	1	
1/28/2025	11:10 AM	Floor 05	Suite 540 Training Lobby - Faucet (507-12)	2	TRUE	1.5	1.5	1	
1/28/2025	11:20 AM	Floor 05	Suite 535 Break Room-Kitchen Faucet (507-36)	2	TRUE	1.5	1	1	
1/28/2025	11:30 AM	Floor 05	Suite 532 Lactation Room - Faucet	2	TRUE	1.5	1.5	1.5	
1/28/2025	11:40 AM	Floor 05	Suite 530 Kitchenette - Faucet (509-10)	2	TRUE	1.5	1.5	1	
1/28/2025	11:50 AM	Floor 05	Suite 540 CBP Open Area Kitchenette - Faucet (507-15)	2	TRUE	1.5	1.5	1	
1/28/2025	1:30 PM	Floor 05	Suite 520 Kitchenette Faucet (508-13)	2	TRUE	1.5	1.5	1.5	
1/29/2025	12:12 AM	Floor 01	119-02 Mailroom - Faucet	2	TRUE		1.6	1.6	
1/29/2025	12:26 AM	Floor 01	119-19 Food Storage Room-Sink/Faucet	2	TRUE	1.6	1.6	1.6	
1/29/2025	12:39 AM	Floor 01	119-16A Shower	2	TRUE				1
1/29/2025	12:51 AM	Floor 01	119-21 Faucet/Eyewash	2	TRUE		1.5	1.5	
1/29/2025	2:01 AM	Floor 01	119-17 Toilet/Sink Combo	2	TRUE	1.6			
1/29/2025	2:28 AM	Floor 01	126-02 Women-Lavatory Faucet-Left	1	TRUE	TRUE	0.5		0.48
1/29/2025	2:29 AM	Floor 01	126-02 Women-Lavatory Faucet-Center	1	TRUE	TRUE	0.5		0.48
1/29/2025	2:30 AM	Floor 01	126-02 Women-Lavatory Faucet-Right	1	TRUE	TRUE	0.5		0.48
1/29/2025	2:37 AM	Floor 01	126-03 Women-Shower-1st from L to R	1	TRUE	TRUE	2		1.9
1/29/2025	2:38 AM	Floor 01	126-03 Women-Shower-2nd from L to R	1	TRUE	TRUE	2		1.9
1/29/2025	2:39 AM	Floor 01	126-03 Women-Shower-3rd from L to R	1	TRUE	TRUE	2		1.9
1/29/2025	2:40 AM	Floor 01	126-03 Women-Shower-4th from L to R	1	TRUE	TRUE	2		1.9
1/29/2025	2:43 AM	Floor 01	126-05 Men-Lavatory Faucet-Left	2	TRUE	TRUE	0.5		0.48
1/29/2025	2:44 AM	Floor 01	126-05 Men-Lavatory Faucet-Center	2	TRUE	TRUE	0.5		0.48
1/29/2025	2:45 AM	Floor 01	126-05 Men-Lavatory Faucet-Right	2	TRUE	TRUE	0.5		0.48
1/29/2025	2:51 AM	Floor 01	126-06 Shower Room - Shower-North-Left	1	TRUE	TRUE	2		1.9
1/29/2025	2:52 AM	Floor 01	126-06 Shower Room-Shower-North-Center	1	TRUE		2		1.9
1/29/2025	2:53 AM	Floor 01	126-06 Shower Room - Shower-North-Right	1	TRUE		2		1.8
1/29/2025	2:54 AM	Floor 01	126-06 Shower Room - Shower-South-Left	1	TRUE	TRUE	2		1.9
1/29/2025	2:55 AM	Floor 01	126-06 Shower Room-Shower-South-Center	1	TRUE		2		1.8
1/29/2025	2:56 AM	Floor 01	126-06 Shower Room - Shower-South-Right	1	TRUE		2		1.8
1/29/2025	9:00 AM	Floor 04	Suite 415 Kitchenette - Faucet (N)	2	TRUE	1.5	1.5	1	
1/29/2025	9:10 AM	Floor 04	Suite 416 Kitchenette - Faucet (NE) - North	2	TRUE	1.5	1	1	
1/29/2025	9:20 AM	Floor 04	Suite 420 Kitchenette - Faucet (NE) - South	2	TRUE	1.5	1.5	1	
1/29/2025	9:30 AM	Floor 04	Suite 435 Kitchenette Faucet (SE)	2	TRUE	1.5	1	1	
1/29/2025	9:40 AM	Floor 04	Suite 435 Kitchenette Faucet (SE) A (Second fixture)	2	TRUE	1.5	1	0.5	
1/29/2025	10:00 AM	Floor 02	Break Room North West - Kitchen Faucet (207-14)	2	TRUE	1.5	1.5	1	
1/29/2025	10:10 AM	Floor 02	Break Room North East Kitchen - Faucet (207-39)	2	TRUE	1.5	2	1.5	
1/29/2025	10:20 AM	Floor 02	Break Room South East Kitchen - Faucet (207-49)	2	TRUE	1.5	1.5	1.5	
1/29/2025	10:30 AM	Floor 02	234 Kitchen Faucet (209-04)	2	TRUE	1.5	1.5	1.5	
1/29/2025	10:40 AM	Floor 01	GSA Suite Kitchenette-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
1/29/2025	10:50 AM	Floor 01	113-6 JLL Kitchenette-Kitchen Faucet	2	TRUE	1.5	1.5	1	
1/29/2025	11:00 AM	Floor 01	123-05 Health Unit - Sink/Faucet	2	TRUE	0.5			0.48
1/29/2025	11:10 AM	Floor 01	123-07 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
1/29/2025	11:20 AM	Floor 01	123-08 Health Unit-Lavatory Faucet	2	TRUE	0.5			0.48
1/29/2025	11:30 AM	Floor 01	128-01 Lactation Room A-Sink/Faucet	2	TRUE	1.5	1.5	1	
1/29/2025	11:40 AM	Floor 01	128-02 Lactation Room B-Sink/Faucet	2	TRUE	1.5	1.5	1.5	
1/29/2025	11:50 AM	Floor 01	128-03 Lactation Room C-Sink/Faucet	2	TRUE	1.5	1.5	1	
1/29/2025	12:00 PM	Floor 01	128-04 Lactation Room D-Sink/Faucet	2	TRUE	1.5	1.5	1	
1/29/2025	12:10 PM	Floor LL	LL15 Men's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
1/29/2025	12:30 PM	Floor LL	LL15 Women's Restroom - Lavatory Faucet	1	TRUE	0.5			0.48
1/29/2025	12:40 PM	Floor LL	LL15 Break Room-Kitchen Faucet	2	TRUE	1.5	1.5	1.5	
1/29/2025	1:00 PM	Floor LL	Print, Postal Sorting Area Faucet	2	TRUE		2	2	

Rosa Parks Federal Building
Weekly .2 Micron Filter Inspection Exception Report
From 01/01/2025 to 01/31/2025

There is no record of inspection for the fixtures/filters listed below for the planned inspection date. GSA is working with maintenance contractor to ensure all filters are inspected and inspections are logged accordingly.

Outlets w/Filters that are not included in the log

Planned Date	Asset Number	Publication Description
---------------------	---------------------	--------------------------------

All filters were inspected